

BID FORM INSTRUCTIONS

Sealed bids will be received at the office of the City Auditor, City Hall, 225 4th Street North, Fargo, North Dakota 58102, until 11:30 o'clock a.m., Wednesday, December 26, 2018, and then publicly opened and read aloud at the Meadowlark Room, located on the second floor of City Hall (225 4th Street North), for the City of Fargo Water Treatment Plant for the chemical Lime to be delivered as ordered between the hours of 7:30 am to 4:00 pm Monday through Friday for the year 2019.

Please use only one bid form. Also, please be sure to label the outside of your envelope **"Fargo Water Treatment Plant Lime Chemical Bid."**

If addendums are issued, the bidder must acknowledge receipt of the addendum on the outside of the bid envelope, or the bid will be rejected and returned to the bidder unopened.

The specification for lime accompanies the bid form. Please include all documentation requested in the lime specification and complete all blanks on the bid form. By signing the Bid form, you are acknowledging the specifications and requirements as listed for the chemical lime.

LIME (CaO) SPECIFICATIONS

Lime shall be priced per ton, delivered in dry form in a bulk tank truck, f.o.b. to the Fargo Water Treatment Plant, 435 14th Avenue South, Fargo, North Dakota, 58103.

The Fargo Water Treatment Plant owns one lime storage bin with a capacity of 301 tons. The storage bin will be filled from an exterior fill station with 4" quick disconnect type couplings.

Delivery trucks with pneumatic blowers are required to unload the chemical.

Lime shall conform to the American Water Works Specification Standard B202-13. It shall be high calcium quicklime, ¼" to ¾" in size.

Lime shall contain a minimum of 90% available calcium oxide and a maximum of 2.5% magnesium oxide.

On slaking, the lime shall produce a minimum 40-degree centigrade temperature rise in the first 30 seconds.

Consider the following five-year historical usage summary. Usage in 2019 is anticipated to be similar, so please plan deliveries accordingly.

FIVE YEAR AVERAGE MONTHLY CHEMICAL USAGE (TONS)

January	February	March	April	May	June	July	August	September	October	November	December
379	330	380	266	416	526	595	548	456	369	372	423

Annual Total=5,060

An SDS (Material) Safety Data Sheet) must accompany the bid.

Documentation of ANSI/NSF Standard 60 certification and maximum application dosage in potable water treatment must accompany the bid.

All fuel surcharges must be included as part of the bid submitted.

BID FORM

**Annual Bid to supply the chemical Lime for the City of Fargo, ND, Water Treatment Plant
from January 1, 2019 through December 31, 2019**

**Bid opening - 11:30am Wednesday, December 26, 2018.
Meadowlark Room on 2nd Floor of City Hall - 225 4th ST N**

Credit Card Guaranteed Price = _____\$/Ton
Credit Card payment (NA) if not acceptable

Purchase Order Guaranteed Price = _____\$/Ton

By signing, I acknowledge the specifications and requirements for lime listed above.

Company Submitting Quote: _____

Signature of Authorized Representative: _____