



2022

WATER QUALITY

REPORT

Troy B. Hall
Water Utility Director

Daniel L. Portlock
Water Utility Engineer

Brian A. Ward
WTP Superintendent

The City of Fargo Water Treatment Plant is issuing this report to inform customers about the quality of water produced and distributed in 2022.

If you are a large-volume user, please distribute a copy of this Water Quality Report to consumers who do not receive a bill.

If you have questions about Fargo drinking water, please contact the Water Treatment Plant at 701.241.1469.

If you are aware of non-English speaking individuals who need help with the appropriate language translation, please contact the Communications & Governmental Affairs Team at 701.241.1310.

If you would like opportunities for public participation in decisions that affect water quality, please attend Fargo City Commission meetings, which are held every two weeks. Please visit the City of Fargo web site for exact meeting dates and times.

<https://www.fargond.gov/city-government/departments/city-commission>



AESTHETIC WATER QUALITY AVERAGES FOR 2022

Total Hardness > 132 (ppm) or 7.72 grains/gallon

Total Dissolved Solids > 391 (ppm)

Iron > Less than 0.01 (ppm)

Manganese > Less than 0.01 (ppm)

pH > 9.14

WHAT YOU NEED TO KNOW ABOUT DRINKING WATER REGULATIONS

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

In order to ensure tap water is safe to drink, the Environmental Protection Agency (EPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking water Hotline (800.426.4791) or visiting their website.

<https://www.epa.gov/ground-water-and-drinking-water/safe-drinking-water-information>

Before the City of Fargo delivers water to your home it is thoroughly tested. All regulatory testing is performed in certified laboratories. In addition, the Fargo Water Treatment Plant is staffed with Certified Operators and Environmental Laboratory Technicians who are monitoring and testing your water to ensure that drinking water standards enforced by the North Dakota Department of Environmental Quality (NDDEQ) are maintained.

The Fargo Water Treatment Plant complies with the EPA Safe Drinking Water Act by routinely testing for contaminants. The contaminants detected and values are listed in the Monitoring Results Tables. Certain contaminants require testing less than once per year. The concentrations of these contaminants are not expected to vary significantly from year to year. This data, while still representative of the water quality, is more than a year old and is also listed in the Monitoring Tables. In 2022, there were no contaminants that exceeded the Maximum Contaminant level (MCL), which is the highest level of a substance allowed in drinking water as set forth by the EPA.

Contaminants that may be present in source water:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive Contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800.426.4791).

Lead and Copper

The MCL for lead and copper is known as the Action Level (AL). This is the concentration which, if exceeded, triggers treatment or other requirements a water system must follow. Ninety percent of all samples tested must be below this concentration. During 2022, no sample site on the City of Fargo water distribution system tested above the AL for lead and copper.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Fargo Water Treatment Plant is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. **Use water from the cold tap for drinking and cooking. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.** If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800.426.4791) or at:

<https://www.epa.gov/ground-water-and-drinking-water/basic-information-about-lead-drinking-water>

MICROBIAL CONTAMINANTS

Turbidity	Treatment Technique (TT)	< 1.0 (NTU) (100%)	MWTP < 0.15 (NTU) (95%) LSWTP < 0.3 (NTU) (95%)	Level Detected (NTU)	Range (NTU)
(MWTP) Effluent	Ultra Filtration; Reverse Osmosis; Disinfection	100% of samples	100 % of samples	0.089 6/3/2022	0.01 to 0.089
(LSWTP) Effluent	Filtration; Disinfection	100% of samples	100 % of samples	0.285 6/1/2022	0.01 to 0.146

LEAD AND COPPER

Substance (monitored at tap) (units) test date	AL	90th Percentile	Sites Exceeding AL	Major Source of Contaminant
Copper (ppm) 8/4/2022	1.3	0.0617	0 of 50 sites	Corrosion of household plumbing systems Erosion of natural deposits
Lead (ppb) 8/4/2022	15	2.04	0 of 50 sites	Corrosion of household plumbing systems Erosion of natural deposits

Substance (monitored at tap) (units) test date	MCL	MCLG	Highest Compliance Level	Major Source of Contaminant
Barium (ppm) 4/17/2018	2	2	0.0376	Discharge of drilling wastes; Discharge from metal refineries; Erosion of Natural Deposits
Fluoride (ppm) 4/17/2018	4	4	0.625	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate - Nitrite (ppm) 6/22/2022	10	10	0.354	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

INORGANIC CONTAMINANTS

Substance (monitored at tap) (units) test date	MCL	MCLG	Highest Compliance Level	Major Source of Contaminant
Barium (ppm) 4/17/2018	2	2	0.0376	Discharge of drilling wastes; Discharge from metal refineries; Erosion of Natural Deposits
Fluoride (ppm) 4/17/2018	4	4	0.625	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate - Nitrite (ppm) 6/22/2022	10	10	0.354	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

RADIOACTIVE CONTAMINANTS

Gross Alpha, Including RA, Excluding RN & U (pCi/l) 7/17/2018	15	15	2.44	Erosion of natural deposits
Radium, Combined (226, 228) (pCi/l) 7/17/2018	5	N/A	0.166	Erosion of natural deposits

..... **DISINFECTANTS**

Substance (monitored at tap) (units) test date	MRDL	MRDLG	Highest Compliance Level	Range	Major Source of Contaminant
Chloramine (ppm) 6/30/2022	4	4	3.1	2.82 to 3.13	Water additive used to control microbes

Substance (monitored at tap) (units) test date	MCL	MCLG	Highest Compliance Level	Range	Major Source of Contaminant
--	-----	------	--------------------------------	-------	-----------------------------

..... **UNREGULATED CONTAMINANTS**

Alkalinity, Carbonate (ppm) 12/20/2022	N/A	N/A	17	ND - 17	Naturally present when water passes through rock and soil which contains carbonate, bicarbonate, and hydroxide compounds
Bicarbonate as HCO ₃ (ppm) 12/20/2022	N/A	N/A	457	52 - 457	Naturally present when water passes through rock and soil which contains carbonate, bicarbonate, and hydroxide compounds
Bromide (ppm) 12/12/2022	N/A	N/A	270	22 - 270	Discharge from oil and gas production and coal-fired steam electric power plants Erosion of natural deposits
Calcium (ppm) 12/20/2022	N/A	N/A	60.3	22 – 60.3	Naturally present when water passes through rock and soil. It may dissolve from rocks such as limestone, marble, calcite, dolomite, gypsum, fluorite and apatite
Conductivity @ 25 C (umho/cm) 12/20/2022	N/A	N/A	935	320 - 935	Conductive ions from dissolved salts and inorganic materials such as alkalis, chlorides, sulfides and carbonate compounds naturally present in water
Orthophosphate (ppm) 12/20/2022	N/A	N/A	0.351	0.006 – 0.351	Water additive used to inhibit corrosion
pH 12/20/2022	N/A	N/A	9.36	8.19 – 9.36	Measure of how acidic or basic water is.
Total Dissolved Solids (ppm) 12/20/2022	N/A	N/A	580	198 - 580	Organic and inorganic materials either naturally occurring or man- made that are dissolved in water

Substance (monitored at tap) (units) test date	MCL	MCLG	Highest Compliance Level	Range	Major Source of Contaminant
--	-----	------	--------------------------------	-------	-----------------------------

TOTAL ORGANIC CARBON REMOVAL

Alkalinity - Source (ppm) 12/31/2022	N/A	N/A	375	164 to 375	Naturally present when water passes through rock and soil which contains carbonate, bicarbonate, and hydroxide compounds
Total Organic Carbon (TOC) - Finished (ppm) 3/31/2022	N/A	N/A	4.89	1.38 to 4.89	Naturally present in the environment
Total Organic Carbon (TOC) - Source (ppm) 3/31/2022	N/A	N/A	11.5	6.10 to 11.5	Naturally present in the environment

DISINFECTION BYPRODUCTS

Bromate - Finished (ppb) 1/31/2022	10	0	3	ND to 4.6	By-product of drinking water disinfection
Haloacetic Acids (HAA5) (ppb) 6/30/2022	60	N/A	13	ND to 14.13	By-product of drinking water disinfection
Total Trihalomethanes (TTHMs) (ppb) 9/30/2022	80	N/A	16	ND to 28.75	By-product of drinking water disinfection

Our Water Supply and Drought Management

The primary water source for the City of Fargo Water Plant is the Red River. A water intake and pump station is located just east of our facility in proximity to the Midtown Dam. The City has alternate sources of water which include the Sheyenne River and water storage at Lake Ashtabula. The Sheyenne intake and pumping station is used approximately 30 % of the time and is located between the communities of West Fargo and Horace. Each pumping facility can be used independently or combined to provide source water flow into each of our treatment facilities. We focus on utilizing these sources wisely to minimize operating and treatment costs while optimizing water quality for our customers.

The City of Fargo owns 52% of the stored water rights to Lake Ashtabula. This allocation was a result of the City of Fargo helping to fund the construction of the Baldhill Dam north of Valley City. During a drought, with Corps of Engineers approval, water from Lake Ashtabula can be released into the Sheyenne River to help meet Fargo’s water needs. This lake (used in 1976, ’84, and ’88), along with water restrictions, and conservation, can help provide Fargo’s emergency water needs for approximately two years.

The City of Fargo has a drought management plan that monitors water flow, river levels and the precipitation index. The City has adopted an ordinance that mandates citizen participation during drought to reduce the impact to all water users. For more information about the drought management plan visit:

<https://fargond.gov/city-government/departments/water-treatment/drought-plan>

Source Water Protection

The City of Fargo public water system, in cooperation with the North Dakota Department of Environmental Quality, has completed the delineation and contaminant/land use inventory elements of the North Dakota Source Water Protection Program. Based on the information from these elements, the North Dakota Department of Environmental Quality has determined our source water is moderately susceptible to potential contaminants.

You can learn more about the North Dakota Source Water Protection Program online at:

https://deq.nd.gov/WQ/1_Groundwater/1_SW.aspx