

INSPECTION CHECKLIST

Fireworks (Outdoor Public Display)

Y N N/A Y = Meets Requirements; N= Does Not Meet Requirements; N/A = Not Applicable

GENERAL:

- ☐ ☐ ☐ A permit is required for public displays (IFC 105.5.44)
- ☐ ☐ ☐ Proof of Insurance required \$100,000 min. (IFC 5601.2.4)
- ☐ ☐ ☐ Plan establishing procedures for a malfunction (IFC 5608.2)
- ☐ ☐ ☐ Diagram/site plan required showing location of buildings, highways, overhead obstructions, and audience/crowd distances (IFC 5608.2.1)
- ☐ ☐ ☐ Public assemblage plan can be required – including standby firefighters (IFC 403)

FIREWORKS STORAGE AT DISPLAY SITE:

- ☐ ☐ ☐ Fireworks shall not be unattended (IFC 5608.5.1)
- ☐ ☐ ☐ Fireworks shall be kept dry (IFC 5608.5.2)
- ☐ ☐ ☐ Shells to be inspected. Damaged, leaking, wet, or torn shells shall not be used (IFC 5608.5.3)
- ☐ ☐ ☐ Aerial shells to be checked for proper fit into mortars (IFC 5608.5.3)
- ☐ ☐ ☐ Ready boxes to be used for storage of fireworks and located at least 25 feet from mortars (IFC 5608.5.5)
- ☐ ☐ ☐ Smoking and open flames are prohibited within 50 ft. of any area where fireworks or pyrotechnic materials are present. (NFPA 1123 8.1.6.1)
- ☐ ☐ ☐ NO SMOKING OR OPEN FLAME signs must be conspicuously posted in the area (IFC 310.3)

FIREWORKS DISPLAY SITE:

- ☐ ☐ ☐ Minimum required radius of display site shall be 70 ft. per inch of internal mortar diameter of the largest aerial shell to be fired [Ex. A 6" mortar = 420'] (NFPA 1123 5.1.3)
- ☐ ☐ ☐ Discharge site arranged so that the trajectory of aerial shells shall not be within 25 feet of overhead objects or obstructions. (NFPA 1123 5.1.4.7)
- ☐ ☐ ☐ The AHJ (fire official) can order that a display be stopped if weather conditions or poor crowd control become a concern (NFPA 1123 8.1.4.1 and 8.1.4.2)
- ☐ ☐ ☐ Aerial shells greater than 6 inches in diameter shall be preloaded into mortars prior to the beginning of the display (NFPA 1123 8.2.9.1)
- ☐ ☐ ☐ Aerial shells greater than 6 inches in diameter shall be fired using electrical ignition or other means of remote ignition with some exceptions (NFPA 1123 8.2.9.2.1 and 8.2.9.2.2)
- ☐ ☐ ☐ Only the operator, authorized assistants, and inspectors representing the AHJ are permitted to be in the display site while the display is in progress (NFPA 1123 8.1.3.2)
- ☐ ☐ ☐ Operators and assistants shall only use flashlights, electrical lighting, or other nonincendive illumination such as chemical luminescent devices for illuminating the firing and ready box area (NFPA 1123 8.1.5)
- ☐ ☐ ☐ The radius for ground pieces of low hazard potential shall be at least 75 feet (NFPA 1123 5.1.3.5.1)
- ☐ ☐ ☐ The radius for ground pieces of high hazard potential shall be at least 125 feet (NFPA 1123 5.1.3.5.2)
- ☐ ☐ ☐ Post display inspection and accounting for unexploded devices is required (IFC 5608.9)