

ADDENDUM NO. 2

FEBRUARY 16, 2023

TO

PROJECT MANUAL

FOR

**FARGO SHEYENNE PUMP STATION – SUPPLEMENTAL PUMP
RFP23040**

FOR

CITY OF FARGO

NORTH DAKOTA

JANUARY 2023

The following changes, additions, and deletions are hereby made a part of the Bidding Documents for the Fargo Sheyenne Pump Station – Supplemental Pump project as fully and completely as if the same were set forth therein. Acknowledge receipt of this addendum in the space provided on the Bid Form and also on the outside of the Bid envelope. Failure to do so may result in rejection of bid.

This addendum consists of one (1) page.

DRAWING

Plan Sheet P / P101 – PROPOSED PLAN

1. Plan Sheet P / P101 – PROPOSED PLAN: Delete Construction Note No. 2 (weld on flange) and replace with the following Construction Note No. 2.



Remove existing 12"x20" reducing 90° bend and install new flanged DI 12"x20" reducing 90° bend with 6" flanged side outlet.

Plan Sheet P / P102 – PROPOSED SECTION

1. Plan Sheet P / P102 – PROPOSED SECTION: Delete Construction Note No. 1 (weld on flange) and replace with the following Construction Note No. 1.



Remove existing 12"x20" reducing 90° bend and install new flanged DI 12"x20" reducing 90° bend with 6" flanged side outlet.

END OF ADDENDUM NO. 2