

Fargo 214 Broadway Fargo, ND 58102 p 701.364.0237

REQUEST FOR PROPOSALS (RFP23090) FOR

Fargo Public Library Sunshades Replacement Project

RFP due date: 2:00pm, Thursday June 8th 2023

Deliver one (1) original RFP and four (4) flash drives containing identical original RFP's to the following address:

City of Fargo Auditor's office 225 4th Street N Fargo, ND 58102

All RFP submittals must be placed in an envelope securely sealed therein and labeled: "City of Fargo RFP: Sunshades Replacement – Downtown Fargo Library"

Office hours are 7:45 am to 4:30 pm, Monday through Friday, excluding holidays

SECTION 00 0105 - CERTIFICATIONS PAGE

FARGO PUBLIC LIBRARY SUNSHADES REPLACEMENT PROJECT

FARGO, NORTH DAKOTA

Architect

I hereby certify that this Plan, Specification, or Report was prepared by me or under my direct supervision, and that I am a duly Registered Architect under the laws of the State of North Dakota.

Robert J. Remark, AIA Reg. No. 2696

April 28, 2023

Electrical Engineer

I hereby certify that this Plan, Specification, or Report was prepared by me or under my direct supervision, and that I am a duly Registered Professional Engineer under the laws of the State of North Dakota.

Michael A. Berger, PE Reg. No. PE-4438 April 28, 2023

SECTION 00 0110 - TABLE OF CONTENTS

PROCUREMENT AND CONTRACTING REQUIREMENTS

Division 00 -- Procurement and Contracting Requirements

- 00 0101 Project Title Page
- 00 0105 Certifications Page
- 00 0110 Table of Contents
- 00 0115 List of Drawing Sheets
- 00 0116 Project Overview
- 00 0117 Request for Proposal
- 00 0118 Proposal Response and Requirements
- 00 0119 Proposal Form
- 00 0120 Evaluation

Attachment A - Contractor Reference and Release Form

00 2113 - Proposal Instructions

00 2600 - Procurement Substitution Procedure

- 00 5000 Contracting Forms and Supplements
- 00 7300 Supplementary Conditions

SPECIFICATIONS

Division 01 -- General Requirements

- 01 2000 Price and Payment Procedures
- 01 2300 Alternates
- 01 2500 Substitution Procedures
- 01 3000 Administrative Requirements
- 01 3216 Construction Progress Schedule
- 01 4000 Quality Requirements
- 01 5000 Temporary Facilities and Controls
- 01 6000 Product Requirements
- 01 6116 Volatile Organic Compound (VOC) Content Restrictions
- 01 7000 Execution and Closeout Requirements
- 01 7419 Construction Waste Management and Disposal
- 01 7800 Closeout Submittals

Division 02 -- Existing Conditions

- 02 4100 Demolition
- Division 06 -- Wood, Plastics, and Composites

06 1000 - Rough Carpentry

Division 07 -- Thermal and Moisture Protection

07 9200 - Joint Sealants

Division 09 -- Finishes

- 09 2116 Gypsum Board Assemblies
- 09 5100 Acoustical Ceilings
- 09 9123 Interior Painting
- **Division 12 -- Furnishings**

12 2400 - Window Shades

Division 26 -- Electrical

26 0500 - Common Work Results for Electrical

26 0501 - Minor Electrical Demolition

26 0519 - Low-Voltage Wiring

26 0526 - Grounding and Bonding

26 0529 - Hangers and Supports for Electrical Systems

26 0533.13 - Conduit

26 0533.16 - Boxes for Electrical Systems

26 0553 - Identification for Electrical Systems

Division 27 -- Communications

27 1005 - Telecommunications Cabling

SECTION 00 0115 - LIST OF DRAWING SHEETS

G100 - COVER SHEET

G101 - TITLE SHEET

ARCHITECTURAL

- A201 FIRST FLOOR PLAN
- A202 SECOND FLOOR PLAN
- ELECTRICAL
 - **E100 FIRST FLOOR ELECTRICAL DEMO**
 - E101 SECOND FLOOR ELECTRICAL DEMO
 - E200 FIRST FLOOR ELECTRICAL PLAN
 - E201 SECOND FLOOR ELECTRICAL PLAN

See construction drawings attachment on the City of Fargo RFP page

PROJECT OVERVIEW

The City of Fargo is requesting proposals for removing and replacing electric sunshades at the Fargo Main library. This project also includes replacement of existing motors, controls, wiring, and switches to achieve local and central, secure and predictable operation. Window sunshade locations:

- 1. Tech Services 131
 - A. Current Openness Factor
 - B. Local Control
- 2. Director's Office 126
 - A. Current Openness Factor
 - B. Local Control
- 3. Deputy Director's Office 125
 - A. Current Openness Factor
 - B. Local Control
- 4. Primary Office Associate 124
 - A. Current Openness Factor
 - B. Local Control
- 5. Staff Lounge 122
 - A. Current Openness Factor
 - B. Local Control
- 6. Children's Library 110
 - A. Current Openness Factor
 - B. Wiggle Room (North) on Separate Local Control
 - C. South and East Sunshades on Centralized Control per Orientation
 - i. North side of alcove to be included in East Control
 - ii. Controls located in Data 167
- 7. Community Room 152
 - A. Current Openness Factor (blackout)
 - B. Local Control
- 8. Second Floor Staff Work Area 206, 213, 215 & 216
 - A. North facing sunshades added to match West Openness Factor with Local Control
 - B. West facing sunshades to match Current Openness Factor with Separate Local Control for each Window (including Tech Librarian's Office)
- 9. Second Floor Open Public Area 201 & 205
 - A. Current Openness Factor
 - B. West, South, and East Sunshades on Centralized Control per Orientation
 - i. North side of alcove to be included in East Control
 - ii. Controls located in Second Floor Staff Work Area East wall (adjacent to public elevator) on South Side of Door to Open Public Area
- 10. Second Floor Computer Lab 225
 - A. Openness Factor to match West Sunshades
 - B. Local Control with Key Activation

SCOPE OF SERVICES

- 1. Remove existing sunshades, rollers, and hardware according to locations on construction documents
- 2. Remove gypsum board at head of window as necessary to gain access to controls, motors, and wiring
- 3. Gypsum board repair/patch/texture/paint to match existing finish
- 4. Install controls, motors, and wiring according to construction documents

- 5. Install new sunshades, trims, and accessories
- 6. Install new switches
- 7. Test system per zone
- 8. Punch list walkthrough
- 9. Completion walkthrough
- 10. Turn over project manual and required documents/items
- 11. Warranty walkthrough

CONDITIONS OF WORK

Each Proposal Submitter must inform themselves fully of the conditions relating to the construction of the project. Failure to do so will not relieve a successful Proposal Submitter of their obligation to furnish all materials and labor necessary to carry out their work and must employ such methods and/or means as will not cause any interruption of, or interference with the work of any other contractor. The General Contractor shall include the cost of the building permit in their proposal.

CONTRACT DESCRIPTION

Contract Type: A single prime contract based on a Stipulated Price.

OWNER OCCUPANCY

- A. Owner intends to continue to occupy adjacent portions of the existing building during the entire construction period.
- B. Cooperate with Owner (City of Fargo Facilities and Fargo Public Library Director) to minimize conflict and to facilitate Owner's operations.
- C. Schedule the Work to accommodate Owner occupancy.
- D. Owner will remove the following items before start of work in each zone:
 - 1. Office furniture adjacent to windows.

CONTRACTOR USE OF SITE AND PREMISES

Existing building spaces may not be used for storage.

Contractor(s) is required to remove all tools and equipment and clean work area prior to leaving the site on a daily basis.

Time Restrictions:

- 1. Accessibility to Contractors: 7:30 am until 8:00 pm Monday thru Friday; arrangements to be made in advance for work after 8:00 pm.
- 2. Limit conduct of especially noisy work to the hours of:
 - a. 7:30 am until 9:00 am Monday thru Thursday.
 - b. 7:30 am until 11:00 am on Fridays.
 - c. After 8:00 pm Monday thru Friday.

Utility Outages and Shutdown:

- 1. Limit disruption of utility services to hours the building is unoccupied.
- 2. Do not disrupt or shut down life safety systems, including but not limited to fire sprinklers and fire alarm system, without 7 days notice to Owner and authorities having jurisdiction.
- 3. Prevent accidental disruption of utility services to other facilities.
- 4. Public restrooms within the library are available for Contractor use.

SCHEDULE OF ALTERNATES

Alternate No. 1: Abandon Existing Wiring.

 State the amount to be DEDUCTED from the Base Proposal to provide all materials, labor & equipment required for abandoning existing wiring, (base proposal to remove existing sunshade electrical wiring), as indicated in the drawings and specifications.

SUBSTITUTION GENERAL REQUIREMENTS

- A. A Substitution Request for products, assemblies, materials, and equipment constitutes a representation that the submitter:
 - 1. Has investigated proposed product and determined that it meets or exceeds the quality level of the specified product, equipment, assembly, or system.
 - 2. Agrees to provide the same warranty for the substitution as for the specified product.
 - 3. Agrees to provide same or equivalent maintenance service and source of replacement parts, as applicable.
 - 4. Agrees to coordinate installation and make changes to other work that may be required for the work to be complete, with no additional cost to Owner.
 - 5. Waives claims for additional costs or time extension that may subsequently become apparent.
 - 6. Agrees to reimburse Owner and Architect for review or redesign services associated with re- approval by authorities.
- B. Document each request with complete data substantiating compliance of proposed substitution with Contract Documents. Burden of proof is on proposer.
- C. Content: Include information necessary for tracking the status of each Substitution Request, and information necessary to provide an actionable response.
 - 1. Forms included in the Project Manual are adequate for this purpose, and must be used.
- D. Limit each request to a single proposed substitution item.
 - 1. Submit an electronic document, combining the request form with supporting data into single document.

ANTICIPATED PROJECT TIMELINE

Issuance of RFP	5/17/2023, 5/24/2023 and 5/31/2023
Pre-Proposal Meeting	5/24/23 @ 9am - Fargo Library; 101 4th St N, Fargo
Deadline for submitting RFP questions	5/30/2023
Questions posted as addendum	6/1/2023 @ 5pm
Request for Proposal Due by	6/8/2023 @ 2pm
Proposal Review and Evaluation	June 2023
Selection approved by Commission	June 2023
Certification of Consultants' Contract	July 2023

CONSTRUCTION PROGRESS SCHEDULE

- A. Prepare preliminary schedule.
- B. Show complete sequence of construction by activity, with dates for beginning and completion of each element of construction.
- C. Maintain schedules to record actual start and finish dates of completed activities.
- D. Distribute copies of updated schedules to Contractor's project site file, to subcontractors, suppliers, Architect, Owner, and other concerned parties.

TEMPORARY FACILITIES AND CONTROLS

- A. Arrange with the Owner and Architect for a time if electrical service needs to be interrupted, to make connections.
- B. Provide barriers to prevent unauthorized entry to construction areas, to prevent access to areas that could be hazardous to workers or the public, to allow for owner's use of site and to protect existing facilities and adjacent properties from damage from construction operations and demolition.
- C. Coordinate temporary parking areas to accommodate construction personnel with Owner.

WASTE REMOVAL

A. Provide waste removal facilities and services as required to maintain the site in clean and orderly condition. Remove trash from the site daily, or more frequent.

REMOVAL OF UTILITIES, FACILITIES, AND CONTROLS

- A. Clean and repair damage caused by installation or use of temporary work.
- B. Restore existing facilities to original condition.

PROGRESS CLEANING

A. Maintain areas free of waste materials, debris, and rubbish. Maintain site in a clean and orderly condition.

PROTECTION OF EXISTING FACILITY

- A. Protect existing areas from damage by construction operations.
- B. Provide special protection where specified in individual specification sections.
- C. Provide temporary and removable protection from existing areas. Control activity in immediate work area to prevent damage.
- D. Provide protective coverings at walls, jambs, sills, soffits, ceilings and furnishings.
- E. Protect finished floors, and other surfaces from dust, debris and movement of heavy objects.
- F. Remove protective coverings when no longer needed

DEMONSTRATION AND INSTRUCTION

- A. Provide a qualified person who is knowledgeable about the Project to perform demonstration and instruction of Owner's personnel.
- B. Utilize operation and maintenance manuals as basis for instruction. Review contents of manual with Owner's personnel in detail to explain all aspects of operation and maintenance.
- C. Prepare and insert additional data in operations and maintenance manuals when need for additional data becomes apparent during instruction.
- D. Adjust operating products and equipment to ensure smooth and unhindered operation.

FINAL CLEANING

- A. Use cleaning materials that are nonhazardous.
- B. Clean interior glass, surfaces exposed to view; remove temporary labels, stains and foreign substances, polish transparent and glossy surfaces, vacuum carpeted and soft surfaces.
- C. Remove waste, surplus materials, trash/rubbish, and construction facilities from the site; dispose of in legal manner

Project Overview is a summary of the Sunshades Replacement project. Refer to Procurement and Contracting Requirements and Specifications for full project parameters and requirements.

CITY OF FARGO REQUEST FOR PROPOSAL FARGO PUBLIC LIBRARY SUNSHADES REPLACEMENT PROJECT

The City of Fargo is requesting proposals for Sunshade Window Covering Replacement and Installation for its Public Library in Downtown Fargo. Sealed proposals will be received by the City of Fargo Auditor's office at 225 4th Street North, Fargo, ND 58102, for the purpose of evaluating costs and operating parameters.

Proposals will be received until 2:00 P.M. Central Standard Time on Thursday, June 8th, 2023.

JLG Architects is the project architect and administrator for this project. The Proposal Instructions, Proposal Form, Form of Contract, Drawings, Specifications, addenda, and other contract documents as prepared by JLG Architects may be examined at the following places: The office of JLG Architects, Fargo, North Dakota; the Builders Exchanges in Fargo-Moorhead, Grand Forks, Bismarck-Mandan, Bismarck, Minot, and Dickinson, North Dakota; Minneapolis/St. Paul, St. Cloud, Mankato, Rochester, Hibbing, Marshall, Willmar, and Duluth, Minnesota; Aberdeen, Rapid City, and Sioux Falls, South Dakota; Billings, Montana; Construction Connect and McGraw Hill/FWDodge

Late proposals cannot be accepted and will be returned unopened to the Proposal submitter.

Each proposal must be accompanied by a separate envelope containing the contractor's license.

The City reserves the right to reject any or all proposals or accept what is, in its judgment, the proposal(s) which is/are in the City's best interest. The City further reserves the right, in the best interests of the City, to waive any technical defects or irregularities in any/all proposals.

Discussions may be conducted with responsible Proposers whose submittals have an opportunity to be reasonably acceptable of being selected for award for purpose of classification to assure full understanding of, and responsiveness to, the solicitation requirements.

A proposal meeting and walkthrough will be held at the Fargo Public Main Library, 101 4th St N, Fargo, on Wednesday, May 24th 2023 at 9:00 am central time. Any questions can be submitted to Deb Wendel Daub, Dwendeldaub@jlgarchitects.com until Tuesday, May 30th 2023 at 5:00pm. Questions will be posted as an addendum to the City of Fargo RFP website on Thursday, June 1st.

PROPOSAL RESPONSE AND REQUIREMENTS

The proposal shall include the following information:

- A. **PROPOSER'S INFORMATION** The full name, business address, and business telephone number of the partnership, joint venture, or corporation submitting the proposal shall be provided.
- B. **QUALIFICATIONS OF KEY PERSONNEL** Identify the Project Manager, the key person responsible for the quality, and the person who will be the principal contact. List the project team members to be utilized on this project. Briefly describe the responsibilities of each person on the project team. Include the names, titles, office location, qualifications, and experiences of each member of the project team.
- C. EXPERIENCE OF COMPANY Number of years company has been involved in similar projects
- D. **METHODOLOGY** Describe the methodology you plan to use to ensure timely review, coordination, and implementation of the required services.
- E. **BACKGROUND AND UNDERSTANDING OF THE SCOPE OF SERVICES** Briefly describe your understanding of the proposed scope of work, your background and qualification to perform the proposed scope of work, and the objectives to be accomplished for this project.
- F. **PROJECT REFERENCES** In the form below, list at least three (3) reference for Sunshade Window Covering Replacement and Installation.
- G. **SCHEDULE OF FEES** Provide a schedule of fees, including staff and equipment hourly rates that will be used to complete the required scope of work. The Fee Schedule shall be based on the total project cost amount with a cost breakdown for various tasks as described in the Scope of Work.

SECTION 00 0119 - PROPOSAL FORM

To: Fargo Public Library Sunshades Replacement Project Fargo, North Dakota

Date:

Having examined all proposal requirements, general conditions, Specifications and Drawings entitled Sunshades Replacement Project; dated: April 28, 2023, and addenda similarly entitled and numbered ______, _____, ______, as prepared by JLG Architects and MBN Engineering, and having visited the site and examined all conditions affecting the work, the undersigned agrees to furnish and pay for all labor, materials, and equipment for the following Construction Contract as required by the afore mentioned documents for the following proposals:

Proposal for (Single Prime):

GENERAL & ELECTRICAL CONSTRUCTION

__Dollars, (\$_____)

The undersigned agrees to perform <u>Alternates</u> (if required by Contract Documents) as described in the Contract Documents for the following cost as a change to the Base Bid Stipulated Sum stated above.

Alternate Number	Description	Amount .	
1	Abandon Existing Wiring	DEDUCT:	
	State the amount to be DEDUCT wiring, (base proposal to remove the drawings and specifications.	e amount to be DEDUCTED to the Base Proposal for abandoning existing (base proposal to remove existing sunshade electrical wiring), as indicated in wings and specifications.	

PROPOSAL SUBMITTER has familiarized themselves with the nature and extent of the Contract Documents including Work, site, locality, and all local conditions, and Laws & Regulations that in any manner may affect cost, progress, performance, or furnishing of the Work.

PROPOSAL SUBMITTER has given the Architect and its consultants written notice of all conflicts, errors, or discrepancies that it has discovered in the Contract Documents and the written resolution by the Architect is acceptable to PROPOSAL SUBMITTER.

The low proposal submitter agrees to submit a list of sub-contractors (AIA G705) within 24 hours of the date of the proposal.

In submitting this proposal, the undersigned agree that this proposal shall not be withdrawn for a period of fourteen days.

Note: This Proposal Form shall be submitted in DUPLICATE.

SIGNED:

 Firm Name	, a (Sole Proprietorship) (Partnership) (Corporation). (strike through two)
Street Address	
City, State ZIP code	
Phone:Fax:	
Signed By,	, Title
Signed By,	
Signed By,	
Witnessed By,	, Title

- 1) Sole Proprietorship: Signature of Sole Proprietor in the presence of a witness who will also sign. Insert the words "Sole Proprietor" under the signature. Affix seal.
- 2) Partnership: Signature of all partners in the presence of a witness who will also sign. Insert the word "Partner" under each signature. Affix seal to each signature.
- 3) Corporation: Signature of a duly authorized signing officer(s) in their normal signatures. Insert the officer's capacity in which the signing officer acts, under each signature. Affix the corporate seal. If the proposal is signed by officials other than the president and the secretary of the company, or the president/secretary/treasurer of the company, a copy of the by-law resolution of their board of director's authorizing them to do so, must be submitted with the Proposal Form in the proposal envelope.

EVALUATION

All Proposals received on time will be opened, in a non-public setting. Proposals will first be reviewed to ensure compliance with the terms of this RFP. Non-compliant or non-responsive Proposals may be rejected. The City will then evaluate the Proposals in accordance with the criteria listed below.

QUALIFICATION AND EXPERIENCE – 25 Points

- The Consultants demonstrated a record of success and familiarity with projects of similar scope, complexity, and magnitude.
- The experience and expertise of the Consultant's key personnel.
- Quality/experience of the project team.

METHODOLOGY – 25 Points

- Use of logical, proven methodology for analyzing the information, carrying out the tasks described in the proposal, and developing the project/service deliverables.
- Incorporate innovative and unique solutions into the project.

UNDERSTANDING OF PROJECT SCOPE – 25 Points

• Displays thorough knowledge of the project scope in their approach to completing the data collection.

QUALITY OF SUBMITTAL – 15 Points

- Clarity and simplicity.
- Responsiveness to the requirements of the RFP.
- Organization, format, and understandability of the proposal.

REFERENCES – 10 Points

• Consultant's References and List of the Projects of the same nature.

In addition to the written proposal, the City may choose to conduct oral interviews. The City will establish a specific date to conduct interviews and no other dates will be provided.

In its evaluation, the City may investigate the qualifications of a Proposer under consideration, require confirmation of information furnished by the Proposer, and require the Proposer to provide additional information or evidence of qualifications for the Services described in this RFP.

ATTACHMENT A CONTRACTOR REFERENCE AND RELEASE FORM

List below at least three (3) reference for a Sunshade Window Covering Replacement and Installation. Additional references may be requested by the City. Attachment shall include company name, contact name, address, email address, telephone numbers and contract period who can verify your experience and ability to perform the type of service listed in the solicitation.

Company Name	Contract Period
Contact Person Name and Title	Telephone Number (include area code)
Complete Primary Address	City State Zip Code
Email Address	Fax Number (include area code)
Project Name	

Company Name	Contract Peri	Contract Period	
Contact Person Name and Title	Telephone N	Telephone Number (include area code)	
Complete Primary Address	City	State	Zip Code
Email Address	Fax Number	(include area	code)
Project Name			

Company Name	Contract Peri	Contract Period		
Contact Person Name and Title	Telephone N	Telephone Number (include area code)		
Complete Primary Address	City	State	Zip Code	
Email Address	Fax Number	(include area	code)	
Project Name				

REFERENCE CHECK RELEASE STATEMENT

Authorizing the City to contact the references provided above for purposes of this RFP.

Signed: ______ Title _____ (Authorized Signature of Proposer)

Company Name _____ Date _____

SECTION 00 2113 - PROPOSAL INSTRUCTIONS

PART 1 GENERAL

1.01 DEFINITIONS

- A. Proposal Documents include the Proposal Requirements and the Contract Documents. The Proposal Requirements consist of the Advertisement or Request for Proposal, Proposal Instructions, Proposal Form, and other sample proposal and contract forms. The Contract Documents consist of the form of Agreement between the Owner and Contractor, Conditions of the Contract (General, Supplementary, and other Conditions), Drawings, Specifications, and all addenda issued prior to execution of the Contract.
- B. Definitions set forth in the General Conditions of the Contract for Construction, AIA Document A201, or in other Contract Documents are applicable to the Proposal Documents.
- C. Addenda are written or graphic instruments issued by the Architect prior to the execution of the Contract which modify or interpret the Proposal Documents by additions, deletions, clarifications, or corrections.
- D. A Proposal is a complete and properly executed proposal to do the Work for the sums stipulated therein, submitted in accordance with the Proposal Documents.
- E. The Base Proposal is the sum for which the Proposal Submitter offers to perform the Work described in the Proposal Documents as the base, to which Work may be added or from which Work may be deleted for sums stated in Alternate Proposals.
- F. An Alternate Proposal (or Alternate) is an amount stated in the Proposal to be added to or deducted from the amount of the Base Proposal if the corresponding change in the Work, as described in the Proposal Documents, is accepted.
- G. A Proposal Submitter is a person or entity who submits a Proposal and who meets the requirements set forth in the Proposal Documents.
- H. A Sub-proposal Submitter is a person or entity who submits a proposal to a Proposal Submitter for materials, equipment, or labor for a portion of the Work.

1.02 PROPOSAL SUBMITTER'S REPRESENTATIONS

- A. The Proposal Submitter by making a Proposal represents that:
 - 1. The Proposal Submitter has read and understands the Proposal Documents or Contract Documents, to the extent that such documentation relates to the Work for which the Proposal is submitted, and for other portions of the Project, if any, being proposed concurrently or presently under construction.
 - 2. The Proposal is made in compliance with the Proposal Documents.
 - 3. The Proposal Submitter has visited the site, become familiar with local conditions under which the Work is to be performed and has correlated the Proposal Submitter personal observations with the requirements of the proposed Contract Documents.
 - 4. The Proposal is based upon the materials, equipment, and systems required by the Proposal Documents without exception.

1.03 PROPOSAL DOCUMENTS

A. Copies:

- 1. Proposal Submitters may obtain complete sets of the Proposal Documents from the issuing office designated in the Request for Proposal in the number and for the deposit sum, if any, stated therein. The deposit will be refunded to Proposal Submitters who submit a bona fide Proposal and return the Proposal Documents in good condition within fifteen days after receipt of Proposal. The cost of replacement of missing or damaged documents will be deducted from the deposit. A Proposal Submitter receiving a Contract award may retain the Proposal Documents and the Proposal Submitter's deposit will be refunded.
- 2. Proposal Documents may not be issued directly to Sub-proposal Submitter's unless specifically offered in the Advertisement or Request for Proposal, or in supplementary request for proposal.
- 3. Proposal Submitters shall use complete sets of Proposal Documents in preparing Proposals; neither the Owner nor Architect assumes responsibility for errors or misinterpretations resulting from the use of incomplete sets of Proposal Documents.
- 4. The Owner and Architect may make copies of the Proposal Documents available on the above terms for the purpose of obtaining Proposals on the Work. No license or grant of use is conferred by issuance of copies of the Proposal Documents.

1.04 INTERPRETATION OR CORRECTION OF PROPOSAL DOCUMENTS

- A. The Proposal Submitter shall carefully study and compare the Proposal Documents with each other, and with other work being proposed concurrently or presently under construction to the extent that it relates to the Work for which the Proposal is submitted, shall examine the site and local conditions, and shall at once report to the Architect errors, inconsistencies, or ambiguities discovered.
- B. Proposal Submitters and Sub-proposal Submitters requiring clarification or interpretation of the Proposal Documents shall make a written request which shall reach the Architect at least seven days prior to the date for receipt of Proposals.
- C. Interpretations, corrections, and changes to the Proposal Documents shall be made by Addendum. Interpretations, corrections, and changes to the Proposal Documents made in any other manner will not be binding, and Proposal Submitters shall not rely upon them.

1.05 SUBSTITUTIONS

- A. The materials, products, and equipment described in the Proposal Documents establish a standard of required function, dimension, appearance, and quality to be met by any proposed substitution.
- B. No substitution will be considered prior to receipt of Proposals unless written request for approval has been received by the Architect at least seven days prior to the date for receipt of Proposals. Such requests shall include the name of the material or equipment for which it is to be substituted and a complete description of the proposed substitution including drawings, performance and test data, and other information necessary for an evaluation. A statement setting forth changes in other materials, equipment or other portions of the Work, including changes in the work of other contracts that incorporation of the proposed substitution would require, shall be included. The burden of proof of the merit of the proposed substitution is upon the proposer. The Architect's decision of approval or disapproval of a proposed substitution shall be final.
- C. If the Architect approves a proposed substitution prior to receipt of Proposals, such approval will be set forth in an Addendum. Proposal Submitters shall not rely upon approvals made in any other manner.
- D. No substitutions will be considered after the Contract award unless specifically provided for in the Contract Documents.

1.06 ADDENDA

- A. Addenda will be transmitted to all who are known by the issuing office to have received a complete set of Proposal Documents.
- B. Copies of Addenda will be made available for inspection wherever Proposal Documents are on file for that purpose.
- C. Addenda will be issued no later than three days prior to the date for receipt of Bids except an Addendum withdrawing the request for Proposals or one which includes postponement of the date for receipt of proposals.
- D. Each Proposal Submitter shall ascertain prior to submitting a Proposal that the Proposal Submitter has received all Addenda issued, and the Proposal Submitter shall acknowledge their receipt in the Proposals.

1.07 PREPARATION OF PROPOSALS

- A. Proposals shall be submitted on the forms included with the Proposal Documents.
- B. All blanks on the proposal form shall be legibly executed in a non-erasable medium.
- C. Sums shall be expressed in both words and figures. In case of discrepancy, the amount written in words shall govern.
- D. Interlineations, alterations, and erasures must be initialed by the signer of the Proposal.
- E. It is requested that a change in cost be submitted for all Alternates. Failure to submit a cost change for an alternate may result in the Owner not being able to put together the project desired and cause the proposal to not be considered. If no change in the Base Proposal is required, enter "No Change."
- F. Where two or more Proposals for designated portions of the Work have been requested, the Proposal Submitter may, without forfeiture of the proposal security, state the Proposal Submitter's refusal to accept award of less than the combination of Proposals stipulated by the Proposal Submitter. The Proposal Submitter shall make no additional stipulations on the proposal form nor qualify the Proposal in any other manor.
- G. Each copy of the Proposal shall state the legal name of the Proposal Submitter and the nature of legal form of the Proposal Submitter. The Proposal Submitter shall provide evidence of legal authority to perform within the jurisdiction of the contract. A Proposal by a corporation shall further give the state of incorporation and have the corporate seal affixed. A Proposal submitted by an agent shall have a current power of attorney attached certifying the agents authority to bind the Proposal Submitter.

1.08 RECEIPT AND OPENING OF PROPOSALS

- A. Proposals shall be received by the Owner as defined in the Advertisement or Request for Proposal -Section 00 1113.
- B. Proposals shall be deposited at the designated location prior to the time and date for receipt of Proposals. Proposals received after the time and date for receipt of Proposals will be returned unopened.
- C. The Proposal Submitter shall assume full responsibility for timely delivery at the location designated for receipt of Proposals.
- D. Any proposal may be withdrawn prior to the above scheduled time for the opening of proposals or authorized postponement thereof. Any proposal received after the time and date specified shall not be considered. No proposal submitter may withdraw a proposal within 30 days after the actual date of opening thereof.

E. The Owner will have the right to retain the proposal security of Propsal Submitters to whom an award is being considered until either (a) the Contract has been executed and bonds, if required, have been furnished, or (b) the specified time has elapsed so that Proposals may be withdrawn or (c) all Proposals have been rejected.

1.09 SUBCONTRACTS

- A. The proposal submitter is specifically advised that any person, firm, or other party to whom it is proposed to award a subcontract under this contract must be acceptable to the Owner. Cause for rejection include, but are not limited to the following:
 - 1. Unacceptable workmanship on past projects.
 - 2. Lack of cooperation and/or inability to meet construction schedules on past projects.
 - 3. Inadequate personnel to meet construction schedule.
- B. The lowest proposal submitter must submit to the Architect a complete list of all suppliers and subcontractors within seven days after the date of the proposal. Inability to provide a list of acceptable subcontractors shall be just cause for rejection of the proposal.

1.10 MODIFICATION OF PROPOSALS

- A. A Proposal may not be modified, withdrawn, or canceled by the Proposal Submitter during the stipulated time period following the time and date designated for the receipt of Proposals, and each Proposal Submitter so agrees in submitting a Proposal.
- B. Prior to the time and date designated for receipt of Proposals, a Proposal submitted may be modified or withdrawn by notice to the party receiving Proposals at the place designated for receipt of Proposals. Such notice shall be in writing over the signature of the Proposal Submitter. Written confirmation over the signature of the Proposal Submitter shall be received, and date- and time-stamped by the receiving party on or before the date and time set for receipt of Proposals. A change shall be so worked as not to reveal the amount of the original Proposal.
- C. Withdrawn Proposals may be resubmitted to the date and time designated for the receipt provided that they are then fully in conformance with these Instructions to Proposal Submitter.

1.11 CONSIDERATION OF PROPOSALS

- A. Opening of Proposals: The properly identified Proposals received on time will be privately opened. An abstract of the Proposals may be made available to Proposal Submitters.
- B. Rejection of Proposals: The Owner shall have the right to reject any or all Proposals. A Proposal not accompanied by a required proposal security or by other data required by the Proposal Documents, or a Proposal which is in any way incomplete or irregular is subject to rejection.
- C. Acceptance of Proposal (Award)
 - 1. It is the intent of the Owner to award a Contract to the lowest qualified Proposal Submitter provided the Proposal has been submitted in accordance with the requirements of the Proposal Documents and does not exceed the funds available. The Owner shall have the right to waive informalities and irregularities in a Proposal received and to accept the Proposal which, in the Owner's judgement, is in the Owner's own best interests.
 - 2. The Owner shall have the right to accept Alternates in any order or combination, unless otherwise specifically provided in the Proposal Documents, and to determine the low Proposal Submitter on the basis of the sum of the Base Proposal and Alternates accepted.

1.12 TIME OF COMPLETION

A. Proposal Submitter agrees to commence work on or before a date to be specified in a written Notice to Proceed by the Owner and to fully complete the Construction Work as outlined in the project documents and as based on project alternates taken.

1.13 CONDITIONS OF WORK

A. Each Proposal Submitter must inform themselves fully of the conditions relating to the construction of the project. Failure to do so will not relieve a successful proposal submitter of their obligation to furnish all materials and labor necessary to carry out their work and must employ such methods and/or means as will not cause any interruption of, or interference with the work of any other contractor.

1.14 PRE-PROPOSAL MEETING

A. A Pre-Proposal Meeting will be held at the project site on Wednesday, May 24, 2023, at 9:00 AM local time. Contractors shall meet at the Fargo Public Main Library, 101 4th St N, Fargo, After they meeting, attendees will be able to tour the site.

1.15 BUILDING PERMIT

A. The General Contractor shall include the cost of the building permit in their proposal.

1.16 BUILDER'S RISK INSURANCE

- A. The Owner will provide Builder's Risk Insurance.
- B. See AIA Document A201-2017 Subsection 11.5 for additional information and specification Section 00
 7300 Supplementary Conditions for modifications.

1.17 LAWS AND REGULATIONS

A. The proposal submitter's attention is directed to the fact that all applicable State laws, municipal ordinances, and the rules and regulations of all authorities having jurisdiction over construction of the project shall apply to the contract throughout and they will be deemed to be included in the contract the same as though herein written out in full.

1.18 OBLIGATION OF PROPOSAL SUBMITTER

A. At the time of the opening of the proposals, each proposal submitter will be presumed to have inspected the site and to have read and become thoroughly familiar with the plans and contract documents (including all addenda). The failure or omission of any proposal submitter to examine any form, instrument, or document shall in no way relieve any proposal submitter from any obligation in respect to their proposal.

1.19 STATE EXCISE AND USE TAX (SALES TAX)

A. In submitting the proposal, the proposal submitter is understood to have included in the proposal price the state tax on all sales of building materials, supplies, and equipment to contractors, subcontractors, or builders for the erection of buildings or their alteration, repair, or improvement.

1.20 STORING MATERIALS OFF-SITE

A. Contractor may store materials off-site and receive payment for said materials. If it is desired by the Contractor to order and store materials off-site, there shall be prior agreement to any arrangement by the Owner and Architect before ordering or Application for Payment. Evidence shall be furnished to the Owner and Architect that the materials have been ordered, delivered and paid for. A Certificate of Insurance for materials stored off-site shall accompany other required information at the time of the Application for Payment. The location of the stored materials shall be acceptable to the Owner.

1.21 OWNER REQUIREMENTS OF THE CONTRACTOR

A. For Contract language that will be incorporated into AIA Owner-Contractor Agreements, see Project Manual Section 00 5000.

PART 2 PRODUCTS (NOT USED)

PART 3 EXECUTION (NOT USED)

SECTION 00 2600 - PROCUREMENT SUBSTITUTION PROCEDURES

PART 1 GENERAL

1.01 SUMMARY

- A. Section Includes
 - 1. Requirements for submitting substitution requests for materials, products, equipment and methods of construction from those required by the Procurement Documents, during the procurement phase and prior to execution of the Owner/Contractor Agreement.

1.02 SUBSTITUTIONS (DURING THE PROCUREMENT/PROPOSAL PHASE)

- A. The technical specification sections may have several materials, products, equipment and methods of construction specified under the same heading. Selection of a specified materials, products, equipment and methods of construction shall be at the option of the Proposal. Where materials, products, equipment and methods of construction are specified accompanied with the phrase "Or Equal", "Approved Substitution", or similar verbiage, the Proposal Submitter may submit materials, products, equipment and methods of construction for approval in accordance with the requirements of this Document.
- B. No substitution will be considered prior to receipt of Proposals unless written request for approval has been received by the Architect (or Construction Manager as applicable) at least seven working days prior to the date for receipt of Proposals.
 - 1. Submit each request for substitution on the Architect's "Procurement Substitution Request Form" included at the end of this Section.
 - 2. Submit one materials, products, equipment and methods of construction per request form, either duplicated from the Project Manual or available from the Architect's office.
 - 3. Submittals not accompanied by this form properly filled in and endorsed, will be discarded without review. NO EXCEPTIONS.
 - 4. Where specified materials, products, and equipment are accompanied by a color, pattern or finish selection, requests for substitution shall include an actual sample of the proposed color, pattern or finish for review.
 - 5. Where multiple materials, products or equipment are specified within a single specification section, specifically identify which product you wish to substitute.
- C. The burden of proof of the merit of the proposed substitution is upon the proposer. The Architect's decision of approval or rejection of a proposed substitution shall be final.
- D. Materials, products, equipment and methods of construction approved by this substitution procedure will be issued in an Addendum.
- E. Refer to Section 01 2500 for requests for substitutions after execution of the Owner/Contractor Agreement.

PART 2 PRODUCTS (NOT USED)

PART 3 EXECUTION (NOT USED)

PROCUREMENT SUBSTITUTION REQUEST FORM

TO:	JLG Architects 214 Broadway Fargo, ND 58102	Phone: 701-365-4103 Contact: Chelsea Clark CClark@jlgarchitects.com	
PROJI	ECT: Fargo Public Library, Sunshade Replacemer	nt Project, Fargo, ND	
Sectio	n Number Section Title		
Specif	fied Product		
Propos	sed Substitution		
All of	the following questions must be answered. Inc	omplete forms will be not be reviewed.	
A.	The following supporting data is attached: Drawings Product Data	amples	
В.	Does the proposed substitution affect dimensions shown on Drawings, or functional clearances? YES NO 		
C.	Does the proposed substitution change the design or details shown on the Drawings? YES NO 		
D.	Does the proposed substitution affect other trades YES DO	?	
E.	Does the proposed substitution affect maintenance service, or source of replacement parts, if applicable? YES NO 		
F.	Does the proposed guarantee or warranty differ from that specified?		
G.	If you indicated "YES" to Items B, C, D, E or F above, attach a thorough explanation on your company letterhead.		
Н.	If there are other major differences between proposed substitution and specified product, attach a thorough explanation on your company letterhead.		
I.	The proposed substitution was used within the last 24 months on the following project:		
	Project Name		
	Architect Tel	ephone No	
J.	Has the proposed substitution been used on a JL	G Architects project within the last 12 months?	
K.	The undersigned states that the function, appeara superior to the specified item.	nce and quality of the substitution item are equivalent or	
Submi	itted By:		
Signat	ture	=irm	
Addres	SS		
Teleph	hone	⁼ ax	
Date _	E-Mail		
For Us	se By Design Consultant:		
	epted Accepted As Noted	Not Accepted Received Too Late	
Name		Signature	
Date _	Remarks		

SECTION 00 5000 - CONTRACTING FORMS AND SUPPLEMENTS

PART 1 GENERAL

1.01 CONTRACTOR IS RESPONSIBLE FOR OBTAINING A VALID LICENSE TO USE ALL COPYRIGHTED DOCUMENTS SPECIFIED BUT NOT INCLUDED IN THE PROJECT MANUAL.

1.02 AGREEMENT AND CONDITIONS OF THE CONTRACT

- A. See Section 00 5200 Agreement Form for the Agreement form to be executed.
- B. See Section 00 7200 General Conditions for the General Conditions.
- C. The Agreement and General Conditions are based on AIA A105.

1.03 FORMS

- A. Use the following forms for the specified purposes unless otherwise indicated elsewhere in Contract Documents.
- B. Post-Award Certificates and Other Forms:
- C. Clarification and Modification Forms:
- D. Closeout Forms:

1.04 REFERENCE STANDARDS

A. AIA A105 - Standard Short Form of Agreement Between Owner and Contractor 2017.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

SECTION 00 7300 - SUPPLEMENTARY CONDITIONS

PART 1 - GENERAL

The following supplements modify, change, delete from, or add to the General Conditions of the Contract for Construction, AIA Document A201, 2017. Where a portion of the General Conditions is modified or deleted by these Supplementary Conditions, the unaltered portions of the General Conditions shall remain in effect.

ARTICLE 1 GENERAL PROVISIONS

1.1 Basic Definitions

- Add: 1.1.3.1 The term "provide" shall mean furnish and install in place.
- 1.1.5 After the paragraph, Add: The general character and scope of the Work is shown by the Drawings. Where a portion of the Work is fully drawn and the remainder is merely indicated, the portion fully drawn shall apply to all similar parts of the Work.
- Add: 1.1.5.1 Figured dimensions on the Drawings shall be followed in preference to scaled measurements on the Drawings.
- 1.1.6 After the paragraph, Add: Where Specifications are abbreviated type, they indicate complete sentences in the same manner as when a note occurs in the Drawings. Omissions of words such as "the Contractor shall" and "as shown on the Drawings" is intentional. The words "shall" or "shall be" are to be supplied by inference.
- Add: 1.1.6.1 Where a number is listed in the Specifications (as for gauges, weights, temperatures, amounts of time, etc.), the number shall be interpreted as that or better.

1.2 Correlation and Intent of the Contract Documents

- Add: 1.2.4 In the case of an inconsistency between Drawings and Specifications or within either Document not clarified by addendum, the better quality or greater quantity of Work shall be provided.
- Add: 1.2.5 As experienced Contractors and Subcontractors, it is assumed each Contractor and Subcontractor understands not all components may be shown on the Drawings including, but not limited to, fasteners, connectors and incidental supports. This shall not relieve the Contractors or Subcontractors from providing all materials, equipment, fasteners, and incidental components as required for a complete installation in accordance with the design intent.

1.5 Ownership and Use of Drawings, Specifications, and Other Instruments of Service

Add: 1.5.2.1 The Contractor(s) may retain one record set of Drawings and Project Manual(s).

1.6 Notice

1.6.1 omit the words "if a method for electronic transmission is set forth in the Agreement".

ARTICLE 2 OWNER

2.3 Information and Services Required of the Owner

2.3.6 Replace the text with: The Contractor(s) will be furnished as many sets of Drawings and Project Manuals as the Architect has available for distribution, but in no case less than one. If the Contractor(s) require additional sets, an electronic copy of the documents will be provided in Adobe PDF format with which the Contractor(s) may use to make additional copies at their expense.

2.4 Required Property Insurance

2.3.1 Unless this obligation is placed on the Contractor pursuant to Section A.3.3.2.1, the Owner shall purchase and maintain, from an insurance company or insurance companies lawfully authorized to issue insurance in the jurisdiction where the Project is located, property insurance written on a builder's risk "all-risks" completed value or equivalent policy insurance coverage shall be no less than the amount of the initial Contract Sum, plus the value of subsequent Modifications and labor performed and

materials or equipment supplied by others. The property insurance shall be maintained until Substantial Completion and thereafter as provided in Section A.2.3.1.3, unless otherwise provided in the Contract Documents or otherwise agreed in writing by the parties to the Agreement. This insurance shall include the interests of the Owner, Contractor, Subcontractors and Sub-subcontractors in the Project as insureds. This insurance shall include the interests of mortgages as loss payees.

ARTICLE 3 CONTRACTOR

3.2 Review of Contract Documents and Field Conditions by Contractor

3.2.1 Add the words "including the geotechnical report (if any)," following the word "performed,".

3.4 Labor and Materials

Add: 3.4.2.1 After the Contract has been executed, the Owner and Architect may consider requests for the substitution of products in place of those specified. The Owner and Architect may, but are not obligated to, consider only those substitution requests that are in full conformance with the conditions set forth in the General Requirements (Division 1 of the Specifications). By making requests for substitutions, the Contractor:

.1 represents that it has personally investigated the proposed substitute product and determined that it is equal or superior in all respects to the product specified;

.2 represents that it will provide the same warranty for the substitution as it would have provided for the product specified;

.3 certifies that the cost data presented is complete and includes all related costs for the substituted product and for Work that must be performed or changed as a result of the substitution, except for the Architect's redesign costs, and waives all claims for additional costs related to the substitution that subsequently become apparent;

.4 agrees that it shall, if the substitution is approved, coordinate the installation of the accepted substitute, making such changes as may be required for the Work to be complete in all respects; and

.5 represents that the request includes a written representation identifying any potential effect the substitution may have on the Project's achievement of a Sustainable Measure or the Sustainable Objective.

- Add: 3.4.4 No trade shall commence Work until conditions are satisfactory for carrying out the Work properly, and surfaces to be covered are suitable.
- Add: 3.4.5 Manufacturer's printed instructions covering details of installation shall be followed where not in conflict with these Specifications. If there is a conflict, notify the Architect and obtain Architect's approval before proceeding.
- Add: 3.4.6 Completed Work shall be left plumb, level, true to line or plane, anchored securely in place, and free from damage.
- Add: 3.4.7 Unless otherwise called for, all pieces of material shall be as large a stock size as is in conformity with standard good practice of the trade.
- Add: 3.4.8 Except where in conflict with the Specifications, current manufacturer's printed instructions of herein specified proprietary products are made part of the Specifications.
- Add: 3.4.9 The Owner shall be entitled to reimbursement from the Contractor for amounts paid to the Architect for reviewing the Contractor's proposed substitutions and making agreed-upon changes in the Drawings and Specifications resulting from such substitutions.
- Add: 3.4.10 The Contractor shall provide all incidental materials and components including, but not limited to, fasteners, connectors, incidental supports and other components of construction as required for complete installation in accordance with the design intent.

3.5 Warranty

Add: 3.5.1.1 The Contractor further warrants that all products, materials and equipment provided under the Contract are asbestos-free as defined under current EPA Guidelines, and that they do not contain any other materials currently known to be hazardous.

3.7 Permits, Fees, Notices and Compliance with Laws

- 3.7.1 Change the word "...Contractor..." to read "...General Contractor..."
- Add: 3.7.2.1 When the Contract Documents require Work better than that required by statute, the Contract Documents shall govern.

3.12 Shop Drawings, Product Data and Samples

Add: 3.12.6.1 If the Contractor or any Subcontractor uses a material, product or piece of equipment which requires modification(s) to any other portion of the Work, including mechanical and electrical Work, the Contractor or Subcontractor using that material, product or piece of equipment shall be responsible for coordinating all required modifications and shall bear the full cost of such modifications.

ARTICLE 4 ARCHITECT

4.2 Administration of the Contract

4.2.3 Add to the end of paragraph: The Architect will not be responsible for the acts or omissions of the Owner.

ARTICLE 5 SUBCONTRACTORS

5.1 Definitions

Add: 5.1.3 All Subcontractors are bound to the terms of the General and Supplementary Conditions.

ARTICLE 6 CONSTRUCTION BY OWNER OR BY SEPARATE CONTRACTORS

No supplement.

ARTICLE 7 CHANGES IN THE WORK

- 7.1 General
 - Add: 7.1.4 All proposals shall, at a minimum, include detailed breakdown and indicate the terms enumerated below. Item (a) constitutes the cost of labor, and items (a), (b), and (c) constitute the basic costs referred to under this Article 7.

(a) Labor costs, itemized by each trade involved, showing the hourly rates for each, and the hours required for the change. Labor rates shall be the same for extra and credit computations and shall be the actual rate paid the workmen, plus contractor's burden on labor, which shall be only the actual costs of fringe benefits, taxes on labor, worker's or workmen's compensation, insurance on labor as affected by payroll, unemployment taxes and insurance, including FICA and FUTA.

(b) Quantities of materials, equipment and supplies, at their actual cost, with unit costs indicated, plus applicable sales tax.

(c) The cost of subcontracted work, computed in the same way as provided for under this subparagraph.

(d) Overhead, profit or commission added after the above computations are complete. Such overhead, profit or commission shall be computed in accordance with the provisions of subparagraph 7.1.5.

Add: 7.1.5 Maximum allowances for Subcontractor's/Contractor's overhead and profit shall be as follows, expressed as a percentage of the basic cost of the change:

For Subcontractors:	a. 15% of the net cost of the additional Work.
For Contractor:	b. 5% of the net cost of the additional Work performed by
	Subcontractors
	c. 15% of the net cost of the work performed by Contractor's

own forces.
Add 5% to a and c for all changes of less than \$500.00;
deduct 5% from a and c for all changes over \$10,000.00.

Overhead and profit shall include all bond premiums (if applicable), and will not be allowed on labor costs if overhead and profit is already included in hourly billing rate.

Add: 7.1.6 For proposed changes in the Work on the lump sum or time and material methods, the costs shall be determined as provided in this subparagraph. The Contractor shall submit an itemized list of quantities with the applicable unit costs and extended price for each, in such form and detail as required by the Architect.

7.2 Change Orders

7.2.2 Neither the Owner nor the Architect are responsible to give Notice of Change Orders to the surety.

7.3 Construction Change Directives

- 7.3.2 At the end of the sentence, Add: "or as deemed necessary by the Architect".
- 7.3.4 At the end of the first sentence replace "a reasonable allowance for overhead and profit." with " allowances for overhead and profit as indicated in 7.1.5."

ARTICLE 8 TIME

8.1 Definitions

- Add: 8.1.3.1 Minor corrective Work and the replacement of defective Work or materials, and the adjustment of control apparatus, will not delay the determination that the Contract is Substantially Complete.
- Add: 8.1.3.2 The date of Final Completion is the date certified by the Architect in accordance with Paragraph 9.10.2.

8.3 Delays and Extensions of Time

Add: 8.3.1.1 The following will not be considered justifications for extension of time unless due to one of the causes stated within Article 8:

a) Delay caused by Subcontractors or Supplier except if the Supplier goes out of business and another Supplier cannot be found in time to meet the schedule.

b) Shortage of workers.

Add: 8.3.1.2 Change Orders for extension of Contract Time shall be considered only under the following conditions or circumstances:

.1 As indicated in Paragraph 8.3.1. The burden of proof to substantiate the extension of time shall rest with the Contractor, including evidence that the cause was beyond their control. The Contractor shall be deemed to have had control of the supply of labor (except in the case of organized labor disputes), materials, equipment, methods, and techniques, and of the Subcontractors.

.2 A delay in the progress of the Work actually occurred as a result of one of the valid causes for time extension.

.3 Unusual delay in delivery solely due to a delay in transportation. An extension of time shall not be considered when delay in delivery is due to improperly scheduled delivery, or when an order has not been promptly and properly placed.

.4 Abnormal weather conditions. The Contractor shall consider the location of the Project, and shall recognize the existence of variations from severe deviations from average climatic conditions. Foul weather in and of itself shall not be a valid cause for a time extension. Time extensions resulting from abnormal weather shall not be considered unless a significant deviation from average seasonal climatic conditions occurred for an extended period of time, and the progress of the Work was delayed to a significant extent. The climatic conditions before and after

the period for which the delay is sought shall be evaluated.

.5 Changes in the Work which significantly affect the progress of the Work. When the anticipated delay can be determined the extension will be made when the Change in Work is authorized by the Owner. When the anticipated delay cannot be determined, the Contractor shall estimate the additional time required, and a mechanism for all parties to determine the allowable delay. In such a case, the Architect will determine the time extension and the Contract Time adjusted accordingly by Change Order. For changes in the Work which affect only a portion or Phase of the entire project, the Owner reserves the right to grant a time extension only for that portion or Phase affected by the Change.

.6 Labor disputes except for lockouts over which the Contractor has control. The amount of time extension shall not be longer than the actual dispute period plus a reasonable time for mobilization, and such extension may be less than the actual dispute period depending on the effect the dispute had upon the progress of the Work.

.7 Unavoidable delays such as damage caused by severe weather, fire or other casualty to the Work; remediation of contaminants, pollutants, or hazardous materials or substances discovered after award of the Contract; litigation including without limitation bankruptcy proceedings; the acts of any federal, state or local government unit that directly result in delays; and other delays outside the control of the Party claiming the delay.

.8 Delays caused by Subcontractors shall be considered only under the conditions noted above.

.9 Time extensions may be granted through a change order for substantiated abnormal weather conditions, however, no change to the contract price will be granted.

Add: 8.3.1.3 Time extensions shall not be granted as a result of delays caused by improper scheduling, or by failure of the Contractor to have Shop Drawings or other required submittals submitted in sufficient time for review.

ARTICLE 9 PAYMENTS AND COMPLETION

9.1 Contract Sum

9.1.2 Add sentence at end: "The costs for overhead, profit and commission shall be determined in accordance with the provisions of subparagraph 7.1.5."

9.3 Applications for Payment

- 9.3.1 In the first sentence replace: "At least ten days before the date established for each progress payment," with: "Not more than once a month,".
- 9.3.2 Replace the text with: Unless otherwise provided in the Contract Documents, payments shall be made on account of materials and equipment delivered to and suitably stored at the site for subsequent incorporation into the Work. Contractor shall not receive payment for materials and equipment stored off site. Payment for materials and equipment stored on the site shall be conditioned upon compliance by the Contractor with procedures satisfactory to the Owner to establish the Owner's title to such materials or equipment, or otherwise protect the Owner's interest, including applicable insurance.
- Add 9.3.4 Progress payments shall be made monthly upon application, in the amount of 90% of the Work completed and materials described under 9.3.2. For a Contract of over \$100 thousand, the Architect will authorize the payment of 100% of the amount completed after a total of 5% of the Contract amount has been retained, providing progress on the Work is in accordance with or ahead of the Contractor's construction schedule and is satisfactory to the Architect and if the Contractor has filed a Consent of Surety with the Architect.

9.8 Substantial Completion

- 9.8.1At the end of the paragraph Add: In all cases, the date of the Substantial Completion may not be earlier than the Certificate of Occupancy issued by the authority having jurisdiction. Minor corrective Work, the replacement of defective Work or materials, and the adjustment of control apparatus will not delay the determination of Substantial Completion. See paragraph 12.2.2.
- 9.8.2At the end of the paragraph Add: Minor punch list items that do not interfere with using the Work as intended may be corrected between Substantial Completion and Final Completion.

9.10 Final Completion and Final Payment

9.10.2 After "warranties or specific Subcontractor warranties," DELETE "and (6)" and REPLACE WITH ", (6) written certification from Contractor in accordance with Final Inspection requirements of Section 01 7800, (7) all Contract Closeout submittals required by Section 01 7800, each submittal having been approved by the Architect, and (8)".

ARTICLE 10 PROTECTION OF PERSONS AND PROPERTY

10.3 Hazardous Materials and Substances

10.3.1 In the second sentence after: "asbestos", Add: ", lead-containing materials,"

ARTICLE 11 INSURANCE AND BONDS

11.5 Adjustment and Settlement of Insured Loss

11.5.1 At the end of the first sentence add: "except when the fiduciary consents to allow a party with a claim to settle directly with the insurer.

ARTICLE 12 UNCOVERING AND CORRECTION OF WORK

No supplement.

ARTICLE 13 MISCELLANEOUS PROVISIONS

No supplement.

ARTICLE 14 TERMINATION OR SUSPENSION OF THE CONTRACT

14.2 Termination by the Owner for Cause

- 14.2.1.2 At the end of the Subparagraph Add "or in accordance with the Contract Documents".
- Add: 14.2.1.5 files a bankruptcy petition or has a bankruptcy action commenced against it that is not discharged within 30 days of commencement of same, makes an assignment for the benefit of its creditors, has a receiver appointed to manage the Contractor's assets or otherwise becomes insolvent;
- Add: 14.2.1.6 fails to maintain schedules as required by the Contract Documents, or fails to comply in a material way with design requirements of the Contract Documents, or persistently fails to perform the Work in accordance with the Contract Documents.
- 14.2.4 Replace the text with: If the unpaid balance of the Contract Sum exceeds the direct and indirect consequential costs of completing the Work (including but not limited to fees and charges of engineers, architects, attorneys and other professionals and court and arbitration costs), and other damages incurred by the Owner, such excess will be paid to the Contractor. If such costs and damages exceed such unpaid balance, the Contractor shall pay the difference to the Owner. Such costs incurred by the Owner will be approved as to reasonableness by the Architect, but when exercising any rights or remedies under this paragraph, the Owner shall not be required to obtain the lowest price for the Work performed. This obligation to payment shall survive termination of the Contract.

ARTICLE 15 CLAIMS AND DISPUTES

15.1.6 Claims for Additional Time

Add: 15.1.6.3 Claims for increase in the Contract Time shall set forth in detail the circumstances that form the basis for the Claim, the date upon which ease cause of delay began to affect the progress of the

Work, the date upon which each cause of delay ceased to affect the progress of the Work, and the number of days' increase in the Contract Time claimed as a consequence of each such cause of delay. The Contractor shall provide such supporting documentation as the Owner may require including, where appropriate, a revised construction schedule indicating all the activities affected by the circumstances forming the basis of the Claim.

Add: 15.1.6.4 The Contractor shall not be entitled to a separate increase in the Contract Time for each one of the number of causes of delay which may have concurrent or interrelated effects on the progress of the Work, or for concurrent delays due to the fault of the Contractor

SECTION 01 2000 - PRICE AND PAYMENT PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Procedures for preparation and submittal of applications for progress payments.
- B. Documentation of changes in Contract Sum and Contract Time.
- C. Change procedures.
- D. Procedures for preparation and submittal of application for final payment.

1.02 RELATED REQUIREMENTS

A. Section 00 5000 - Contracting Forms and Supplements: Forms to be used.

1.03 SCHEDULE OF VALUES

- A. Electronic media printout including equivalent information will be considered in lieu of standard form specified; submit draft to Architect for approval.
- B. Forms filled out by hand will not be accepted.
- C. Submit Schedule of Values to the Architect at the earliest feasible date, but in no case later than seven days before the date scheduled for submittal of the initial application for payment.
- D. Format: Utilize the Table of Contents of this Project Manual. Identify each line item with number and title of the specification Section.
 - 1. Provide a breakdown of the Contract Sum in sufficient detail to facilitate continued evaluation of Applications for Payment and progress reports.
 - 2. Break principle subcontract amounts down into several line items.
 - 3. Round amounts off to the nearest whole dollar; the total shall equal the Contract Sum.
 - 4. For each part of the Work where an Application for Payment may include materials or equipment purchased or fabricated and stored, but not yet installed, provide separate line items on the Schedule of Values for initial cost of the materials, for each subsequent stage of completion, and for total installed value of that part of the Work.
 - 5. Margins of Cost: Show line items for indirect costs, and margins on actual costs, only to the extent that such items will be listed individually in Applications for Payment. Each item in the Schedule of Values and Application for Payment shall be complete including its total cost and proportionate share of general overhead and profit margin.
 - 6. At the Contractor's option, temporary facilities and other major cost items that are not direct cost of actual work-in-place may be shown as separate line items in the Schedule of Values or distributed as general overhead expense.
- E. Correlate line items in the Schedule of Values with other required administrative schedules and forms, including:
 - 1. Contractor's construction schedule.
 - 2. Application for Payment form.
 - 3. List of subcontractors.
 - 4. List of principal suppliers and fabricators.
- F. Revise schedule to list approved Change Orders, with each Application For Payment.

1.04 APPLICATIONS FOR PROGRESS PAYMENTS

A. Payment Period: Submit at intervals stipulated in the Agreement.
- B. Forms filled out by hand will not be accepted.
- C. Execute certification by signature of authorized officer.
- D. Use data from approved Schedule of Values. Provide dollar value in each column for each line item for portion of work performed and for stored products.
- E. List each authorized Change Order as a separate line item, listing Change Order number and dollar amount as for an original item of work.
- F. Submit three copies of each Application for Payment to the Architect by means ensuring receipt within 24 hours; one copy shall be complete, including waivers of lien, payroll reports, and/or similar attachments, when required.
 - 1. One approved copy will be retained by the Architect, one will be returned to the Contractor, and one forwarded to the Owner for their use in issuing payment.
- G. Initial Application for Payment: Administrative actions and submittals that must precede or coincide with submittal of the first Application for Payment include the following:
 - 1. List of subcontractors: AIA G705.
 - 2. List of principle suppliers and fabricators.
 - 3. Schedule of Values: AIA G703.
 - 4. Submittal schedule.
 - 5. Contractor's Construction Schedule (preliminary if not final).
 - 6. Schedule of principal products.
 - 7. List of Contractor's staff assignments.
 - 8. Certificates of insurance and insurance policies.
- H. Include the following with each application:
 - 1. Waivers of Mechanics Lien: Submit waivers of mechanics lien from every entity who may lawfully be entitled to file a mechanics lien arising out of the Contract, and related to the Work covered by the payment.
 - 2. Construction progress schedule, revised and current as specified in Section 01 3216.
 - 3. Affidavits attesting to off-site stored products.
- I. Application for Payment at Substantial Completion: Following issuance of the Certificate of Substantial Completion, submit an Application for Payment; this application shall reflect any Certificates of Partial Substantial Completion issued previously for Owner occupancy of designated portions of the Work.
 - 1. Administrative actions and submittals that shall precede or coincide with this application include:
 - a. Occupancy permits and similar approvals.
 - b. Warranties (guarantees) and maintenance agreements.
 - c. Testing, adjusting, and balancing reports.
 - d. Maintenance instructions.
 - e. Start-up performance reports.
 - f. Change-over information related to Owner's occupancy, use, operation, and maintenance.
 - g. Final cleaning.
 - h. Application for reduction of retainage, and consent of surety.
 - i. List of incomplete Work, recognized as exceptions to Architect's Certificate of Substantial Completion.

1.05 MODIFICATION PROCEDURES

A. For minor changes not involving an adjustment to the Contract Sum or Contract Time, Architect will issue Supplemental Instructions on AIA form G710 directly to Contractor.

- B. Change Orders: For changes for which advance pricing is desired, Architect will issue a document that includes a detailed description of a proposed change with supplementary or revised drawings and specifications, a change in Contract Time for executing the change and the period of time during which the requested price will be considered valid. Contractor shall prepare and submit a fixed price quotation within 7 days.
 - 1. Owner-Initiated Proposal Requests: Proposed changes in the Work that will require adjustment to the Contract Sum or Contract Time will be issued by the Architect, with a detailed description of the proposed change and supplemental or revised Drawings and Specifications, if necessary.
 - a. Proposal requests issued by the Architect are for information only. Do not consider Proposal Requests as an instruction either to stop work in progress, or to execute the proposed change.
 - b. Unless otherwise indicated in the proposal request, within 5 days of receipt of the proposal request, submit to the Architect for the Owner's review an estimate of cost necessary to execute the proposed change.
 - c. Include a list of quantities of products to be purchased and unit costs, along with the total amount of purchases to be made. Where requested, furnish survey data to substantiate quantities.
 - d. Indicate applicable taxes, delivery charges, equipment rental, and amounts of trade discounts.
 - e. Include a statement indicating the effect the proposed change in the Work will have on the Contract Time.
 - 2. Contractor-Initiated Change Order Proposal Requests: When latent or other unforeseen conditions require modifications to the Contract, the Contractor may propose changes by submitting a request for a change to the Architect.
 - a. Include a statement outlining the reasons for the change and the effect of the change on the Work. Provide a complete description of the proposed change. Indicate the effect of the proposed change on the Contract Sum and Contract Time.
 - b. Include a list of quantities of products to be purchased and unit costs along with the total amount of purchases to be made. Where requested, furnish survey data to substantiate quantities.
 - c. Indicate applicable taxes, delivery charges, equipment rental, and amounts of trade discounts.
 - d. Comply with requirements in Section "Product Substitutions" if the proposed change in the Work requires the substitution of a product or system for a product or system specified.
 - 3. Proposal Request Form: Use AIA Document G709 for Change Order Proposal Requests.
- C. Construction Change Directive: When the Owner and Contractor are not in total agreement on the terms of a Change Order Proposal Request, the Architect may issue a Construction Change Directive instructing the Contractor to proceed with a change in the Work, for subsequent inclusion in a Change Order.
 - 1. The Construction Change Directive will contain a complete description of the change in the Work and designate the method to be followed to determine change in the Contract Sum or Contract Time.
 - 2. Documentation: Maintain detailed records on a time and material basis of work required by the Construction Change Directive.

- 3. After completion of the change, submit an itemized account and supporting data necessary to substantiate cost and time adjustments to the Contract.
- D. Computation of Change in Contract Amount: As specified in the Agreement and Conditions of the Contract.
 - 1. Maximum allowances for Subcontractor's/Contractor's overhead and profit as expressed as a percentage of the basic cost of the change:
 - a. Subcontractors: 15% of the net cost of the additional Work.
 - b. Contractors: 5% of the net cost of the additional Work performed by subcontractors.
 - c. Contractors: 15% of the net cost of work performed by the contractor's own forces.
 - d. Add 5% to above allowances for changes of less than \$500.00.
 - e. Deduct 5% from above allowances for changes greater than \$10,000.00.
 - f. Overhead and profit shall include all bond premiums (if applicable), and will not be allowed on labor costs if overhead and profit is already included in hourly billing rate.
- E. Execution of Change Orders: Architect will issue Change Orders for signatures of parties as provided in the Conditions of the Contract.
- F. After execution of Change Order, promptly revise Schedule of Values and Application for Payment forms to record each authorized Change Order as a separate line item and adjust the Contract Sum.
- G. Promptly revise progress schedules to reflect any change in Contract Time, revise sub-schedules to adjust times for other items of work affected by the change, and resubmit.
- H. Promptly enter changes in Project Record Documents.

1.06 APPLICATION FOR FINAL PAYMENT

- A. Prepare Application for Final Payment as specified for progress payments, identifying total adjusted Contract Sum, previous payments, and sum remaining due.
- B. Application for Final Payment will not be considered until the following have been accomplished:
 - 1. All closeout procedures specified in Section 01 7000.
 - 2. Completion of items specified for completion after Substantial Completion (punchlists).
 - 3. Assurance that unsettled claims will be settled.
 - 4. Assurance that Work not complete and accepted will be completed without undue delay.
 - 5. Transmittal of required construction records to Owner.
 - 6. Proof taxes, fees, and similar obligations have been paid.
 - 7. Removal of temporary facilities and services.
 - 8. Removal of surplus materials, rubbish, and similar elements.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

SECTION 01 2300 - ALTERNATES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Description of Alternates.
- B. Procedures for pricing Alternates.
- C. Documentation of changes to Contract Sum and Contract Time.

1.02 DEFINITIONS

A. Alternate: An alternate is an amount proposed by Proposal Submitters and stated on the Proposal Form for certain construction activities defined in the Proposal Requirements that may be added to or deducted from the Base Proposal amount if the Owner decides to accept a corresponding change in either the amount of construction to be completed, or in the products, materials, equipment, systems, or installation methods described in the Contract Documents.

1.03 ACCEPTANCE OF ALTERNATES

- A. Alternates quoted on Proposal Forms will be reviewed and accepted or rejected at Owner's option. Accepted Alternates will be identified in the Owner-Contractor Agreement.
- B. Coordinate related work and modify surrounding work to integrate the Work of each Alternate.
- C. Work Included Under Each Alternate: Make modifications to work required by each alternate selected at no additional cost to the Owner other than as proposed on the Proposal Form. Proposal Submitters shall be responsible for alternates and shall see that all changes are covered under their related sections, whether specifically called out or not. Extra costs incurred due to modifications to or deviations from the Drawings or Specifications caused directly or indirectly by each alternate shall be included in each alternate proposal.

1.04 SCHEDULE OF ALTERNATES

- A. Alternate No. 1: Abandon Existing Wiring.
 - 1. State the amount to be DEDUCTED from the Base Proposal to provide all materials, labor & equipment required for abandoning existing wiring, (base proposal to remove existing sunshade electrical wiring), as indicated in the drawings and specifications.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

SECTION 01 2500 - SUBSTITUTION PROCEDURES

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Procedural requirements for proposed substitutions.

1.02 RELATED REQUIREMENTS

- A. Section 00 2600 Procurement Substitution Procedures: Required form for substitutions requests made before the end of proposal (during procurement).
- B. Section 01 3000 Administrative Requirements: Submittal procedures, coordination.
- C. Section 01 6000 Product Requirements: Fundamental product requirements, product options, delivery, storage, and handling.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 GENERAL REQUIREMENTS

- A. A Substitution Request for products, assemblies, materials, and equipment constitutes a representation that the submitter:
 - 1. Has investigated proposed product and determined that it meets or exceeds the quality level of the specified product, equipment, assembly, or system.
 - 2. Agrees to provide the same warranty for the substitution as for the specified product.
 - 3. Agrees to provide same or equivalent maintenance service and source of replacement parts, as applicable.
 - 4. Agrees to coordinate installation and make changes to other work that may be required for the work to be complete, with no additional cost to Owner.
 - 5. Waives claims for additional costs or time extension that may subsequently become apparent.
 - 6. Agrees to reimburse Owner and Architect for review or redesign services associated with reapproval by authorities.
- B. Where a product requirement includes sustainability documentation, this documentation is required to to be included in the substitution request. If documentation is not included, the substitution will be rejected. See individual Specification Sections sustainability requirements.
- C. Document each request with complete data substantiating compliance of proposed substitution with Contract Documents. Burden of proof is on proposer.
- D. Content: Include information necessary for tracking the status of each Substitution Request, and information necessary to provide an actionable response.
 - 1. Forms included in the Project Manual are adequate for this purpose, and must be used.
- E. Limit each request to a single proposed substitution item.
 - 1. Submit an electronic document, combining the request form with supporting data into single document.

3.02 SUBSTITUTION PROCEDURES DURING PROCUREMENT

- A. Submittal Time Restrictions:
- B. Section 00 2600 Procurement Substitution Procedures specifies time restrictions for submitting requests for substitutions during the proposal period, and the documents required.

C. Submittal Form (before award of contract):

3.03 SUBSTITUTION PROCEDURES DURING CONSTRUCTION

- A. Submittal Form (after award of contract):
 - 1. Submit substitution requests by completing CSI/CSC Form 13.1A Substitution Request (After Proposal/Negotiating). See this form for additional information and instructions. Use only this form; other forms of submission are unacceptable.
- B. Architect will consider requests for substitutions only within 30 days after date of Agreement. Requests for substitutions after the proposals have been received are done so at the risk of the Contractor. Substitutions may not be granted.
- C. Substitutions may be considered when a product becomes unavailable through no fault of the Contractor.
- D. Substitutions will not be considered under one or more of the following circumstances:
 - 1. When they are indicated or implied on shop drawing or product data submittals, without having received prior approval.
 - 2. Without a separate written request.
 - 3. When acceptance will require revisions to Contract Documents.

3.04 RESOLUTION

- A. Architect may request additional information and documentation prior to rendering a decision. Provide this data in an expeditious manner.
- B. Architect will notify Contractor in writing of decision to accept or reject request.

3.05 ACCEPTANCE

A. Accepted substitutions change the work of the Project. They will be documented and incorporated into work of the project by Change Order, Construction Change Directive, Architectural Supplementary Instructions, or similar instruments provided for in the Conditions of the Contract.

SECTION 01 3000 - ADMINISTRATIVE REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. General administrative requirements.
- B. Electronic document submittal service.
- C. Preconstruction meeting.
- D. Progress meetings.
- E. Number of copies of submittals.
- F. Requests for Information (RFI) procedures.
- G. Submittal procedures.

1.02 RELATED REQUIREMENTS

A. Section 01 6000 - Product Requirements: General product requirements.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 ELECTRONIC DOCUMENT SUBMITTAL SERVICE

- A. All documents transmitted for purposes of administration of the contract are to be in electronic (PDF, MS Word, or MS Excel) format, as appropriate to the document, and transmitted via an Internet-based submittal service that receives, logs and stores documents, provides electronic stamping and signatures, and notifies addressees via email.
 - 1. Besides submittals for review, information, and closeout, this procedure applies to Requests for Information (RFIs), progress documentation, contract modification documents (e.g. supplementary instructions, change proposals, change orders), applications for payment, field reports and meeting minutes, Contractor's correction punchlist, and any other document any participant wishes to make part of the project record.
 - 2. Contractor and Architect are required to use this service.
 - 3. It is Contractor's responsibility to submit documents in allowable format.
 - 4. Subcontractors, suppliers, and Architect's consultants are to be permitted to use the service at no extra charge.
 - 5. Users of the service need an email address, internet access, and PDF review software that includes ability to mark up and apply electronic stamps (such as Adobe Acrobat, www.adobe.com, or Bluebeam PDF Revu, www.bluebeam.com), unless such software capability is provided by the service provider.
 - 6. Paper document transmittals will not be reviewed; emailed electronic documents will not be reviewed.
 - 7. All other specified submittal and document transmission procedures apply, except that electronic document requirements do not apply to samples or color selection charts.
- B. Cost: The cost of the service is to be paid by Contractor; include the cost of the service in the Contract Sum.
- C. Training: One, one-hour, web-based training session will be arranged for all participants, with representatives of Architect and Contractor participating; further training is the responsibility of the

user of the service.

D. Project Closeout: Architect will determine when to terminate the service for the project and is responsible for obtaining archive copies of files for Owner.

3.02 PRECONSTRUCTION MEETING

- A. Schedule meeting after Notice of Award.
- B. Attendance Required:
 - 1. Owner.
 - 2. Architect.
 - 3. Contractor.
 - 4. Major subcontractors.
- C. Agenda:
 - 1. Execution of Owner-Contractor Agreement.
 - 2. Submission of insurance certificates.
 - 3. Distribution of Contract Documents.
 - 4. Submission of list of subcontractors, list of products, schedule of values, and progress schedule.
 - 5. Procedures and processing of field decisions, submittals, substitutions, applications for payments, proposal request, Change Orders, and Contract closeout procedures.
 - 6. Scheduling.
 - a. Contractor's schedule.
 - b. Start of on-site work.
 - c. Completion date.
 - d. Coordination with on-site Owner's representatives.
 - e. Sequence of work.
 - f. Full or partial Owner occupancy as applicable.
 - 7. Shop drawings and sample distribution.
 - 8. Mockups.
 - 9. Critical products for the project timeline.
 - 10. Material deliveries.
 - 11. Procedures to be followed when working on site.
 - 12. Address items prior to on-site work.
 - a. Parking.
 - b. Noise and general safety.
 - c. Use of the site.
 - d. Construction Dumpster.
- D. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect, Owner, participants, and those affected by decisions made.

3.03 PROGRESS MEETINGS

- A. Schedule and administer meetings throughout progress of the work at maximum monthly intervals.
- B. Make arrangements for meetings, prepare agenda with copies for participants, preside at meetings.
- C. Attendance Required:
 - 1. Contractor.
 - 2. Owner.
 - 3. Architect.
 - 4. Contractor's superintendent.

- 5. Major subcontractors.
- D. Agenda:
 - 1. Review minutes of previous meetings.
 - 2. Review of work progress.
 - 3. Field observations, problems, and decisions.
 - 4. Identification of problems that impede, or will impede, planned progress.
 - 5. Review of submittals schedule and status of submittals.
 - 6. Review of off-site fabrication and delivery schedules.
 - 7. Maintenance of progress schedule.
 - 8. Corrective measures to regain projected schedules.
 - 9. Planned progress during succeeding work period.
 - 10. Coordination of projected progress.
 - 11. Maintenance of quality and work standards.
 - 12. Effect of proposed changes on progress schedule and coordination.
 - 13. Other business relating to work.
- E. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect, Owner, participants, and those affected by decisions made.

3.04 CLOSEOUT MEETING

- A. Schedule and administer meetings throughout progress of the work at maximum monthly intervals.
- B. Make arrangements for meetings, prepare agenda with copies for participants, preside at meetings.
- C. Attendance Required:
 - 1. Contractor.
 - 2. Owner.
 - 3. Architect.
 - 4. Applicable subcontractors.
- D. Agenda:
 - 1. Starting Systems and Owner Training.
 - a. Electrical.
 - b. Specialty Systems, i.e. Window Shades.
 - c. Testing, adjusting and balancing.
 - 2. Project Record Drawings.
 - 3. Record Project Manuals.
 - 4. Project Record Submittals.
 - 5. Warranties and Special Warranties.
 - 6. Spare parts, extra stock materials.
 - 7. Contractors initial punchlist.
 - 8. Architects review of punchlist.
 - 9. Consent of Surety of Final Payment.
 - 10. Final Payment and Retainage Reduction.
 - 11. Affidavit of Liens and Waivers.
 - 12. Insurance Coverages.
 - a. Property.
 - b. Liability.
 - 13. 11 Month Warranty.

E. Record minutes and distribute copies within two days after meeting to participants, with two copies to Architect, Owner, participants, and those affected by decisions made.

3.05 REQUESTS FOR INFORMATION (RFI)

- A. Definition: A request seeking one of the following:
 - 1. An interpretation, amplification, or clarification of some requirement of Contract Documents arising from inability to determine from them the exact material, process, or system to be installed; or when the elements of construction are required to occupy the same space (interference); or when an item of work is described differently at more than one place in Contract Documents.
 - 2. A resolution to an issue which has arisen due to field conditions and affects design intent.
- B. Whenever possible, request clarifications at the next appropriate project progress meeting, with response entered into meeting minutes, rendering unnecessary the issuance of a formal RFI.
- C. Preparation: Prepare an RFI immediately upon discovery of a need for interpretation of Contract Documents. Failure to submit a RFI in a timely manner is not a legitimate cause for claiming additional costs or delays in execution of the work.
 - 1. Prepare a separate RFI for each specific item.
 - a. Review, coordinate, and comment on requests originating with subcontractors and/or materials suppliers.
 - b. Do not forward requests which solely require internal coordination between subcontractors.
 - 2. Prepare in a format and with content acceptable to Owner.
 - 3. Prepare using software provided by the Electronic Document Submittal Service.
 - 4. Combine RFI and its attachments into a single electronic file. PDF format is preferred.
- D. Reason for the RFI: Prior to initiation of an RFI, carefully study all Contract Documents to confirm that information sufficient for their interpretation is definitely not included.
 - 1. Include in each request Contractor's signature attesting to good faith effort to determine from Contract Documents information requiring interpretation.
 - 2. Unacceptable Uses for RFIs: Do not use RFIs to request the following::
 - a. Approval of submittals (use procedures specified elsewhere in this section).
 - b. Approval of substitutions (see Section 01 6000 Product Requirements)
 - c. Changes that entail change in Contract Time and Contract Sum (comply with provisions of the Conditions of the Contract).
 - d. Different methods of performing work than those indicated in the Contract Drawings and Specifications (comply with provisions of the Conditions of the Contract).
 - 3. Improper RFIs: Requests not prepared in compliance with requirements of this section, and/or missing key information required to render an actionable response. They will be returned without a response, with an explanatory notation.
 - 4. Frivolous RFIs: Requests regarding information that is clearly indicated on, or reasonably inferable from, Contract Documents, with no additional input required to clarify the question. They will be returned without a response, with an explanatory notation.
 - a. The Owner reserves the right to assess the Contractor for the costs (on time-and-materials basis) incurred by the Architect, and any of its consultants, due to processing of such RFIs.
- E. Content: Include identifiers necessary for tracking the status of each RFI, and information necessary to provide an actionable response.

- 1. Official Project name and number, and any additional required identifiers established in Contract Documents.
- 2. Owner's, Architect's, and Contractor's names.
- 3. Discrete and consecutive RFI number, and descriptive subject/title.
- 4. Issue date, and requested reply date.
- Reference to particular Contract Document(s) requiring additional information/interpretation. Identify pertinent drawing and detail number and/or specification section number, title, and paragraph(s).
- 6. Annotations: Field dimensions and/or description of conditions which have engendered the request.
- 7. Contractor's suggested resolution: A written and/or a graphic solution, to scale, is required in cases where clarification of coordination issues is involved, for example; routing, clearances, and/or specific locations of work shown diagrammatically in Contract Documents. If applicable, state the likely impact of the suggested resolution on Contract Time or the Contract Sum.
- F. Attachments: Include sketches, coordination drawings, descriptions, photos, submittals, and other information necessary to substantiate the reason for the request.
- G. RFI Log: Prepare and maintain a tabular log of RFIs for the duration of the project.
 - 1. Indicate current status of every RFI. Update log promptly and on a regular basis.
 - 2. Note dates of when each request is made, and when a response is received.
 - 3. Highlight items requiring priority or expedited response.
 - 4. Highlight items for which a timely response has not been received to date.
 - 5. Identify and include improper or frivolous RFIs.
- H. Responses: Content of answered RFIs will not constitute in any manner a directive or authorization to perform extra work or delay the project. If in Contractor's belief it is likely to lead to a change to Contract Sum or Contract Time, promptly issue a notice to this effect, and follow up with an appropriate Change Order request to Owner.
 - 1. Do not extend applicability of a response to specific item to encompass other similar conditions, unless specifically so noted in the response.
 - 2. Upon receipt of a response, promptly review and distribute it to all affected parties, and update the RFI Log.

3.06 SUBMITTAL SCHEDULE

- A. Submit to Architect for review a schedule for submittals in tabular format.
 - 1. Coordinate with Contractor's construction schedule and schedule of values.
 - 2. Format schedule to allow tracking of status of submittals throughout duration of construction.
 - 3. Arrange information to include scheduled date for initial submittal, specification number and title, submittal category (for review or for information), description of item of work covered, and role and name of subcontractor.
 - 4. Account for time required for preparation, review, manufacturing, fabrication and delivery when establishing submittal delivery and review deadline dates.
 - a. For assemblies, equipment, systems comprised of multiple components and/or requiring detailed coordination with other work, allow for additional time to make corrections or revisions to initial submittals, and time for their review.

3.07 SUBMITTALS FOR REVIEW

A. When the following are specified in individual sections, submit them for review:

- 1. Product data.
- 2. Shop drawings.
- 3. Samples for selection.
- 4. Samples for verification.
- B. Submit to Architect for review for the limited purpose of checking for compliance with information given and the design concept expressed in Contract Documents.
- C. Samples will be reviewed for aesthetic, color, or finish selection.
- D. After review, provide copies and distribute in accordance with SUBMITTAL PROCEDURES article below and for record documents purposes described in Section 01 7800 Closeout Submittals.

3.08 SUBMITTALS FOR INFORMATION

- A. When the following are specified in individual sections, submit them for information:
 - 1. Manufacturer's instructions.
 - 2. Manufacturer's field reports.
 - 3. Other types indicated.
- B. Submit for Architect's knowledge as contract administrator or for Owner.

3.09 SUBMITTALS FOR PROJECT CLOSEOUT

- A. Submit Correction Punch List for Substantial Completion.
- B. Submit Final Correction Punch List for Substantial Completion.
- C. When the following are specified in individual sections, submit them at project closeout in compliance with requirements of Section 01 7800 Closeout Submittals:
 - 1. Project record documents.
 - 2. Operation and maintenance data.
 - 3. Warranties.
 - 4. Other types as indicated.
- D. Submit for Owner's benefit during and after project completion.

3.10 NUMBER OF COPIES OF SUBMITTALS

- A. Electronic Documents: Submit one electronic copy in PDF format; an electronically-marked up file will be returned. Create PDFs at native size and right-side up; illegible files will be rejected.
- B. Samples: Submit the number specified in individual specification sections; one of which will be retained by Architect.
 - 1. After review, produce duplicates.
 - 2. Retained samples will not be returned to Contractor unless specifically so stated.

3.11 SUBMITTAL PROCEDURES

- A. General Requirements:
 - 1. Use a separate transmittal for each item.
 - 2. Identify: Project; Contractor; subcontractor or supplier; pertinent drawing and detail number; and specification section number and article/paragraph, as appropriate on each copy.
 - 3. Apply Contractor's stamp, signed or initialed certifying that review, approval, verification of products required, field dimensions, adjacent construction work, and coordination of information is in accordance with the requirements of the work and Contract Documents.
 - a. Submittals from sources other than the Contractor, or without Contractor's stamp will not be acknowledged, reviewed, or returned.

- 4. Deliver each submittal on date noted in submittal schedule, unless an earlier date has been agreed to by all affected parties, and is of the benefit to the project.
- 5. Schedule submittals to expedite the Project, and coordinate submission of related items.
 - a. For each submittal for review, allow 15 days excluding delivery time to and from the Contractor.
 - b. For sequential reviews involving Architect's consultants, Owner, or another affected party, allow an additional 7 days.
 - c. Color selections will not be reviewed or approved until all related products are submitted to ensure a cohesive palette.
 - d. Products that make up a system, assembly, or that are directly related to each other often must be reviewed together. Review will not begin until all components are submitted.
 - e. Coordinate with Architect and/or Construction Manager, as applicable, where schedule dictates an expedited review of products.
- 6. Identify variations from Contract Documents and product or system limitations that may be detrimental to successful performance of the completed work.
- 7. Provide space for Contractor and Architect review stamps.
- 8. When revised for resubmission, identify all changes made since previous submission.
- 9. Distribute reviewed submittals. Instruct parties to promptly report inability to comply with requirements.
- 10. Incomplete submittals will not be reviewed, unless they are partial submittals for distinct portion(s) of the work, and have received prior approval for their use.
- B. Product Data Procedures:
 - 1. Submit only information required by individual specification sections.
 - 2. Collect required information into a single submittal.
 - 3. Do not submit (Material) Safety Data Sheets for materials or products.
- C. Shop Drawing Procedures:
 - 1. Prepare accurate, drawn-to-scale, original shop drawing documentation by interpreting Contract Documents and coordinating related work.
 - 2. Do not reproduce Contract Documents to create shop drawings.
 - 3. Generic, non-project-specific information submitted as shop drawings do not meet the requirements for shop drawings.
- D. Samples Procedures:
 - 1. Transmit related items together as single package.
 - 2. Identify each item to allow review for applicability in relation to shop drawings showing installation locations.
- E. Do not use shop drawings without an appropriate final stamp indicating action taken in connection with construction.

3.12 SUBMITTAL REVIEW

- A. Submittals for Review: Architect will review each submittal, and approve, or take other appropriate action.
- B. Submittals for Information: Architect will acknowledge receipt and review.
- C. Architect's actions will be reflected by marking each returned submittal using virtual stamp on electronic submittals.

SECTION 01 3216 - CONSTRUCTION PROGRESS SCHEDULE

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Preliminary schedule.
- B. Construction progress schedule, bar chart type.

1.02 SUBMITTALS

- A. Within 10 days after date of Agreement, submit preliminary schedule defining planned operations for the first 60 days of Work, with a general outline for remainder of Work.
- B. Submit updated schedule with each Application for Payment.

1.03 SCHEDULE FORMAT

- A. Listings: In chronological order according to the start date for each activity. Identify each activity with the applicable specification section number.
- B. Diagram Sheet Size: Maximum 22 x 17 inches (560 x 432 mm) or width required.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 PRELIMINARY SCHEDULE

A. Prepare preliminary schedule in the form of a horizontal bar chart.

3.02 CONTENT

- A. Show complete sequence of construction by activity, with dates for beginning and completion of each element of construction.
- B. Identify each item by specification section number.
- C. Identify work of separate stages and other logically grouped activities.
- D. Show accumulated percentage of completion of each item, and total percentage of Work completed, as of the first day of each month.
- E. Provide legend for symbols and abbreviations used.

3.03 BAR CHARTS

- A. Include a separate bar for each major portion of Work or operation.
- B. Identify the first work day of each week.

3.04 REVIEW AND EVALUATION OF SCHEDULE

- A. Participate in joint review and evaluation of schedule with Architect at each submittal.
- B. Evaluate project status to determine work behind schedule and work ahead of schedule.
- C. After review, revise as necessary as result of review, and resubmit within 10 days.

3.05 UPDATING SCHEDULE

- A. Maintain schedules to record actual start and finish dates of completed activities.
- B. Indicate progress of each activity to date of revision, with projected completion date of each activity.
- C. Annotate diagrams to graphically depict current status of Work.

- D. Identify activities modified since previous submittal, major changes in Work, and other identifiable changes.
- E. Indicate changes required to maintain Date of Substantial Completion.
- F. Submit reports required to support recommended changes.

3.06 DISTRIBUTION OF SCHEDULE

- A. Distribute copies of updated schedules to Contractor's project site file, to subcontractors, suppliers, Architect, Owner, and other concerned parties.
- B. Instruct recipients to promptly report, in writing, problems anticipated by projections indicated in schedules.

SECTION 01 4000 - QUALITY REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Submittals.
- B. References and standards.
- C. Control of installation.
- D. Tolerances.
- E. Manufacturers' field services.
- F. Defect Assessment.

1.02 RELATED REQUIREMENTS

- A. Section 01 3000 Administrative Requirements: Submittal procedures.
- B. Section 01 4533 Code-Required Special Inspections and Procedures.
- C. Section 01 6000 Product Requirements: Requirements for material and product quality.

1.03 SUBMITTALS

- A. See Section 01 3000 Administrative Requirements, for submittal procedures.
- B. Design Data: Submit for Architect's knowledge as contract administrator for the limited purpose of assessing compliance with information given and the design concept expressed in the Contract Documents, or for Owner's information.
- C. Manufacturer's Instructions: When specified in individual specification sections, submit printed instructions for delivery, storage, assembly, installation, start-up, adjusting, and finishing, for the Owner's information. Indicate special procedures, perimeter conditions requiring special attention, and special environmental criteria required for application or installation.
- D. Erection Drawings: Submit drawings for Architect's benefit as contract administrator or for Owner.
 - 1. Submit for information for the limited purpose of assessing compliance with information given and the design concept expressed in the Contract Documents.

1.04 REFERENCES AND STANDARDS

- A. For products and workmanship specified by reference to a document or documents not included in the Project Manual, also referred to as reference standards, comply with requirements of the standard, except when more rigid requirements are specified or are required by applicable codes.
- B. Comply with reference standard of date of issue current on date of Contract Documents, except where a specific date is established by applicable code.
- C. Obtain copies of standards where required by product specification sections.
- D. Maintain copy at project site during submittals, planning, and progress of the specific work, until Substantial Completion.
- E. Should specified reference standards conflict with Contract Documents, request clarification from Architect before proceeding.
- F. Neither the contractual relationships, duties, or responsibilities of the parties in Contract nor those of Architect shall be altered from Contract Documents by mention or inference otherwise in any reference document.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 CONTROL OF INSTALLATION

- A. Monitor quality control over suppliers, manufacturers, products, services, site conditions, and workmanship, to produce work of specified quality.
- B. Comply with manufacturers' instructions, including each step in sequence.
- C. Should manufacturers' instructions conflict with Contract Documents, request clarification from Architect before proceeding.
- D. Comply with specified standards as minimum quality for the work except where more stringent tolerances, codes, or specified requirements indicate higher standards or more precise workmanship.
- E. Have work performed by persons qualified to produce required and specified quality.
- F. Verify that field measurements are as indicated on shop drawings or as instructed by the manufacturer.
- G. Secure products in place with positive anchorage devices designed and sized to withstand stresses, vibration, physical distortion, and disfigurement.

3.02 TOLERANCES

- A. Monitor fabrication and installation tolerance control of products to produce acceptable Work. Do not permit tolerances to accumulate.
- B. Comply with manufacturers' tolerances. Should manufacturers' tolerances conflict with Contract Documents, request clarification from Architect before proceeding.
- C. Adjust products to appropriate dimensions; position before securing products in place.

3.03 DEFECT ASSESSMENT

- A. Replace Work or portions of the Work not complying with specified requirements.
- B. If, in the opinion of Architect, it is not practical to remove and replace the work, Architect will direct an appropriate remedy or adjust payment.

SECTION 01 5000 - TEMPORARY FACILITIES AND CONTROLS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Temporary Controls: Barriers, enclosures, and fencing.
- B. Waste removal facilities and services.

1.02 RELATED REQUIREMENTS

A. Section 01 5813 - Temporary Project Signage.

1.03 REFERENCE STANDARDS

- A. ASTM E84 Standard Test Method for Surface Burning Characteristics of Building Materials 2018.
- ASTM E90 Standard Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions and Elements 2009 (Reapproved 2016).

1.04 QUALITY ASSURANCE

- A. Regulations: All contractors, sub-contractors, and suppliers shall comply with industry standards and applicable laws and regulations of authorities having jurisdiction including, but not limited to:
 - 1. Building code requirements.
 - 2. Health and safety regulations.
 - 3. Utility company regulations.
 - 4. Police Department, Fire Department, and Rescue Squad rules.
 - 5. Environmental protection regulations.
 - a. Environmental Protection: Provide protection, operate temporary facilities, and conduct construction in ways and by methods that comply with environmental regulations, and minimize the possibility that air might be contaminated or polluted, or that other undesirable effects might result. Avoid use of tools and equipment which produce harmful noise. Restrict use of noise making tools and equipment to hours that will minimize complaints from persons or visitor.
- B. Standards: All contractors, sub-contractors, and visitors shall comply with NFPA Code 241, "Building Construction and Demolition Operations," ANSI-A10 Series standards for "Safety Requirements for Construction and Demolition," and NECA Electrical Design Library "Temporary Electrical Facilities."
- C. All contractors, sub-contractors, and suppliers shall provide new materials; if acceptable to the Architect, undamaged previously used materials in serviceable condition may be used. Provide materials suitable for the use intended.
- D. Lumber and Plywood: Comply with requirements in Section 06 1000 Rough Carpentry.
- E. Maintenance: Maintain facilities in good operating condition until removal.
- F. Protect ducts, diffusers, vents, sprinkler heads and other mechanical devices/systems from dust generated from construction.

1.05 TELECOMMUNICATIONS SERVICES

A. Each Contractor is responsible for their own cellular phone service.

1.06 BARRIERS

A. Provide barriers to prevent unauthorized entry to construction areas, to prevent access to areas that could be hazardous to workers or the public, to allow for owner's use of site and to protect existing

facilities and adjacent properties from damage from construction operations and demolition.

- B. Barricades: Comply with standards and code requirements for erection of structurally adequate barricades. Paint with appropriate colors, graphics, and warning signs to inform personnel and the public, of the hazard being protected against.
- C. Protect non-owned vehicular traffic, stored materials, site, and structures from damage.

1.07 INTERIOR ENCLOSURES

- A. Provide temporary partitions and ceilings as indicated to separate work areas from Owner-occupied areas, to prevent penetration of dust and moisture into Owner-occupied areas, and to prevent damage to existing materials and equipment.
- B. Construction: Framing and reinforced polyethylene sheet materials with closed joints and sealed edges at intersections with existing surfaces:
 - 1. Insulated to R 12 (RSI 2.1).
 - 2. STC rating of 35 in accordance with ASTM E90.
 - 3. Maximum flame spread rating of 25 in accordance with ASTM E84.
 - 4. Interior protection barriers and walls shall be constructed using 5/8" type X gypsum board each side of 3-5/8 inch minimum thickness metal stud framing.
 - 5. Doors between construction and occupied spaces shall be self closing, and self latching.

1.08 SECURITY AND SAFETY

- A. Provide security and facilities to protect Work, existing facilities, and Owner's operations from unauthorized entry, vandalism, or theft.
- B. Coordinate with Owner's security program.
- C. First Aid Supplies: Comply with regulation of authorities having jurisdiction.
- D. Temporary Fire Protection
 - 1. Fire Extinguishers: Provide hand-carried, portable, UL-rated, class A fire extinguishers for temporary offices and similar spaces. In other locations, provide hand-carried, portable, class ABC dry chemical extinguishers, or a combination of extinguishers of NFPA recommended types for the exposures.
 - 2. Comply with NFPA 10 and 241 for classification, extinguishing agent, and size required by location and class of fire exposure.
 - 3. Until fire protection needs are supplied by permanent facilities, install and maintain temporary fire protection facilities of the types needed to protect against reasonably predictable and controllable fire losses. Comply with NFPA 10 "Standard for Portable Fire Extinguishers," and NFPA 241 "Standard for Safeguarding Construction, Alterations, and Demolition Operations."
 - 4. Locate fire extinguishers where convenient and effective for their intended purpose, but not less than one extinguisher on each floor at or near each usable stairwell.
- E. Store combustible materials in containers in fire-safe locations. Remove from construction site daily.
- F. Maintain unobstructed access to fire extinguishers, fire hydrants, temporary fire protection facilities, stairways and other access routes for fighting fires. Prohibit smoking in hazardous fire exposure areas.
- G. Provide continuous supervision of welding operations, combustion type temporary heating units, and similar sources of fire ignition.
- H. Except for use of permanent fire protection as soon as available, do not change over from use of temporary security and protection facilities to permanent facilities until Substantial Completion, or longer as requested by the Architect.

I. Until permanent stairs are available, provide temporary stairs where ladders are not adequate. Cover finished permanent stairs with a protective covering of plywood or similar materials so finishes will be undamaged at the time of acceptance.

1.09 VEHICULAR ACCESS AND PARKING

- A. Comply with regulations relating to use of streets and sidewalks, access to emergency facilities, and access for emergency vehicles.
- B. Coordinate temporary parking areas to accommodate construction personnel with Owner. When site space is not adequate, provide additional off-site parking.

1.10 WASTE REMOVAL

- A. See Section 01 7419 Construction Waste Management and Disposal, for additional requirements.
- B. Provide waste removal facilities and services as required to maintain the site in clean and orderly condition.
- C. Provide containers with lids. Remove trash from site periodically.
- D. If materials to be recycled or re-used on the project must be stored on-site, provide suitable noncombustible containers; locate containers holding flammable material outside the structure unless otherwise approved by the authorities having jurisdiction.
- E. Collection and Disposal of Waste: Collect waste from construction areas and elsewhere daily. Comply with requirements of NFPA 241 for removal of combustible waste material and debris. Enforce requirements strictly. Do not hold materials more than 7 days during normal weather or 3 days when the temperature is expected to rise above 80 deg F (27 deg C). Handle hazardous, dangerous, or unsanitary waste materials separately from other waste.

1.11 REMOVAL OF UTILITIES, FACILITIES, AND CONTROLS

- A. Remove temporary utilities, equipment, facilities, materials, prior to Date of Substantial Completion inspection.
- B. Clean and repair damage caused by installation or use of temporary work.
- C. Termination and Removal: Unless the Architect requests it be maintained longer, remove each temporary facility when the need has ended, or when replaced by authorized use of a permanent facility, but no later than Substantial Completion. Complete, or if necessary restore, permanent construction that may have been delayed because of interference with the temporary facility. Repair damaged Work, clean exposed surfaces and replace Work which cannot be satisfactorily repaired.
- D. Materials and facilities that constitute temporary facilities are property of each prime Contractor.
- E. At Substantial Completion, clean and renovate permanent facilities that have been used during the construction period, including but not limited to:
 - 1. Replace air filters and clean inside of ductworks and housings.
 - 2. Replace significantly worn parts and parts that have been subject to unusual operating conditions.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION - NOT USED

SECTION 01 6000 - PRODUCT REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. General product requirements.
- B. Re-use of existing products.
- C. Transportation, handling, storage and protection.
- D. Product option requirements.
- E. Substitution limitations.
- F. Procedures for Owner-supplied products.
- G. Maintenance materials, including extra materials, spare parts, tools, and software.

1.02 RELATED REQUIREMENTS

- A. Section 00 2600 Procurement Substitution Requirements: Requests for substitution during the proposal process.
- B. Section 01 2500 Substitution Procedures: Substitutions made during procurement and/or construction phases.
- C. Section 01 4000 Quality Requirements: Product quality monitoring.
- D. Section 01 6116 Volatile Organic Compound (VOC) Content Restrictions: Requirements for VOC-restricted product categories.
- E. Section 01 7419 Construction Waste Management and Disposal: Waste disposal requirements potentially affecting product selection, packaging and substitutions.

1.03 DEFINITIONS

- A. Definitions used in this Article are not intended to change the meaning of other terms used in the Contract Documents, such as "specialties," "systems," "structure," "finishes," "accessories," and similar terms. Such terms are self-explanatory and have well recognized meanings in the construction industry.
 - "Products" are items purchased for incorporation in the Work, whether purchased for the Project or taken from previously purchased stock. The term "product" includes the terms "material," " equipment," "system," and terms of similar intent.
 - 2. "Named Products" are items identified by manufacturer's product name, including make or model designation, indicated in the manufacturer's published product literature, that is current as of the date of the Contract Documents.
 - 3. "Materials" are products that are substantially shaped, cut, worked, mixed, finished, refined, or otherwise fabricated, processed, or installed to form a part of the Work.
 - 4. "Equipment" is a product with operational parts, whether motorized or manually operated, that requires service connections such as wiring or piping.

1.04 REFERENCE STANDARDS

- A. EN 15804 Sustainability of construction works Environmental product declarations Core rules for the product category of construction products 2013.
- B. ISO 14025 Environmental labels and declarations -- Type III environmental declarations -- Principles and procedures 2006.
- C. ISO 14040 Environmental management -- Life cycle assessment -- Principles and framework 2006.
- D. ISO 14044 Environmental management -- Life cycle assessment -- Requirements and guidelines 2006.

E. ISO 21930 - Sustainability in buildings and civil engineering works -- Core rules for environmental product declarations of construction products and services 2017.

1.05 SUBMITTALS

- A. Proposed Products List: Submit list of major products proposed for use, with name of manufacturer, trade name, and model number of each product.
 - 1. Submit within 30 days after date of Agreement.
 - 2. For products specified only by reference standards, list applicable reference standards.
- B. Product Data Submittals: Submit manufacturer's standard published data. Mark each copy to identify applicable products, models, options, and other data. Supplement manufacturers' standard data to provide information specific to this Project.
- C. Shop Drawing Submittals: Prepared specifically for this Project; indicate utility and electrical characteristics, utility connection requirements, and location of utility outlets for service for functional equipment and appliances.
- D. Sample Submittals: Illustrate functional and aesthetic characteristics of the product, with integral parts and attachment devices. Coordinate sample submittals for interfacing work.
 - 1. For selection from standard finishes, submit samples of the full range of the manufacturer's standard colors, textures, and patterns.
- E. Sustainable Design Submittals: Items necessary to document use of sustainable construction materials, products, and practices.

1.06 QUALITY ASSURANCE

- A. Source Limitations: To the fullest extent possible, provide products of the same kind, from a single source.
- B. Compatibility of Options: When the Contractor is given the option of selecting between two or more products for use on the Project, the product selected shall be compatible with products previously selected, even if previously selected products were also options.
 - 1. Each prime Contractor is responsible for providing products and construction methods that are compatible with products and construction methods of other prime or separate Contractors.
 - 2. If a dispute arises between prime Contractors over concurrently selectable, but incompatible products, the Architect will determine which products shall be retained and which are incompatible and must be replaced.
- C. Nameplates: Except for required labels and operating data, do not attach or imprint manufacturer's or producer's nameplates or trademarks on exposed surfaces of products which will be exposed to view in occupied spaces or on the exterior.
- D. Labels: Locate required product labels and stamps on a concealed surface or, where required for observation after installation, on an accessible surface that is not conspicuous.
- E. Equipment Nameplates: Provide a permanent nameplate on each item of service-connected or poweroperated equipment. Locate on an easily accessible surface which is inconspicuous in occupied spaces. The nameplate shall contain the following information and other essential operating data:
 - 1. Name of product and manufacturer.
 - 2. Model and serial number.
 - 3. Capacity.
 - 4. Speed.
 - 5. Ratings.

- F. Environmental Product Declaration (EPD): Publicly available, critically reviewed life cycle analysis having at least a cradle-to-gate scope.
 - 1. Good: Product-specific; compliant with ISO 14044.
 - 2. Better: Industry-wide, generic; compliant with ISO 21930, or with ISO 14044, ISO 14040, ISO 14025, and EN 15804; Type III third-party certification with external verification, in which the manufacturer is recognized as the program operator.
 - 3. Best: Commercial-product-specific; compliant with ISO 21930, or with ISO 14044, ISO 14040, ISO 14025, and EN 15804; Type III third-party certification with external verification, in which the manufacturer is recognized as the program operator.
 - 4. Where demonstration of impact reduction below industry average is required, submit both industry-wide and commercial-product-specific declarations; or submit at least 5 declarations for products of the same type by other manufacturers in the same industry.
- G. Health Product Declarations (HPD): Complete, published declaration with full disclosure of known hazards, prepared using one of the HPDC (HPD-OLT) online tools.
- H. Sustainably Harvested Wood: Solid wood, wood chips, and wood fiber sourced and labeled by an organization accredited by one of the following:
 - 1. Wood sourced from a sustainable harvested location. Submit any documentation available.
 - 2. Chain of Custody documents are not required.

PART 2 PRODUCTS

2.01 PRODUCT SELECTION

- A. General Product Requirements: Provide products that comply with the Contract Documents, that are undamaged and, unless otherwise indicated, unused at the time of installation.
 - 1. Provide products complete with all accessories, trim, finish, safety guards, and other devices and details needed for a complete installation and for the intended use and effect.
 - 2. Standard Products: Where available, provide standard products of types that have been produced and used successfully in similar situations on other projects.
- B. Product Selection Procedures: Product selection is governed by the Contract Documents and governing regulations, not by previous Project experience. Procedures governing product selection include the following:
 - 1. Proprietary Specification Requirements: Where only a single product or manufacturer is named, provide the product indicated. No substitutions will be permitted.
 - 2. Semi proprietary Specification Requirements: Where two or more products or manufacturers are named, provide one of the products indicated. No substitutions will be permitted.
 - a. Where products or manufacturers are specified by name, accompanied by the term "or equal," or "or approved equal" comply with the Contract Documents provisions concerning "substitutions" to obtain approval for use of an unnamed product.
 - 3. Descriptive Specification Requirements: Where specifications describe a product or assembly, listing exact characteristics required, with or without use of a brand or trade name, provide a product or assembly that provides the characteristics and otherwise complies with Contract requirements.
 - 4. Performance Specification Requirements: Where Specifications require compliance with performance requirements, provide products that comply with these requirements, and are recommended by the manufacturer for the application indicated. General overall performance of a product is implied where the product is specified for a specific application.

- a. Manufacturer's recommendations may be contained in published product literature, or by the manufacturer's certification of performance.
- 5. Compliance with Standards, Codes, and Regulations: Where the Specifications only require compliance with an imposed code, standard, or regulation select a product that complies with the standards, codes, or regulations specified.
- 6. Visual Matching: Where Specifications require matching an established Sample, the Architect's decision will be final on whether a proposed product matches satisfactorily.
- 7. Visual Selection: Where specified product requirements include the phrase "...as selected from manufacturer's standard colors, patterns, textures..." or a similar phrase, select a product and manufacturer that complies with other specified requirements. The Architect will select the color, pattern, and texture from the product line selected.

2.02 EXISTING PRODUCTS

- A. Do not use materials and equipment removed from existing premises unless specifically required or permitted by Contract Documents.
- B. Unforeseen historic items encountered remain the property of the Owner; notify Owner promptly upon discovery; protect, remove, handle, and store as directed by Owner.
- C. Existing materials and equipment indicated to be removed, but not to be re-used, relocated, reinstalled, delivered to the Owner, or otherwise indicated as to remain the property of the Owner, become the property of the Contractor; remove from site.

2.03 NEW PRODUCTS

- A. Provide new products unless specifically required or permitted by Contract Documents.
- B. Use of products having any of the following characteristics is not permitted:
 - 1. Made using or containing CFC's or HCFC's.
 - 2. Made of wood from newly cut old growth timber.
 - 3. Containing lead, cadmium, or asbestos.
- C. Where other criteria are met, Contractor shall give preference to products that:
 - 1. If used on interior, have lower emissions, as defined in Section 01 6116.
 - 2. If wet-applied, have lower VOC content, as defined in Section 01 6116.
 - 3. Are extracted, harvested, and/or manufactured closer to the location of the project.
 - 4. Have longer documented life span under normal use.
 - 5. Result in less construction waste. See Section 01 7419
 - 6. Are made of vegetable materials that are rapidly renewable.
 - 7. Are made of recycled materials.
 - 8. If made of wood, are made of sustainably harvested wood, wood chips, or wood fiber.
 - 9. Have a published Environmental Product Declaration (EPD).
 - 10. Have a published Health Product Declaration (HPD).
 - 11. Are Living Building Challenge Red List Free.
 - 12. Have a published Declare Label.

2.04 PRODUCT OPTIONS

- A. Products Specified by Reference Standards or by Description Only: Use any product meeting those standards or description.
- B. Products Specified by Naming One or More Manufacturers: Use a product of one of the manufacturers named and meeting specifications, no options or substitutions allowed.

C. Products Specified by Naming One or More Manufacturers with a Provision for Substitutions: Submit a request for substitution for any manufacturer not named.

2.05 MAINTENANCE MATERIALS

- A. Furnish extra materials, spare parts, tools, and software of types and in quantities specified in individual specification sections.
- B. Deliver to Project site; obtain receipt prior to final payment.

PART 3 EXECUTION

3.01 SUBSTITUTION LIMITATIONS

A. See Section 01 2500 - Substitution Procedures.

3.02 OWNER-SUPPLIED PRODUCTS

- A. Owner's Responsibilities:
 - 1. Arrange for and deliver Owner reviewed shop drawings, product data, and samples, to Contractor.
 - 2. Arrange and pay for product delivery to site.
 - 3. On delivery, inspect products jointly with Contractor.
 - 4. Submit claims for transportation damage and replace damaged, defective, or deficient items.
 - 5. Arrange for manufacturers' warranties, inspections, and service.
- B. Contractor's Responsibilities:
 - 1. Review Owner reviewed shop drawings, product data, and samples.
 - 2. Receive and unload products at site; inspect for completeness or damage jointly with Owner.
 - 3. Handle, store, install and finish products.
 - 4. Repair or replace items damaged after receipt.

3.03 TRANSPORTATION AND HANDLING

- A. Package products for shipment in manner to prevent damage; for equipment, package to avoid loss of factory calibration.
- B. If special precautions are required, attach instructions prominently and legibly on outside of packaging.
- C. Coordinate schedule of product delivery to designated prepared areas in order to minimize site storage time and potential damage to stored materials.
- D. Transport and handle products in accordance with manufacturer's instructions.
- E. Transport materials in covered trucks to prevent contamination of product and littering of surrounding areas.
- F. Promptly inspect shipments to ensure that products comply with requirements, quantities are correct, and products are undamaged.
- G. Provide equipment and personnel to handle products by methods to prevent soiling, disfigurement, or damage, and to minimize handling.
- H. Arrange for the return of packing materials, such as wood pallets, where economically feasible.

3.04 STORAGE AND PROTECTION

- A. Designate receiving/storage areas for incoming products so that they are delivered according to installation schedule and placed convenient to work area in order to minimize waste due to excessive materials handling and misapplication. See Section 01 7419.
- B. Store and protect products in accordance with manufacturers' instructions.
- C. Store with seals and labels intact and legible.

- D. Store sensitive products in weathertight, climate-controlled enclosures in an environment favorable to product.
- E. For exterior storage of fabricated products, place on sloped supports above ground.
- F. Provide bonded off-site storage and protection when site does not permit on-site storage or protection.
- G. Protect products from damage or deterioration due to construction operations, weather, precipitation, humidity, temperature, sunlight and ultraviolet light, dirt, dust, and other contaminants.
- H. Comply with manufacturer's warranty conditions, if any.
- I. Do not store products directly on the ground.
- J. Cover products subject to deterioration with impervious sheet covering. Provide ventilation to prevent condensation and degradation of products.
- K. Prevent contact with material that may cause corrosion, discoloration, or staining.
- L. Provide equipment and personnel to store products by methods to prevent soiling, disfigurement, or damage.
- M. Arrange storage of products to permit access for inspection. Periodically inspect to verify products are undamaged and are maintained in acceptable condition.

3.05 INSTALLATION OF PRODUCTS

- A. Comply with manufacturer's instructions and recommendations for installation of products in the applications indicated. Anchor each product securely in place, accurately located and aligned with other Work.
- B. Clean exposed surfaces and protect as necessary to ensure freedom from damage and deterioration at time of Substantial Completion.

SECTION 01 6116 - VOLATILE ORGANIC COMPOUND (VOC) CONTENT

RESTRICTIONS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Requirements for Indoor-Emissions-Restricted products.
- B. Requirements for VOC-Content-Restricted products.

1.02 RELATED REQUIREMENTS

- A. Section 01 3000 Administrative Requirements: Submittal procedures.
- B. Section 01 4000 Quality Requirements: Procedures for testing and certifications.
- C. Section 01 6000 Product Requirements: Fundamental product requirements, substitutions and product options, delivery, storage, and handling.

1.03 DEFINITIONS

- A. Indoor-Emissions-Restricted Products: All products in the following product categories, whether specified or not:
 - 1. Interior paints and coatings applied on site.
 - 2. Interior adhesives and sealants applied on site, including flooring adhesives.
 - 3. Flooring.
 - 4. Composite wood.
 - 5. Products making up wall and ceiling assemblies.
 - 6. Other products when specifically stated in the specifications.
- B. VOC-Content-Restricted Products: All products in the following product categories, whether specified or not:
 - 1. Interior paints and coatings applied on site.
 - 2. Interior adhesives and sealants applied on site, including flooring adhesives.
 - 3. Wet-applied roofing and waterproofing.
 - 4. Other products when specifically stated in the specifications.
- C. Interior of Building: Anywhere inside the exterior weather barrier.
- D. Adhesives: All gunnable, trowelable, liquid-applied, and aerosol adhesives, whether specified or not; including flooring adhesives, resilient base adhesives, and pipe jointing adhesives.
- E. Sealants: All gunnable, trowelable, and liquid-applied joint sealants and sealant primers, whether specified or not; including firestopping sealants and duct joint sealers.
- F. Inherently Non-Emitting Materials: Products composed wholly of minerals or metals, unless they include organic-based surface coatings, binders, or sealants; and specifically the following:
 - 1. Concrete.
 - 2. Clay brick.
 - 3. Metals that are plated, anodized, or powder-coated.
 - 4. Glass.
 - 5. Ceramics.
 - 6. Solid wood flooring that is unfinished and untreated.

1.04 REFERENCE STANDARDS

- A. 40 CFR 59, Subpart D National Volatile Organic Compound Emission Standards for Architectural Coatings; U.S. Environmental Protection Agency current edition.
- B. ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings 2005 (Reapproved 2018).
- C. CAL (CDPH SM) Standard Method for the Testing and Evaluation of Volatile Organic Chemical Emissions from Indoor Sources Using Environmental Chambers Version 1.2 2017.
- D. CARB (ATCM) Airborne Toxic Control Measure to Reduce Formaldehyde Emissions from Composite Wood Products; California Air Resources Board current edition.
- E. CARB (SCM) Suggested Control Measure for Architectural Coatings; California Air Resources Board 2020.
- F. CHPS (HPPD) High Performance Products Database Current Edition.
- G. CRI (GLP) Green Label Plus Testing Program Certified Products Current Edition.
- H. SCAQMD 1113 Architectural Coatings 1977, with Amendment (2016).
- I. SCAQMD 1168 Adhesive and Sealant Applications 1989, with Amendment (2022).
- J. SCS (CPD) SCS Certified Products Current Edition.
- K. UL (GGG) GREENGUARD Gold Certified Products Current Edition.

1.05 SUBMITTALS

- A. See Section 01 3000 Administrative Requirements for submittal procedures.
- B. Product Data: For each VOC-restricted product used in the project, submit evidence of compliance.

1.06 QUALITY ASSURANCE

- A. Indoor Emissions Standard and Test Method: CAL (CDPH SM), using Standard Private Office exposure scenario and the allowable concentrations specified in the method, and range of total VOC's after 14 days.
 - 1. Wet-Applied Products: State amount applied in mass per surface area.
 - 2. Paints and Coatings: Test tinted products, not just tinting bases.
 - 3. Evidence of Compliance: Acceptable types of evidence are the following;
 - a. Current UL (GGG) certification.
 - b. Current SCS (CPD) Floorscore certification.
 - c. Current SCS (CPD) Indoor Advantage Gold certification.
 - d. Current listing in CHPS (HPPD) as a low-emitting product.
 - e. Current CRI (GLP) certification.
 - f. Test report showing compliance and stating exposure scenario used.
 - 4. Product data submittal showing VOC content is NOT acceptable evidence.
 - 5. Manufacturer's certification without test report by independent agency is NOT acceptable evidence.
- B. VOC Content Test Method: 40 CFR 59, Subpart D (EPA Method 24), or ASTM D3960, unless otherwise indicated.
 - 1. Evidence of Compliance: Acceptable types of evidence are:
 - a. Report of laboratory testing performed in accordance with requirements.
 - b. Published product data showing compliance with requirements.
- C. Composite Wood Emissions Standard: CARB (ATCM) for ultra-low emitting formaldehyde (ULEF) resins.
 - 1. Evidence of Compliance: Acceptable types of evidence are:

- a. Current SCS "No Added Formaldehyde (NAF)" certification; www.scscertified.com.
- b. Report of laboratory testing performed in accordance with requirements.
- c. Published product data showing compliance with requirements.
- D. Testing Agency Qualifications: Independent firm specializing in performing testing and inspections of the type specified in this section.

PART 2 PRODUCTS

2.01 MATERIALS

- A. All Products: Comply with the most stringent of federal, State, and local requirements, or these specifications.
- B. Indoor-Emissions-Restricted Products: Comply with Indoor Emissions Standard and Test Method, except for:
 - 1. Composite Wood, Wood Fiber, and Wood Chip Products: Comply with Composite Wood Emissions Standard or contain no added formaldehyde resins.
 - 2. Inherently Non-Emitting Materials.
- C. VOC-Content-Restricted Products: VOC content not greater than required by the following:
 - 1. Adhesives, Including Flooring Adhesives: SCAQMD 1168 Rule.
 - 2. Joint Sealants: SCAQMD 1168 Rule.
 - 3. Paints and Coatings: Each color; most stringent of the following:
 - a. 40 CFR 59, Subpart D.
 - b. SCAQMD 1113 Rule.
 - c. CARB (SCM).
 - 4. Wet-Applied Roofing and Waterproofing: Comply with requirements for paints and coatings.

PART 3 EXECUTION

3.01 FIELD QUALITY CONTROL

- A. Owner reserves the right to reject non-compliant products, whether installed or not, and require their removal and replacement with compliant products at no extra cost to Owner.
- B. Additional costs to restore indoor air quality due to installation of non-compliant products will be borne by Contractor.

SECTION 01 7000 - EXECUTION AND CLOSEOUT REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Examination, preparation, and general installation procedures.
- B. Requirements for alterations work, including selective demolition, except removal, disposal, and/or remediation of hazardous materials and toxic substances.
- C. Cutting and patching.
- D. Cleaning and protection.
- E. Demonstration and instruction of Owner personnel.
- F. Closeout procedures, including Contractor's Correction Punch List, except payment procedures.
- G. General requirements for maintenance service.

1.02 RELATED REQUIREMENTS

- A. Section 01 1000 Summary: Limitations on working in existing building; continued occupancy; work sequence; identification of salvaged and relocated materials.
- B. Section 01 3000 Administrative Requirements: Submittals procedures.
- C. Section 01 4000 Quality Requirements: Testing and inspection procedures.
- D. Section 01 5000 Temporary Facilities and Controls: Temporary exterior enclosures.
- E. Section 01 5000 Temporary Facilities and Controls: Temporary interior partitions.
- F. Section 01 7800 Closeout Submittals: Project record documents, operation and maintenance data, warranties, and bonds.

1.03 REFERENCE STANDARDS

A. NFPA 241 - Standard for Safeguarding Construction, Alteration, and Demolition Operations 2022, with Errata (2021).

1.04 SUBMITTALS

- A. See Section 01 3000 Administrative Requirements, for submittal procedures.
- B. Cutting and Patching: Submit written request in advance of cutting or alteration that affects:
 - 1. Structural integrity of any element of Project.
 - 2. Integrity of weather exposed or moisture resistant element.
 - 3. Efficiency, maintenance, or safety of any operational element.
 - 4. Visual qualities of sight exposed elements.
 - 5. Work of Owner or separate Contractor.
- C. Project Record Documents: Accurately record actual locations of capped and active utilities.

1.05 PROJECT CONDITIONS

A. Ventilate enclosed areas to assist cure of materials, to dissipate humidity, and to prevent accumulation of dust, fumes, vapors, or gases.

1.06 COORDINATION

- A. See Section 01 1000 for occupancy-related requirements.
- B. Coordinate scheduling, submittals, and work of the various sections of the Project Manual to ensure efficient and orderly sequence of installation of interdependent construction elements, with provisions for accommodating items installed later.

- C. Verify that utility requirements and characteristics of new operating equipment are compatible with building utilities. Coordinate work of various sections having interdependent responsibilities for installing, connecting to, and placing in service, such equipment.
- D. Coordinate space requirements, supports, and installation of mechanical and electrical work that are indicated diagrammatically on drawings. Follow routing indicated for pipes, ducts, and conduit, as closely as practicable; place runs parallel with lines of building. Utilize spaces efficiently to maximize accessibility for other installations, for maintenance, and for repairs.
- E. In finished areas except as otherwise indicated, conceal pipes, ducts, and wiring within the construction. Coordinate locations of fixtures and outlets with finish elements.
- F. Coordinate completion and clean-up of work of separate sections.
- G. After Owner occupancy of premises, coordinate access to site for correction of defective work and work not in accordance with Contract Documents, to minimize disruption of Owner's activities.

PART 2 PRODUCTS

2.01 PATCHING MATERIALS

- A. New Materials: As specified in product sections; match existing products and work for patching and extending work.
- B. Type and Quality of Existing Products: Determine by inspecting and testing products where necessary, referring to existing work as a standard.
- C. Product Substitution: For any proposed change in materials, submit request for substitution described in Section 01 6000 Product Requirements.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that existing site conditions and substrate surfaces are acceptable for subsequent work. Start of work means acceptance of existing conditions.
- B. Verify that existing substrate is capable of structural support or attachment of new work being applied or attached.
- C. Examine and verify specific conditions described in individual specification sections.
- D. Take field measurements before confirming product orders or beginning fabrication, to minimize waste due to over-ordering or misfabrication.
- E. Verify that utility services are available, of the correct characteristics, and in the correct locations.
- F. Prior to Cutting: Examine existing conditions prior to commencing work, including elements subject to damage or movement during cutting and patching. After uncovering existing work, assess conditions affecting performance of work. Beginning of cutting or patching means acceptance of existing conditions.

3.02 PREPARATION

- A. Clean substrate surfaces prior to applying next material or substance.
- B. Seal cracks or openings of substrate prior to applying next material or substance.
- C. Apply manufacturer required or recommended substrate primer, sealer, or conditioner prior to applying any new material or substance in contact or bond.

3.03 LAYING OUT THE WORK

A. Promptly notify Architect of any discrepancies discovered.

3.04 GENERAL INSTALLATION REQUIREMENTS

- A. Install products as specified in individual sections, in accordance with manufacturer's instructions and recommendations, and so as to avoid waste due to necessity for replacement.
- B. Make vertical elements plumb and horizontal elements level, unless otherwise indicated.
- C. Install equipment and fittings plumb and level, neatly aligned with adjacent vertical and horizontal lines, unless otherwise indicated.
- D. Make consistent texture on surfaces, with seamless transitions, unless otherwise indicated.
- E. Make neat transitions between different surfaces, maintaining texture and appearance.

3.05 ALTERATIONS

- A. Drawings showing existing construction and utilities are based on casual field observation and existing record documents only.
 - 1. Verify that construction and utility arrangements are as indicated.
 - 2. Report discrepancies to Architect before disturbing existing installation.
 - 3. Beginning of alterations work constitutes acceptance of existing conditions.
- B. Keep areas in which alterations are being conducted separated from other areas that are still occupied.
 - 1. Provide, erect, and maintain temporary dustproof partitions of construction indicated on drawings .
- C. Remove existing work as indicated and as required to accomplish new work.
 - 1. Remove items indicated on drawings.
 - 2. Where new surface finishes are to be applied to existing work, perform removals, patch, and prepare existing surfaces as required to receive new finish; remove existing finish if necessary for successful application of new finish.
 - 3. Where new surface finishes are not specified or indicated, patch holes and damaged surfaces to match adjacent finished surfaces as closely as possible.
- D. Services (Including but not limited to HVAC, Plumbing, Electrical, and Telecommunications): Remove, relocate, and extend existing systems to accommodate new construction.
 - 1. Maintain existing active systems that are to remain in operation; maintain access to equipment and operational components; if necessary, modify installation to allow access or provide access panel.
 - 2. Where existing active systems serve occupied facilities but are to be replaced with new services, maintain existing systems in service until new systems are complete and ready for service.
 - a. Disable existing systems only to make switchovers and connections; minimize duration of outages.
 - b. See Section 01 1000 for other limitations on outages and required notifications.
 - c. Provide temporary connections as required to maintain existing systems in service.
 - 3. Verify that abandoned services serve only abandoned function.
 - 4. Remove abandoned pipe, ducts, conduits, and equipment , including those above accessible ceilings; remove back to source of supply where possible; patch holes left by removal using materials specified for new construction.
- E. Protect existing work to remain.
 - 1. Perform cutting to accomplish removals neatly and as specified for cutting new work.
 - 2. Repair adjacent construction and finishes damaged during removal work.
- F. Adapt existing work to fit new work: Make as neat and smooth transition as possible.
- 1. When existing finished surfaces are cut so that a smooth transition with new work is not possible, terminate existing surface along a straight line at a natural line of division and make recommendation to Architect.
- 2. Where a change of plane of 1/4 inch (6 mm) or more occurs in existing work, submit recommendation for providing a smooth transition for Architect review and request instructions.
- G. Patching: Where the existing surface is not indicated to be refinished, patch to match the surface finish that existed prior to cutting. Where the surface is indicated to be refinished, patch so that the substrate is ready for the new finish.
- H. Refinish existing surfaces as indicated:
 - 1. Where rooms or spaces are indicated to be refinished, refinish all visible existing surfaces to remain to the specified condition for each material, with a neat transition to adjacent finishes.
 - 2. If mechanical or electrical work is exposed accidentally during the work, re-cover and refinish to match.
- I. Clean existing systems and equipment.
- J. Remove demolition debris and abandoned items from alterations areas and dispose of.
- K. Comply with all other applicable requirements of this section.

3.06 CUTTING AND PATCHING

- A. Whenever possible, execute the work by methods that avoid cutting or patching.
- B. See Alterations article above for additional requirements.
- C. Perform whatever cutting and patching is necessary to:
 - 1. Complete the work.
 - 2. Fit products together to integrate with other work.
 - 3. Provide openings for penetration of mechanical, electrical, and other services.
 - 4. Match work that has been cut to adjacent work.
 - 5. Repair areas adjacent to cuts to required condition.
 - 6. Repair new work damaged by subsequent work.
 - 7. Remove samples of installed work for testing when requested.
 - 8. Remove and replace defective and non-complying work.
- D. Execute work by methods that avoid damage to other work and that will provide appropriate surfaces to receive patching and finishing. In existing work, minimize damage and restore to original condition.
- E. Employ skilled and experienced installer to perform cutting.
- F. Cut rigid materials using masonry saw or core drill. Pneumatic tools not allowed without prior approval.
- G. Restore work with new products in accordance with requirements of Contract Documents.
- H. Patching:
 - 1. Finish patched surfaces to match finish that existed prior to patching. On continuous surfaces, refinish to nearest intersection or natural break. For an assembly, refinish entire unit.
 - 2. Match color, texture, and appearance.
 - 3. Repair patched surfaces that are damaged, lifted, discolored, or showing other imperfections due to patching work. If defects are due to condition of substrate, repair substrate prior to repairing finish.

3.07 PROGRESS CLEANING

A. Maintain areas free of waste materials, debris, and rubbish. Maintain site in a clean and orderly condition.

- B. Remove debris and rubbish from pipe chases, plenums, attics, crawl spaces, and other closed or remote spaces, prior to enclosing the space.
- C. Broom and vacuum clean interior areas prior to start of surface finishing, and continue cleaning to eliminate dust.
- D. Collect and remove waste materials, debris, and trash/rubbish from site periodically and dispose offsite; do not burn or bury.

3.08 DEMONSTRATION AND INSTRUCTION

- A. Demonstrate operation and maintenance of products to Owner's personnel two weeks prior to date of Substantial Completion.
- B. Demonstrate start-up, operation, control, adjustment, trouble-shooting, servicing, maintenance, and shutdown of each item of equipment at scheduled time, at equipment location.
- C. Provide a qualified person who is knowledgeable about the Project to perform demonstration and instruction of Owner's personnel.
- D. Utilize operation and maintenance manuals as basis for instruction. Review contents of manual with Owner's personnel in detail to explain all aspects of operation and maintenance.
- E. Prepare and insert additional data in operations and maintenance manuals when need for additional data becomes apparent during instruction.

3.09 ADJUSTING

A. Adjust operating products and equipment to ensure smooth and unhindered operation.

3.10 FINAL CLEANING

- A. Use cleaning materials that are nonhazardous.
- B. Clean interior and exterior glass, surfaces exposed to view; remove temporary labels, stains and foreign substances, polish transparent and glossy surfaces, vacuum carpeted and soft surfaces.
- C. Remove all labels that are not permanent. Do not paint or otherwise cover fire test labels or nameplates on mechanical and electrical equipment.
- D. Clean equipment and fixtures to a sanitary condition with cleaning materials appropriate to the surface and material being cleaned.
- E. Remove waste, surplus materials, trash/rubbish, and construction facilities from the site; dispose of in legal manner.

3.11 CLOSEOUT PROCEDURES

- A. Make submittals that are required by governing or other authorities.
- B. Accompany Project Coordinator on preliminary inspection to determine items to be listed for completion or correction in the Contractor's Correction Punch List for Contractor's Notice of Substantial Completion.
- C. Notify Architect when work is considered ready for Architect's Substantial Completion inspection.
- D. Submit written certification containing Contractor's Correction Punch List, that Contract Documents have been reviewed, work has been inspected, and that work is complete in accordance with Contract Documents and ready for Architect's Substantial Completion inspection.
- E. Conduct Substantial Completion inspection and create Final Correction Punch List containing Architect's and Contractor's comprehensive list of items identified to be completed or corrected and submit to Architect.
- F. Correct items of work listed in Final Correction Punch List and comply with requirements for access to Owner-occupied areas.

- G. Notify Architect when work is considered finally complete and ready for Architect's Substantial Completion final inspection.
- H. Complete items of work determined by Architect listed in executed Certificate of Substantial Completion.

3.12 MAINTENANCE

- A. Provide service and maintenance of components indicated in specification sections.
- B. Maintenance Period: As indicated in specification sections or, if not indicated, not less than one year from the Date of Substantial Completion or the length of the specified warranty, whichever is longer.
- C. Examine system components at a frequency consistent with reliable operation. Clean, adjust, and lubricate as required.
- D. Include systematic examination, adjustment, and lubrication of components. Repair or replace parts whenever required. Use parts produced by the manufacturer of the original component.
- E. Maintenance service shall not be assigned or transferred to any agent or subcontractor without prior written consent of the Owner.

SECTION 01 7419 - CONSTRUCTION WASTE MANAGEMENT AND DISPOSAL

PART 1 GENERAL

1.01 WASTE MANAGEMENT REQUIREMENTS

- A. Owner requires that this project generate the least amount of trash and waste possible.
- B. Employ processes that ensure the generation of as little waste as possible due to error, poor planning, breakage, mishandling, contamination, or other factors.
- C. Minimize trash/waste disposal in landfills; reuse, salvage, or recycle as much waste as economically feasible.
- D. Required Recycling, Salvage, and Reuse: The following may not be disposed of in landfills or by incineration:
 - 1. Aluminum and plastic beverage containers.
 - 2. Corrugated cardboard.
 - 3. Wood pallets.
 - 4. Clean dimensional wood: May be used as blocking or furring.
 - 5. Metals, including packaging banding, metal studs, sheet metal, structural steel, piping, reinforcing bars, door frames, and other items made of steel, iron, galvanized steel, stainless steel, aluminum, copper, zinc, lead, brass, and bronze.
- E. Contractor Reporting Responsibilities: Submit periodic Waste Disposal Reports; report landfill disposal, incineration, recycling, salvage, and reuse regardless of to whom the cost or savings accrues; use the same units of measure on required reports.
- F. Methods of trash/waste disposal that are not acceptable are:
 - 1. Burning on the project site.
 - 2. Burying on the project site.
 - 3. Dumping or burying on other property, public or private.
 - 4. Other illegal dumping or burying.
- G. Regulatory Requirements: Contractor is responsible for knowing and complying with regulatory requirements, including but not limited to Federal, state and local requirements, pertaining to legal disposal of all construction and demolition waste materials.

1.02 RELATED REQUIREMENTS

1.03 DEFINITIONS

- A. Clean: Untreated and unpainted; not contaminated with oils, solvents, caulk, or the like.
- B. Construction and Demolition Waste: Solid wastes typically including building materials, packaging, trash, debris, and rubble resulting from construction, remodeling, repair and demolition operations.
- C. Hazardous: Exhibiting the characteristics of hazardous substances, i.e., ignitibility, corrosivity, toxicity or reactivity.
- D. Nonhazardous: Exhibiting none of the characteristics of hazardous substances, i.e., ignitibility, corrosivity, toxicity, or reactivity.
- E. Nontoxic: Neither immediately poisonous to humans nor poisonous after a long period of exposure.
- F. Recyclable: The ability of a product or material to be recovered at the end of its life cycle and remanufactured into a new product for reuse by others.

- G. Recycle: To remove a waste material from the project site to another site for remanufacture into a new product for reuse by others.
- H. Recycling: The process of sorting, cleansing, treating and reconstituting solid waste and other discarded materials for the purpose of using the altered form. Recycling does not include burning, incinerating, or thermally destroying waste.
- I. Return: To give back reusable items or unused products to vendors for credit.
- J. Reuse: To reuse a construction waste material in some manner on the project site.
- K. Salvage: To remove a waste material from the project site to another site for resale or reuse by others.
- L. Sediment: Soil and other debris that has been eroded and transported by storm or well production runoff water.
- M. Source Separation: The act of keeping different types of waste materials separate beginning from the first time they become waste.
- N. Toxic: Poisonous to humans either immediately or after a long period of exposure.
- O. Trash: Any product or material unable to be reused, returned, recycled, or salvaged.
- P. Waste: Extra material or material that has reached the end of its useful life in its intended use. Waste includes salvageable, returnable, recyclable, and reusable material.

1.04 SUBMITTALS

A. See Section 01 3000 - Administrative Requirements for submittal procedures.

PART 2 PRODUCTS

2.01 PRODUCT SUBSTITUTIONS

- A. See Section 01 6000 and Section 01 2500.
- B. For each proposed product substitution, submit the following information in addition to requirements specified in Section 01 6000:
 - 1. Relative amount of waste produced, compared to specified product.
 - 2. Cost savings on waste disposal, compared to specified product, to be deducted from the Contract Sum.
 - 3. Proposed disposal method for waste product.
 - 4. Markets for recycled waste product.

PART 3 EXECUTION

3.01 WASTE MANAGEMENT PROCEDURES

- A. See Section 01 3000 for additional requirements for project meetings, reports, submittal procedures, and project documentation.
- B. See Section 01 5000 for additional requirements related to trash/waste collection and removal facilities and services.
- C. See Section 01 6000 for waste prevention requirements related to delivery, storage, and handling.
- D. See Section 01 7000 for trash/waste prevention procedures related to demolition, cutting and patching, installation, protection, and cleaning.

SECTION 01 7800 - CLOSEOUT SUBMITTALS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Project record documents.
- B. Operation and maintenance data.
- C. Warranties and bonds.

1.02 RELATED REQUIREMENTS

- A. Section 01 3000 Administrative Requirements: Submittals procedures, shop drawings, product data, and samples.
- B. Section 01 7000 Execution and Closeout Requirements: Contract closeout procedures.
- C. Individual Product Sections: Specific requirements for operation and maintenance data.
- D. Individual Product Sections: Warranties required for specific products or Work.

1.03 SUBMITTALS

- A. Project Record Documents: Submit documents to Architect with claim for final Application for Payment.
- B. Operation and Maintenance Data:
 - 1. Submit two copies and .pdf format of preliminary draft or proposed formats and outlines of contents before start of Work. Architect will review draft and return one copy and .pdf format with comments.
 - 2. For equipment, or component parts of equipment put into service during construction and operated by Owner, submit completed documents within ten days after acceptance.
 - 3. Submit one copy of completed documents and .pdf format 15 days prior to final inspection. This copy will be reviewed and returned after final inspection, with Architect comments. Revise content of all document sets as required prior to final submission.
 - 4. Submit two sets of revised final documents and .pdf format in final form within 10 days after final inspection.
- C. Warranties:
 - 1. For equipment or component parts of equipment put into service during construction with Owner's permission, submit documents within 10 days after acceptance.
 - 2. Make other submittals within 10 days after Date of Substantial Completion, prior to final Application for Payment.
 - 3. For items of Work for which acceptance is delayed beyond Date of Substantial Completion, submit within 10 days after acceptance, listing the date of acceptance as the beginning of the warranty period.

PART 2 PRODUCTS - NOT USED

PART 3 EXECUTION

3.01 PROJECT RECORD DOCUMENTS

- A. Maintain on site one set of the following record documents; record actual revisions to the Work:
 - 1. Drawings.
 - 2. Specifications.

- 3. Addenda.
- 4. Change Orders and other modifications to the Contract.
- 5. Reviewed shop drawings, product data, and samples.
- 6. Manufacturer's instruction for assembly, installation, and adjusting.
- B. Ensure entries are complete and accurate, enabling future reference by Owner.
- C. Store record documents separate from documents used for construction.
- D. Record information concurrent with construction progress.
- E. Specifications: Legibly mark and record at each product section description of actual products installed, including the following:
 - 1. Manufacturer's name and product model and number.
 - 2. Product substitutions or alternates utilized.
 - 3. Changes made by Addenda and modifications.
- F. Record Drawingsand Shop Drawings: Legibly mark each item to record actual construction including:
 - 1. Measured horizontal and vertical locations of underground utilities and appurtenances, referenced to permanent surface improvements.
 - 2. Measured locations of internal utilities and appurtenances concealed in construction, referenced to visible and accessible features of the Work.
 - 3. Field changes of dimension and detail.
 - 4. Details not on original Contract drawings.

3.02 OPERATION AND MAINTENANCE DATA

- A. Source Data: For each product or system, list names, addresses and telephone numbers of Subcontractors and suppliers, including local source of supplies and replacement parts.
- B. Product Data: Mark each sheet to clearly identify specific products and component parts, and data applicable to installation. Delete inapplicable information.
- C. Drawings: Supplement product data to illustrate relations of component parts of equipment and systems, to show control and flow diagrams. Do not use Project Record Documents as maintenance drawings.
- D. Typed Text: As required to supplement product data. Provide logical sequence of instructions for each procedure, incorporating manufacturer's instructions.

3.03 OPERATION AND MAINTENANCE DATA FOR MATERIALS AND FINISHES

- A. For Each Product, Applied Material, and Finish:
 - 1. Product data, with catalog number, size, composition, and color and texture designations.
 - 2. Information for re-ordering custom manufactured products.
- B. Instructions for Care and Maintenance: Manufacturer's recommendations for cleaning agents and methods, precautions against detrimental cleaning agents and methods, and recommended schedule for cleaning and maintenance.
- C. Moisture protection and weather-exposed products: Include product data listing applicable reference standards, chemical composition, and details of installation. Provide recommendations for inspections, maintenance, and repair.
- D. Additional information as specified in individual product specification sections.
- E. Where additional instructions are required, beyond the manufacturer's standard printed instructions, have instructions prepared by personnel experienced in the operation and maintenance of the specific products.

3.04 OPERATION AND MAINTENANCE DATA FOR EQUIPMENT AND SYSTEMS

- A. For Each Item of Equipment and Each System:
 - 1. Description of unit or system, and component parts.
 - 2. Identify function, normal operating characteristics, and limiting conditions.
 - 3. Include performance curves, with engineering data and tests.
 - 4. Complete nomenclature and model number of replaceable parts.
- B. Where additional instructions are required, beyond the manufacturer's standard printed instructions, have instructions prepared by personnel experienced in the operation and maintenance of the specific products.
- C. Panelboard Circuit Directories: Provide electrical service characteristics, controls, and communications; typed.
- D. Include color coded wiring diagrams as installed.
- E. Operating Procedures: Include start-up, break-in, and routine normal operating instructions and sequences. Include regulation, control, stopping, shut-down, and emergency instructions. Include any special operating instructions.
- F. Maintenance Requirements: Include routine procedures and guide for preventative maintenance and trouble shooting; disassembly, repair, and reassembly instructions; and alignment, adjusting, balancing, and checking instructions.
- G. Provide servicing and lubrication schedule, and list of lubricants required.
- H. Include manufacturer's printed and .pdf format operation and maintenance instructions.
- I. Include sequence of operation by controls manufacturer.
- J. Provide original manufacturer's parts list, illustrations, assembly drawings, and diagrams required for maintenance.
- K. Provide control diagrams by controls manufacturer as installed.
- L. Provide Contractor's coordination drawings, with color coded piping diagrams as installed.
- M. Provide list of original manufacturer's spare parts, current prices, and recommended quantities to be maintained in storage.
- N. Additional Requirements: As specified in individual product specification sections.

3.05 ASSEMBLY OF OPERATION AND MAINTENANCE MANUALS

- A. Assemble operation and maintenance data into durable manuals and electronic copies in .pdf format for Owner's personnel use, with data arranged in the same sequence as, and identified by, the specification sections.
- B. Where systems involve more than one specification section, provide separate tabbed divider for each system.
- C. Binders: Commercial quality, 8-1/2 by 11 inch (216 by 280 mm) three D side ring binders with durable plastic covers; 2 inch (50 mm) maximum ring size. When multiple binders are used, correlate data into related consistent groupings.
- D. Cover: Identify each binder with typed or printed title OPERATION AND MAINTENANCE INSTRUCTIONS; identify title of Project; identify subject matter of contents.
- E. Project Directory: Title and address of Project; names, addresses, and telephone numbers of Architect, Consultants, Contractor and subcontractors, with names of responsible parties.
- F. Tables of Contents: List every item separated by a divider, using the same identification as on the divider tab; where multiple volumes are required, include all volumes Tables of Contents in each

volume, with the current volume clearly identified.

- G. Dividers: Provide tabbed dividers for each separate product and system; identify the contents on the divider tab; immediately following the divider tab include a description of product and major component parts of equipment.
- H. Text: Manufacturer's printed data, or typewritten data on 20 pound paper.
- I. Drawings: Provide with reinforced punched binder tab. Bind in with text; fold larger drawings to size of text pages.
- J. Arrangement of Contents: Organize each volume in parts as follows:
 - 1. Project Directory.
 - 2. Table of Contents, of all volumes, and of this volume.
 - 3. Operation and Maintenance Data: Arranged by system, then by product category.
 - a. Source data.
 - b. Product data, shop drawings, and other submittals.
 - c. Operation and maintenance data.
 - d. Field quality control data.
 - e. Photocopies of warranties and bonds.
 - 4. Design Data: To allow for addition of design data furnished by Architect or others, provide a tab labeled "Design Data" and provide a binder large enough to allow for insertion of at least 20 pages of typed text.

3.06 WARRANTIES AND BONDS

- A. Obtain warranties, executed in duplicate by responsible Subcontractors, suppliers, and manufacturers, within 10 days after completion of the applicable item of work, include electronic copy in .pdf format. Except for items put into use with Owner's permission, leave date of beginning of time of warranty until Date of Substantial completion is determined.
- B. Verify that documents are in proper form, contain full information, and are notarized.
- C. Co-execute submittals when required.
- D. Retain warranties until time specified for submittal.
- E. Manual: Bind in commercial quality 8-1/2 by 11 inch (216 by 279 mm) three D side ring binders with durable plastic covers.
- F. Cover: Identify each binder with typed or printed title WARRANTIES AND BONDS, with title of Project; name, address and telephone number of Contractor and equipment supplier; and name of responsible company principal.
- G. Table of Contents: Neatly typed, in the sequence of the Table of Contents of the Project Manual, with each item identified with the number and title of the specification section in which specified, and the name of product or work item.
- H. Separate each warranty with index tab sheets keyed to the Table of Contents listing. Provide full information, using separate typed sheets as necessary. List Subcontractor, supplier, and manufacturer, with name, address, and telephone number of responsible principal.

SECTION 02 4100 - DEMOLITION

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Selective demolition of building elements for alteration purposes.

1.02 RELATED REQUIREMENTS

- A. Section 01 1000 Summary: Limitations on Contractor's use of site and premises.
- B. Section 01 7000 Execution and Closeout Requirements: Project conditions; and existing construction to remain.
- C. Section 01 7419 Construction Waste Management and Disposal: Limitations on disposal of removed materials; requirements for recycling.

1.03 REFERENCE STANDARDS

- A. 29 CFR 1926 U.S. Occupational Safety and Health Standards current edition.
- B. NFPA 241 Standard for Safeguarding Construction, Alteration, and Demolition Operations 2022, with Errata (2021).

PART 2 PRODUCTS -- NOT USED

PART 3 EXECUTION

3.01 GENERAL PROCEDURES AND PROJECT CONDITIONS

- A. Comply with requirements in Section 01 7000.
- B. Comply with applicable codes and regulations for demolition operations and safety of adjacent structures and the public.
 - 1. Obtain required permits.
 - 2. Comply with applicable requirements of NFPA 241.
 - 3. Provide, erect, and maintain temporary barriers and security devices.
 - 4. Use physical barriers to prevent access to areas that could be hazardous to workers or the public.
 - 5. Conduct operations to minimize effects on and interference with adjacent functions and occupants.
 - 6. Do not close or obstruct roadways or sidewalks without permits from authority having jurisdiction.
 - Conduct operations to minimize obstruction of public and private entrances and exits. Do not
 obstruct required exits at any time. Protect persons using entrances and exits from removal
 operations.
 - 8. Obtain written permission from owners of adjacent properties when demolition equipment will traverse, infringe upon, or limit access to their property.
- C. Do not begin removal until receipt of notification to proceed from Owner.
- D. Do not begin removal until Owner furnisthings have been moved.
- E. Protect existing structures and other elements to remain in place and not removed.
- F. Minimize production of dust due to demolition operations.
- G. Perform demolition in a manner that maximizes salvage and recycling of materials.
 - 1. Comply with requirements of Section 01 7419 Construction Waste Management and Disposal.
 - 2. Dismantle existing construction and separate materials.

3. Set aside reusable, recyclable, and salvageable materials; store and deliver to collection point or point of reuse.

3.02 EXISTING UTILITIES

- A. Protect existing utilities to remain from damage.
- B. Do not disrupt public utilities without permit from authority having jurisdiction.
- C. Do not close, shut off, or disrupt existing life safety systems that are in use without at least 7 days prior written notification to Owner.

3.03 SELECTIVE DEMOLITION FOR ALTERATIONS

- A. Existing construction and utilities indicated on drawings are based on casual field observation and existing record documents only.
 - 1. Verify construction and utility arrangements are as indicated.
 - 2. Report discrepancies to Architect before disturbing existing installation.
 - 3. Beginning of demolition work constitutes acceptance of existing conditions that would be apparent upon examination prior to starting demolition.
- B. Separate areas in which demolition is being conducted from areas that remain occupied.
 - 1. Provide, erect, and maintain temporary dustproof partitions of construction indicated on drawings .
- C. Remove existing work as indicated and required to accomplish new work.
- D. Protect existing work to remain.
 - 1. Perform cutting to accomplish removal work neatly and as specified for cutting new work.
 - 2. Repair adjacent construction and finishes damaged during removal work.
 - 3. Patch to match new work.

3.04 DEBRIS AND WASTE REMOVAL

- A. Remove debris, junk, and trash from site.
- B. Leave site in clean condition, ready for subsequent work.
- C. Clean up spillage and wind-blown debris from public and private lands.

SECTION 06 1000 - ROUGH CARPENTRY

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Concealed wood blocking, nailers, and supports.

1.02 RELATED REQUIREMENTS

A. Section 09 2116 - Gypsum Board Assemblies: Gypsum-based sheathing.

1.03 REFERENCE STANDARDS

- ASTM A153/A153M Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware 2016a.
- B. ASTM E84 Standard Test Method for Surface Burning Characteristics of Building Materials 2018.
- C. PS 20 American Softwood Lumber Standard 2021.
- D. SPIB (GR) Grading Rules 2014.

1.04 DELIVERY, STORAGE, AND HANDLING

A. General: Cover wood products to protect against moisture. Support stacked products to prevent deformation and to allow air circulation.

PART 2 PRODUCTS

2.01 GENERAL REQUIREMENTS

- A. Dimension Lumber: Comply with PS 20 and requirements of specified grading agencies.
 - 1. If no species is specified, provide species graded by the agency specified; if no grading agency is specified, provide lumber graded by grading agency meeting the specified requirements.
 - 2. Grading Agency: Grading agency whose rules are approved by the Board of Review, American Lumber Standard Committee at www.alsc.org, and who provides grading service for the species and grade specified; provide lumber stamped with grade mark unless otherwise indicated.
- B. Wood sourced from a sustainbly harvested location. Submit any documentation available.

2.02 DIMENSION LUMBER FOR CONCEALED APPLICATIONS

- A. Grading Agency: Southern Pine Inspection Bureau, Inc; SPIB (GR).
- B. Sizes: Nominal sizes as indicated on drawings, S4S.
- C. Moisture Content: S-dry or MC19.
- D. Stud Framing (2 by 2 through 2 by 6 (50 by 50 mm through 50 by 150 mm)):
 - 1. Species: Allowed under referenced grading rules.
 - 2. Grade: No. 2.
- E. Joist, Rafter, and Small Beam Framing (2 by 6 through 4 by 16 (50 by 150 mm through 100 by 400 mm).
 - 1. Species: Allowed under grading rules.
- F. Miscellaneous Framing, Blocking, Nailers, Grounds, and Furring (WD BLKG):
 - 1. Lumber: S4S, No. 2 or Standard Grade.
 - 2. Boards: Standard or No. 3.

2.03 ACCESSORIES

A. Fasteners and Anchors:

- 1. Metal and Finish: Hot-dipped galvanized steel complying with ASTM A153/A153M for high humidity and preservative-treated wood locations, unfinished steel elsewhere.
- 2. Drywall Screws: Bugle head, hardened steel, power driven type, length three times thickness of sheathing.

PART 3 EXECUTION

3.01 INSTALLATION - GENERAL

- A. Select material sizes to minimize waste.
- B. Reuse scrap to the greatest extent possible; clearly separate scrap for use on site as accessory components, including: shims, bracing, and blocking.

3.02 BLOCKING, NAILERS, AND SUPPORTS

- A. Provide framing and blocking members as indicated or as required to support finishes, fixtures, specialty items, and trim.
- B. In framed assemblies that have concealed spaces, provide solid wood fireblocking as required by applicable local code, to close concealed draft openings between floors and between top story and roof/attic space; other material acceptable to authorities having jurisdiction may be used in lieu of solid wood blocking.
- C. In walls, provide blocking attached to studs as backing and support for wall-mounted items, unless item can be securely fastened to two or more studs or other method of support is explicitly indicated.

3.03 CLEANING

- A. Waste Disposal: See Section 01 7419 Construction Waste Management and Disposal.
 - 1. Comply with applicable regulations.
 - 2. Do not send materials treated with pentachlorophenol, CCA, or ACA to co-generation facilities or "waste-to-energy" facilities.
- B. Do not leave wood, shavings, sawdust, etc. on the ground.
- C. Prevent sawdust and wood shavings from entering the storm drainage system.

SECTION 07 9200 - JOINT SEALANTS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Nonsag gunnable joint sealants.
- B. Joint backings and accessories.

1.02 RELATED REQUIREMENTS

A. Section 09 2116 - Gypsum Board Assemblies: Sealing acoustical and sound-rated walls and ceilings.

1.03 REFERENCE STANDARDS

- A. ASTM C794 Standard Test Method for Adhesion-In-Peel of Elastomeric Joint Sealants 2015a.
- B. ASTM C1087 Standard Test Method for Determining Compatibility of Liquid-Applied Sealants with Accessories Used in Structural Glazing Systems 2016.
- C. ASTM C1193 Standard Guide for Use of Joint Sealants 2016.

1.04 SUBMITTALS

- A. See Section 01 3000 Administrative Requirements for submittal procedures.
- B. Product Data: Submit manufacturer's technical datasheets for each product to be used; include the following:
 - 1. Physical characteristics, including movement capability, VOC content, hardness, cure time, and color availability.
 - 2. List of backing materials approved for use with the specific product.
 - 3. Substrates that product is known to satisfactorily adhere to and with which it is compatible.
 - 4. Substrates the product should not be used on.
- C. Color Cards for Selection: Where sealant color is not specified, submit manufacturer's color cards showing standard colors available for selection.
- D. Samples for Verification: Where custom sealant color is specified, obtain directions from Architect and submit at least two physical samples for verification of color of each required sealant.
- E. Preconstruction Laboratory Test Reports: Submit at least four weeks prior to start of installation.

1.05 QUALITY ASSURANCE

- A. Installer Qualifications: Company specializing in performing the work of this section and with at least three years of experience.
- B. Preconstruction Laboratory Testing: Arrange for sealant manufacturer(s) to test each combination of sealant, substrate, backing, and accessories.
 - 1. Adhesion Testing: In accordance with ASTM C794.
 - 2. Compatibility Testing: In accordance with ASTM C1087.
 - 3. Allow sufficient time for testing to avoid delaying the work.
 - 4. Deliver sufficient samples to manufacturer for testing.
 - 5. Report manufacturer's recommended corrective measures, if any, including primers or techniques not indicated in product data submittals.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Nonsag Sealants:
 - 1. Bostik Inc: www.bostik-us.com.
 - 2. Dow Chemical Company: consumer.dow.com/en-us/industry/ind-building-construction.html.
 - 3. Hilti, Inc: www.us.hilti.com.
 - 4. Momentive Performance Materials, Inc (formerly GE Silicones): www.momentive.com.
 - 5. Pecora Corporation: www.pecora.com.
 - 6. Sherwin-Williams Company: www.sherwin-williams.com.
 - 7. Sika Corporation: www.usa-sika.com.
 - 8. Specified Technologies Inc: www.stifirestop.com.
 - 9. Tremco Commercial Sealants & Waterproofing: www.tremcosealants.com.
 - 10. W.R. Meadows, Inc: www.wrmeadows.com.
 - 11. Substitutions: See Section 01 6000 Product Requirements.
- B. Self-Leveling Sealants:
 - 1. Bostik Inc: www.bostik-us.com.
 - 2. Dow Chemical Company: consumer.dow.com/en-us/industry/ind-building-construction.html.
 - 3. Pecora Corporation: www.pecora.com.
 - 4. Sherwin-Williams Company: www.sherwin-williams.com.
 - 5. Sika Corporation: www.usa-sika.com.
 - 6. Tremco Commercial Sealants & Waterproofing: www.tremcosealants.com.
 - 7. W.R. Meadows, Inc: www.wrmeadows.com.
 - 8. Substitutions: See Section 01 6000 Product Requirements.

2.02 JOINT SEALANT APPLICATIONS

- A. Scope:
 - 1. Interior Joints: Do not seal interior joints unless specifically indicated to be sealed. Interior joints to be sealed include, but are not limited to, the following items.
 - a. Joints between door, window, and other frames and adjacent construction.
 - b. Other joints indicated below.
 - 2. Do not seal the following types of joints:
 - a. Joints indicated to be treated with manufactured expansion joint cover, or some other type of sealing device.
 - b. Joints where sealant is specified to be provided by manufacturer of product to be sealed.
 - c. Joints where installation of sealant is specified in another section.
 - d. Joints between suspended panel ceilings/grid and walls.
- B. Sound-Rated Assemblies: Walls and ceilings identified as STC-rated, sound-rated, or acoustical.

2.03 JOINT SEALANTS - GENERAL

- A. Material ID's:
 - 1. (SEALANT-1): Joint sealant or caulking with or without backer rod. Type as indicated above.

2.04 NONSAG JOINT SEALANTS

- A. Non-Staining Silicone Sealant: ASTM C920, Grade NS, Uses M and A; not expected to withstand continuous water immersion or traffic.
 - 1. Color: To be selected by Architect from manufacturer's standard range.

- 2. Cure Type: Multi-component, neutral curing.
- 3. Service Temperature Range: Minus 20 to 180 degrees F (Minus 29 to 82 degrees C).

2.05 ACCESSORIES

- A. Backing Tape: Self-adhesive polyethylene tape with surface that sealant will not adhere to and recommended by tape and sealant manufacturers for specific application.
- B. Masking Tape: Self-adhesive, nonabsorbent, nonstaining, removable without adhesive residue, and compatible with surfaces adjacent to joints and sealants.
- C. Joint Cleaner: Noncorrosive and nonstaining type, type recommended by sealant manufacturer; compatible with joint forming materials.
- D. Primers: Type recommended by sealant manufacturer to suit application; nonstaining.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that joints are ready to receive work.
- B. Verify that backing materials are compatible with sealants.

3.02 PREPARATION

- A. Remove loose materials and foreign matter that could impair adhesion of sealant.
- B. Clean joints, and prime as necessary, in accordance with manufacturer's instructions.
- C. Perform preparation in accordance with manufacturer's instructions and ASTM C1193.
- D. Mask elements and surfaces adjacent to joints from damage and disfigurement due to sealant work; be aware that sealant drips and smears may not be completely removable.

3.03 INSTALLATION

- A. Install this work in accordance with sealant manufacturer's requirements for preparation of surfaces and material installation instructions.
- B. Provide joint sealant installations complying with ASTM C1193.
- C. Measure joint dimensions and size joint backers to achieve width-to-depth ratio, neck dimension, and surface bond area as recommended by manufacturer, except where specific dimensions are indicated.
- D. Install bond breaker backing tape, as required.
- E. Install sealant free of air pockets, foreign embedded matter, ridges, and sags, and without getting sealant on adjacent surfaces.
- F. Do not install sealant when ambient temperature is outside manufacturer's recommended temperature range, or will be outside that range during the entire curing period, unless manufacturer's approval is obtained and instructions are followed.
- G. Nonsag Sealants: Tool surface concave, unless otherwise indicated; remove masking tape immediately after tooling sealant surface.

SECTION 09 2116 - GYPSUM BOARD ASSEMBLIES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Performance criteria for gypsum board assemblies.
- B. Metal stud wall framing.
- C. Metal channel ceiling framing.
- D. Gypsum sheathing.
- E. Gypsum wallboard.
- F. Joint treatment and accessories.

1.02 RELATED REQUIREMENTS

A. Section 07 9200 - Joint Sealants: Sealing acoustical gaps in construction other than gypsum board or plaster work.

1.03 REFERENCE STANDARDS

- A. AISI S220 North American Standard for Cold-Formed Steel Nonstructural Framing 2020.
- B. AISI S240 North American Standard for Cold-Formed Steel Structural Framing 2015, with Errata (2020).
- C. ASTM A1003/A1003M Standard Specification for Steel Sheet, Carbon, Metallic- and Nonmetallic-Coated for Cold-Formed Framing Members 2015.
- D. ASTM C475/C475M Standard Specification for Joint Compound and Joint Tape for Finishing Gypsum Board 2015.
- E. ASTM C754 Standard Specification for Installation of Steel Framing Members to Receive Screw-Attached Gypsum Panel Products 2017.
- F. ASTM C840 Standard Specification for Application and Finishing of Gypsum Board 2017a.
- G. ASTM C1047 Standard Specification for Accessories For Gypsum Wallboard and Gypsum Veneer Base 2014a.
- H. ASTM C1396/C1396M Standard Specification for Gypsum Board 2017.
- I. GA-216 Application and Finishing of Gypsum Panel Products 2016.
- J. GA-600 Fire Resistance Design Manual 2015.
- K. UL (FRD) Fire Resistance Directory Current Edition.

1.04 SUBMITTALS

- A. See Section 01 3000 Administrative Requirements for submittal procedures.
- B. Product Data: Provide data on metal framing, gypsum board, glass mat faced gypsum board, accessories, and joint finishing system.
- C. Sustainability Design Documentation: Provide applicable sustainability documentation for each product as described in Section 01 3329 Sustainable Design Requirements.

PART 2 PRODUCTS

2.01 PRODUCT REQUIREMENTS

A. Products listed as Basis of Design have been selected using sustainability criteria. Products from other manufacturer's listed herein, and/or substitutions will only be accepted if they meet, or exceed, the performance of the Basis of Design. Manufacturer must be able to provide sustainability documentation

showing that the product meets, or exceeds, the Basis of Design.

2.02 GYPSUM BOARD ASSEMBLIES

- A. Provide completed assemblies complying with ASTM C840 and GA-216.
- B. Fire-Resistance-Rated Assemblies: Provide completed assemblies with the following characteristics:
 - 1. Gypsum Association File Numbers: Comply with requirements of GA-234 and GA-600 for the particular assembly.
 - 2. UL Assembly Numbers: Provide construction equivalent to that listed for the particular assembly in the current UL (FRD).

2.03 METAL FRAMING MATERIALS

- A. Steel Sheet: ASTM A1003/A1003M, subject to the ductility limitations indicated in AISI S240.
- B. Sustainability Requirements: Manufacturers must be able to provide the following, or acceptable alternate, product documentations:
 - 1. Environmental Product Declaration (EPD) or Declare Label.
 - 2. Health Product Declaration (HPD).
- C. Basis of Design: ClarkDietrich; www.clarkdietrich.com.
- D. Other Acceptable Manufactures provided they meet or exceed the Basis of Design performance, including sustainability requirements Metal Framing, Connectors, and Accessories:
 - 1. Marino: www.marinoware.com.
 - 2. SCAFCO Corporation: www.scafco.com.
 - 3. Steel Construction Systems: www.steelconsystems.com.
 - 4. Substitutions: See Section 01 6000 Product Requirements.
- E. Nonstructural Framing System Components: AISI S220; galvanized sheet steel, of size and properties necessary to comply with ASTM C754 for the spacing indicated, with maximum deflection of wall framing of L/120 at 5 psf (L/120 at 240 Pa).
 - 1. Studs: "C" shaped with flat or formed webs with knurled faces.
 - a. (MET STUD-2): Provide 20 gauge studs unless noted otherwise.
 - 2. Runners: U shaped, sized to match studs.
 - 3. Furring Members (FUR-1): Hat-shaped sections, minimum depth of 7/8 inch (22 mm).
 - 4. Furring Members : Zee-shaped sections, minimum depth as indicated on drawings.

2.04 BOARD MATERIALS

- A. Manufacturers Gypsum-Based Board:
 - 1. CertainTeed Corporation: www.certainteed.com/.
 - 2. Georgia-Pacific Gypsum: www.gpgypsum.com.
 - 3. Gold Bond Building Products, LLC provided by National Gypsum Company: www.goldbondbuilding.com.
 - 4. USG Corporation: www.usg.com.
 - 5. Substitutions: See Section 01 6000 Product Requirements.
- B. Gypsum Wallboard: Paper-faced gypsum panels as defined in ASTM C1396/C1396M; sizes to minimize joints in place; ends square cut.
 - 1. Material ID:
 - a. (GYP BD-1): 5/8 inch Type X.
 - 2. Application: Use for vertical surfaces and ceilings, unless otherwise indicated.

- 3. At Assemblies Indicated with Fire-Resistance Rating: Use type required by indicated tested assembly; if no tested assembly is indicated, use Type X board, UL or WH listed.
- 4. Basis of Design: USG Corporation; Sheetrock Brand EcoSmart Gypsum Panels: www.usg.com.
- 5. Other Acceptable Paper-Faced Products provided they meet or exceed the Basis of Design performance requirements:
 - a. CertainTeed Corporation; Type X Drywall: www.certainteed.com.
 - b. Georgia-Pacific Gypsum; ToughRock: www.gpgypsum.com.
 - c. Gold Bond Building Products, LLC provided by National Gypsum Company; Gold Bond Fire-Shield Gypsum Board: www.goldbondbuilding.com.
 - d. Substitutions: See Section 01 6000 Product Requirements.

2.05 GYPSUM BOARD ACCESSORIES

- A. Finishing Accessories: ASTM C1047, extruded aluminum alloy (6063 T5) or galvanized steel sheet ASTM A924/A924M G90, unless noted otherwise.
 - 1. Reveal Molding (WRT-1): Model DRM-625-50 by Fry Reglet.
 - 2. Types: As detailed or required for finished appearance.
- B. Joint Materials: ASTM C475/C475M and as recommended by gypsum board manufacturer for project conditions.
 - 1. Tape: 2 inch (50 mm) wide, coated glass fiber tape for joints and corners.
 - 2. Tape: 2 inch (50 mm) wide, creased paper tape for joints and corners.

PART 3 EXECUTION

3.01 EXAMINATION

A. Verify that project conditions are appropriate for work of this section to commence.

3.02 FRAMING INSTALLATION

- A. Metal Framing: Install in accordance with AISI S220 and manufacturer's instructions.
- B. Suspended Ceilings and Soffits: Space framing and furring members as indicated.
- C. Studs: Space studs at 16 inches on center (at 406 mm on center).
 - 1. Extend partition framing to structure where indicated and to ceiling in other locations.
 - 2. Partitions Terminating at Ceiling: Attach ceiling runner securely to ceiling track in accordance with manufacturer's instructions.
- D. Furring for Fire-Resistance Ratings: Install as required for fire-resistance ratings indicated and to GA-600 requirements.

3.03 BOARD INSTALLATION

- A. Comply with ASTM C840, GA-216, and manufacturer's instructions. Install to minimize butt end joints, especially in highly visible locations.
- B. Single-Layer Nonrated: Install gypsum board in most economical direction, with ends and edges occurring over firm bearing.
 - 1. Exception: Tapered edges to receive joint treatment at right angles to framing.
- C. Fire-Resistance-Rated Construction: Install gypsum board in strict compliance with requirements of assembly listing.
- D. Installation on Metal Framing: Use screws for attachment of gypsum board.

3.04 INSTALLATION OF TRIM AND ACCESSORIES

A. Control Joints: Place control joints consistent with lines of building spaces and as indicated.

- 1. Not more than 30 feet (10 meters) apart on walls and ceilings over 50 feet (16 meters) long.
- 2. Provide a control joint at both sides of the wall at every door frame. Locate at hinge side of door.
- 3. Provide a control joint at both sides of the wall at openings in the wall. Provide on one side of the opening for openings 48 inches wide or less. For openings over 48 inches, provide on both sides of the opening.
- B. Corner Beads: Install at external corners, using longest practical lengths.
- C. Edge Trim: Install at locations where gypsum board abuts dissimilar materials.

3.05 JOINT TREATMENT

- A. Glass Mat Faced Gypsum Board and Exterior Glass Mat Faced Sheathing: Use fiberglass joint tape, embed and finish with setting type joint compound.
- B. Paper Faced Gypsum Board: Use paper joint tape, embed with drying type joint compound and finish with drying type joint compound.
- C. Finish gypsum board in accordance with levels defined in ASTM C840, as follows:
 - 1. Level 5: Walls and ceilings to receive semi-gloss or gloss paint finish and other areas that are existing.
 - 2. Level 4: Walls and ceilings to receive paint finish or wall coverings, unless otherwise indicated.
 - 3. Level 2: In utility areas, behind cabinetry, and on backing board to receive tile finish.
 - 4. Level 1: Wall areas above finished ceilings, whether or not accessible in the completed construction.
- D. Tape, fill, and sand exposed joints, edges, and corners to produce smooth surface ready to receive finishes.
 - 1. Feather coats of joint compound so that camber is maximum 1/32 inch (0.8 mm).
- E. Where Level 5 is existing finish, apply high build drywall surfacer over entire surface after joints have been properly treated; achieve a flat and tool mark-free finish.

3.06 TOLERANCES

A. Maximum Variation of Finished Gypsum Board Surface from True Flatness: 1/8 inch in 10 feet (3 mm in 3 m) in any direction.

SECTION 09 5100 - ACOUSTICAL CEILINGS

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Suspended metal grid ceiling system.
- B. Acoustical units.

1.02 RELATED REQUIREMENTS

- A. Section 01 6116 Volatile Organic Compound (VOC) Content Restrictions.
- B. Divisions 21 through 28 for mechanical and electrical components in acoustical ceilings.

1.03 REFERENCE STANDARDS

- A. ASTM A653/A653M Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process 2017.
- B. ASTM C635/C635M Standard Specification for Manufacture, Performance, and Testing of Metal Suspension Systems for Acoustical Tile and Lay-in Panel Ceilings 2022.
- C. ASTM C636/C636M Standard Practice for Installation of Metal Ceiling Suspension Systems for Acoustical Tile and Lay-In Panels 2019.
- D. ASTM E580/E580M Standard Practice for Installation of Ceiling Suspension Systems for Acoustical Tile and Lay-in Panels in Areas Subject to Earthquake Ground Motions 2022.
- E. ASTM E1264 Standard Classification for Acoustical Ceiling Products 2022.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Sequence work to ensure acoustical ceilings are not installed until building is enclosed, sufficient heat is provided, dust generating activities have terminated, and overhead work is completed, tested, and approved.
- B. Do not install acoustical units until after interior wet work is dry.

1.05 SUBMITTALS

- A. See Section 01 3000 Administrative Requirements for submittal procedures.
- B. Product Data: Provide data on suspension system components and acoustical units.
- C. Samples: Submit two samples 4 x 6 inch (100 x 150 mm) in size illustrating material and finish of acoustical units.

1.06 QUALITY ASSURANCE

- A. Suspension System Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.
- B. Acoustical Unit Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with minimum three years documented experience.

1.07 FIELD CONDITIONS

A. Maintain uniform temperature of minimum 60 degrees F (16 degrees C), and maximum humidity of 40 percent prior to, during, and after acoustical unit installation.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Acoustic Tiles/Panels:
 - 1. Armstrong World Industries, Inc: www.armstrongceilings.com.
 - 2. CertainTeed Corporation: www.certainteed.com.
 - 3. USG Corporation: www.usg.com/ceilings.
 - 4. Substitutions: See Section 01 6000 Product Requirements.
- B. Suspension Systems:
 - 1. Armstrong World Industries, Inc: www.armstrongceilings.com.
 - 2. CertainTeed Corporation: www.certainteed.com.
 - 3. Rockfon, LLC: www.rockfon.com.
 - 4. USG Corporation: www.usg.com/ceilings.
 - 5. Substitutions: See Section 01 6000 Product Requirements.

2.02 ACOUSTICAL UNITS

- A. Acoustical Units General: ASTM E1264, Class A.
 - 1. VOC Content: As specified in Section 01 6116.
- B. Acoustical Panels (ACT-#): Painted mineral fiber:
 - 1. Basis of Design: To match existing.

2.03 SUSPENSION SYSTEM(S)

- A. Metal Suspension Systems General: Complying with ASTM C635/C635M; die cut and interlocking components, with perimeter moldings, hold down clips, stabilizer bars, clips, and splices as required.
 - 1. Materials:
 - a. Steel Grid: ASTM A653/A653M, G30 coating, unless otherwise indicated.
- B. Exposed Suspension System: Hot-dipped galvanized steel grid with aluminum cap.
 - 1. Basis of Design: To match existing.

2.04 ACCESSORIES

- A. Support Channels and Hangers: Galvanized steel; size and type to suit application and ceiling system flatness requirement specified.
- B. Hanger Wire: 12 gauge, 0.08 inch (2 mm) galvanized steel wire.
- C. Hold-Down Clips: Manufacturer's standard clips to suit application.
- D. Perimeter Moldings: Same metal and finish as grid.
 - 1. Size: As required for installation conditions.
 - 2. Angle Molding: L-shaped, for mounting at same elevation as face of grid.
- E. Touch-up Paint: Type and color to match acoustical and grid units.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify existing conditions before starting work.
- B. Verify that layout of hangers will not interfere with other work.

3.02 INSTALLATION - SUSPENSION SYSTEM

- A. Install suspension system in accordance with ASTM C636/C636M, ASTM E580/E580M, ASTM C636/C636M, ASTM E580/E580M, ASTM C636/C636M, and ASTM E580/E580M and as supplemented in this section.
- B. Rigidly secure system, including integral mechanical and electrical components, for maximum deflection of 1:360.
- C. Locate system on room axis according to reflected plan.
- D. Perimeter Molding: Install at intersection of ceiling and vertical surfaces and at junctions with other interruptions.
 - 1. Use longest practical lengths.
 - 2. Miter corners.
- E. Suspension System, Non-Seismic: Hang suspension system independent of walls, columns, ducts, pipes and conduit. Where carrying members are spliced, avoid visible displacement of face plane of adjacent members.
- F. Where ducts or other equipment prevent the regular spacing of hangers, reinforce the nearest affected hangers and related carrying channels to span the extra distance.
- G. Do not support components on main runners or cross runners if weight causes total dead load to exceed deflection capability.
- H. Support fixture loads using supplementary hangers located within 6 inches (152 mm) of each corner, or support components independently.
- I. Do not eccentrically load system or induce rotation of runners.

3.03 INSTALLATION - ACOUSTICAL UNITS

- A. Install acoustical units in accordance with manufacturer's instructions.
- B. Fit acoustical units in place, free from damaged edges or other defects detrimental to appearance and function.
- C. Fit border trim neatly against abutting surfaces.
- D. Install acoustical units level, in uniform plane, and free from twist, warp, and dents.
- E. Cutting Acoustical Units:
 - 1. Make field cut edges of same profile as factory edges.
 - 2. Double cut and field paint exposed reveal edges.
- F. Where round obstructions occur, provide preformed closures to match perimeter molding.
- G. Install hold-down clips on panels within 20 ft (6 m) of an exterior door.

3.04 TOLERANCES

- A. Maximum Variation from Flat and Level Surface: 1/8 inch in 10 feet (3 mm in 3 m).
- B. Maximum Variation from Plumb of Grid Members Caused by Eccentric Loads: 2 degrees.

SECTION 09 9123 - INTERIOR PAINTING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Surface preparation.
- B. Field application of paints.
- C. Scope: Finish interior surfaces exposed to view, unless fully factory-finished and unless otherwise indicated.
 - 1. Prime surfaces to receive wall coverings.
- D. Do Not Paint or Finish the Following Items:
 - 1. Items factory-finished unless otherwise indicated; materials and products having factory-applied primers are not considered factory finished.
 - 2. Items indicated to receive other finishes.
 - 3. Items indicated to remain unfinished.
 - 4. Fire rating labels, equipment serial number and capacity labels, bar code labels, and operating parts of equipment.
 - 5. Stainless steel, anodized aluminum, bronze, terne-coated stainless steel, and lead items.
 - 6. Floors, unless specifically indicated.
 - 7. Concealed pipes, ducts, and conduits.

1.02 RELATED REQUIREMENTS

- A. Section 01 6116 Volatile Organic Compound (VOC) Content Restrictions.
- B. Section 09 9113 Exterior Painting.
- C. Divisions 21 through 26: Identification for mechanical and electrical systems.

1.03 REFERENCE STANDARDS

- A. ASTM D4442 Standard Test Methods for Direct Moisture Content Measurement of Wood and Wood-Based Materials 2020.
- B. MPI (APSM) Master Painters Institute Architectural Painting Specification Manual Current Edition.
- C. SSPC-SP 1 Solvent Cleaning 2015, with Editorial Revision (2016).
- D. SSPC-SP 6 Commercial Blast Cleaning 2007.

1.04 SUBMITTALS

- A. See Section 01 3000 Administrative Requirements, for submittal procedures.
- B. Product Data: Provide complete list of products to be used, with the following information for each:
 - 1. Manufacturer's name, product name and/or catalog number, and general product category (e.g., "alkyd enamel").
 - 2. MPI product number (e.g., MPI #47).
 - 3. Cross-reference to specified paint system products to be used in project; include description of each system.
- C. Samples: Submit three paper "draw down" samples, 8-1/2 by 11 inches (216 by 279 mm) in size, illustrating range of colors available for each finishing product specified.
 - 1. Where sheen is specified, submit samples in only that sheen.
 - 2. Where sheen is not specified, discuss sheen options with Architect before preparing samples, to eliminate sheens not required.

- 3. Paint color submittals will not be considered until color submittals for major materials not to be painted, such as masonry, have been approved.
- D. Sustainability Design Documentation: Provide applicable sustainability documentation for each product as described in Section 01 3329 Sustainable Design Requirements.
- E. Certification: By manufacturer that paints and finishes comply with VOC limits specified.
- F. Manufacturer's Instructions: Indicate special surface preparation procedures.
- G. Maintenance Data: Submit data including finish schedule showing where each product/color/finish was used, product technical data sheets, material safety data sheets (MSDS), care and cleaning instructions, touch-up procedures, repair of painted and finished surfaces, and color samples of each color and finish used.

1.05 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified, with minimum three years documented experience.
- B. Applicator Qualifications: Company specializing in performing the type of work specified with minimum five years experience.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Deliver products to site in sealed and labeled containers; inspect to verify acceptability.
- B. Container Label: Include manufacturer's name, type of paint, brand name, lot number, brand code, coverage, surface preparation, drying time, cleanup requirements, color designation, and instructions for mixing and reducing.
- C. Paint Materials: Store at minimum ambient temperature of 45 degrees F (7 degrees C) and a maximum of 90 degrees F (32 degrees C), in ventilated area, and as required by manufacturer's instructions.

1.07 FIELD CONDITIONS

- A. Do not apply materials when surface and ambient temperatures are outside the temperature ranges required by the paint product manufacturer.
- B. Follow manufacturer's recommended procedures for producing best results, including testing of substrates, moisture in substrates, and humidity and temperature limitations.
- Do not apply materials when relative humidity exceeds 85 percent, at temperatures less than 5 degrees
 F (3 degrees C) above the dew point, or to damp or wet surfaces.
- D. Minimum Application Temperatures for Paints: 50 degrees F (10 degrees C) for interiors unless required otherwise by manufacturer's instructions.
- E. Provide lighting level of 80 fc (860 lux) measured mid-height at substrate surface.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Provide paints and finishes used in any individual system from the same manufacturer; no exceptions.
- B. Primer Sealers: Same manufacturer as top coats.
- C. Substitutions: See Section 01 6000 Product Requirements.

2.02 PROJECT REQUIREMENTS

A. Products listed as Basis of Design have been selected using sustainability criteria. Products from other manufacturer's listed herein, and/or substitutions will only be accepted if they meet, or exceed, the performance of the Basis of Design. Manufacturer must be able to provide sustainability documentation showing that the product meets, or exceeds, the Basis of Design.

2.03 PAINTS AND FINISHES - GENERAL

- A. Paints and Finishes: Ready-mixed, unless intended to be a field-catalyzed paint.
 - 1. Provide paints and finishes of a soft paste consistency, capable of being readily and uniformly dispersed to a homogeneous coating, with good flow and brushing properties, and capable of drying or curing free of streaks or sags.
 - 2. Provide materials that are compatible with one another and the substrates indicated under conditions of service and application, as demonstrated by manufacturer based on testing and field experience.
 - 3. For opaque finishes, tint each coat including primer coat and intermediate coats, one-half shade lighter than succeeding coat, with final finish coat as base color.
 - 4. Supply each paint material in quantity required to complete entire project's work from a single production run.
 - 5. Do not reduce, thin, or dilute paint or finishes or add materials unless such procedure is specifically described in manufacturer's product instructions.
- B. Volatile Organic Compound (VOC) Content: See Section 01 6116.
- C. Sheens: Provide the sheens specified; where sheen is not specified, sheen will be selected later by Architect from the manufacturer's full line.
- D. Colors (PT-#): to match existing.
 - 1. Extend colors to surface edges; colors may change at any edge as directed by Architect.

2.04 PAINT SYSTEMS - INTERIOR

- A. Paint I-OP Interior Surfaces to be Painted, Unless Otherwise Indicated: Including gypsum board, concrete, concrete masonry units, wood, uncoated steel, shop primed steel, and galvanized steel.
 - 1. Two top coats and one coat primer.
 - 2. Top Coat(s): Interior Latex.
 - a. Sustainability Requirements: Manufacturer's must be able to provide the following, or equivalent, product documentations:
 - 1) Environmental Product Declaration (EPD) or Declare Label.
 - 2) Living Building Challenge Red List Free or Compliant.
 - 3) Health Product Declaration (HPD).
 - b. Basis of Design Products:
 - 1) Benjamin Moore Ultra Spec 500.
 - 2) Sherwin-Williams ProMar 200 Zero VOC.
 - 3. Primer: As recommended by top coat manufacturer for specific substrate.
- B. Paint I-OP-MD-DT Medium Duty Door/Trim: For surfaces subject to frequent contact by occupants, including metals and wood:
 - 1. Medium duty applications include doors, door frames, railings, handrails, guardrails, and balustrades, unless noted otherwise.
 - 2. Two top coats and one coat primer.
 - 3. Top Coat(s): High Performance Architectural Interior Latex.
 - a. Sustainability Requirements: Manufacturer's must be able to provide the following, or equivalent, product documentations:
 - 1) Environmental Product Declaration (EPD) or Declare Label.
 - 2) Living Building Challenge Red List Free or Compliant.
 - 3) Health Product Declaration (HPD).

- b. Basis of Design Products:
 - 1) Sherwin-Williams Pro Industrial Pre-Catalyzed Waterbased Epoxy, Eg-Shel. (MPI #139)
 - Sherwin-Williams Pro Industrial Pre-Catalyzed Waterbased Epoxy, Semi-Gloss. (MPI #141)
- 4. Primer: As recommended by top coat manufacturer for specific substrate.

2.05 ACCESSORY MATERIALS

- A. Accessory Materials: Provide primers, sealers, cleaning agents, cleaning cloths, sanding materials, and clean-up materials as required for final completion of painted surfaces.
- B. Patching Material: Latex filler.
- C. Fastener Head Cover Material: Latex filler.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Do not begin application of paints and finishes until substrates have been adequately prepared.
- B. Verify that surfaces are ready to receive work as instructed by the product manufacturer.
- C. Examine surfaces scheduled to be finished prior to commencement of work. Report any condition that may potentially affect proper application.
- D. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.
- E. Test shop-applied primer for compatibility with subsequent cover materials.
- F. Measure moisture content of surfaces using an electronic moisture meter. Do not apply finishes unless moisture content of surfaces is below the following maximums:
 - 1. Gypsum Wallboard: 12 percent.
 - 2. Masonry, Concrete, and Concrete Masonry Units: 12 percent.
 - 3. Interior Wood: 15 percent, measured in accordance with ASTM D4442.

3.02 PREPARATION

- A. Clean surfaces thoroughly and correct defects prior to application.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.
- C. Remove or mask surface appurtenances, including electrical plates, hardware, light fixture trim, escutcheons, and fittings, prior to preparing surfaces or finishing.
- D. Seal surfaces that might cause bleed through or staining of topcoat.
- E. Remove mildew from impervious surfaces by scrubbing with solution of tetra-sodium phosphate and bleach. Rinse with clean water and allow surface to dry.
- F. Gypsum Board: Fill minor defects with filler compound. Spot prime defects after repair.
- G. Galvanized Surfaces:
 - 1. Remove surface contamination and oils and wash with solvent according to SSPC-SP 1.
- H. Ferrous Metal:
 - 1. Solvent clean according to SSPC-SP 1.
 - 2. Shop-Primed Surfaces: Sand and scrape to remove loose primer and rust. Feather edges to make touch-up patches inconspicuous. Clean surfaces with solvent. Prime bare steel surfaces. Re-prime entire shop-primed item.

3. Remove rust, loose mill scale, and other foreign substances using methods recommended in writing by paint manufacturer and blast cleaning according to SSPC-SP 6 Commercial Blast Cleaning. Protect from corrosion until coated.

3.03 APPLICATION

- A. Apply products in accordance with manufacturer's written instructions and recommendations in "MPI Architectural Painting Specification Manual".
- B. Do not apply finishes to surfaces that are not dry. Allow applied coats to dry before next coat is applied.
- C. Apply each coat to uniform appearance in thicknesses specified by manufacturer.
- D. Vacuum clean surfaces of loose particles. Use tack cloth to remove dust and particles just prior to applying next coat.
- E. Reinstall electrical cover plates, hardware, light fixture trim, escutcheons, and fittings removed prior to finishing.

3.04 CLEANING

A. Collect waste material that could constitute a fire hazard, place in closed metal containers, and remove daily from site.

3.05 PROTECTION

- A. Protect finishes until completion of project.
- B. Touch-up damaged finishes after Substantial Completion.

SECTION 12 2400 - WINDOW SHADES

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Interior motorized roller shades.
- B. Motor controls.

1.02 REFERENCE STANDARDS

- A. NFPA 70 National Electrical Code Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- B. UL 325 Standard for Door, Drapery, Gate, Louver, and Window Operators and Systems Current Edition, Including All Revisions.

1.03 ADMINISTRATIVE REQUIREMENTS

A. Preinstallation Meeting: Convene one week prior to commencing work related to products of this section; require attendance of affected installers.

1.04 SUBMITTALS

- A. See Section 01 3000 Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets, including materials, finishes, fabrication details, dimensions, profiles, mounting requirements, and accessories.
- C. Shop Drawings: Include shade schedule indicating size, location and keys to details, head, jamb and sill details, mounting dimension requirements for each product and condition, and operation direction.
- D. Verification Samples: Minimum size 6 inches (150 mm) square, representing actual materials, color and pattern.
- E. Manufacturer's Instructions: Include instructions for storage, handling, protection, examination, preparation, and installation of product.
- F. Operation and Maintenance Data: List of all components with part numbers, sources of supply, and operation and maintenance instructions; include copy of shop drawings.
- G. Warranty: Submit sample of manufacturer's warranty and documentation of final executed warranty completed in Owner's name and registered with manufacturer.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Deliver shades in manufacturer's unopened packaging, labeled to identify each shade for each opening.
- B. Handle and store shades in accordance with manufacturer's recommendations.

1.06 FIELD CONDITIONS

A. Do not install products under environmental conditions outside manufacturer's absolute limits.

1.07 WARRANTY

- A. See Section 01 7800 Closeout Submittals, for additional warranty requirements.
- B. Provide manufacturer's warranty from Date of Substantial Completion, covering the following:
 - 1. Shade Hardware: One year.
 - 2. Fabric: One year.
 - 3. Aluminum and Steel Coatings: One year.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Interior Motorized Roller Shades, Motors and Motor Controls:
 - 1. Draper, Inc: www.draperinc.com.
 - 2. Hunter Douglas Architectural: www.hunterdouglasarchitectural.com.
 - 3. Levolor: www.levolor.com/commercial.
 - 4. MechoShade Systems LLC: www.mechoshade.com.
 - 5. SWFcontract, a division of Springs Window Fashions, LLC: www.swfcontract.com.
 - 6. Substitutions: See Section 01 6000 Product Requirements.

2.02 ROLLER SHADES

- A. General:
 - 1. Provide shade system components that are easy to remove or adjust without removal of mounted shade brackets.
 - 2. Provide shade system that operates smoothly when shades are raised or lowered.
 - 3. Motorized Shades: Motor system housed inside roller tube, controlling shade movement via motor controls indicated; listed or recognized to UL 325.
 - a. Comply with NFPA 70.
 - b. Electrical Components: Listed, classified, and labeled as suitable for the purpose intended. Where applicable, system components to be FCC compliant.
 - c. Motors: Size and configuration as recommended by manufacturer for the type, size, and arrangement of shades to be operated; integrated into shade operating components and concealed from view; fully compatible with controls to be installed.
- B. Roller Shades Basis of Design: Motorized Roller Shades by Draper.
 - 1. Description: Single roller, motor-operated fabric window shade system complete with mounting brackets, roller tubes, hembars, hardware, and accessories.
 - a. Mounting: Window head mounted.
 - b. Size: As indicated on drawings.
 - c. Fabric: As indicated under Shade Fabric article.
 - 2. Brackets and Mounting Hardware: As recommended by manufacturer for mounting indicated and to accommodate shade fabric roll-up size and weight.
 - a. Material: Steel, 1/8 inch (3 mm) thick.
 - b. Double Roller Brackets: Configured for light-filtering and room-darkening shades in one opening.
 - 1) Light-Filtering Fabric: Room-side of opening.
 - 2) Room-Darkening Fabric: Glass-side of opening.
 - c. Multiple Shade Operation: Provide hardware as necessary to operate more than one shade using a single motor or motors wired together.
 - 3. Roller Tubes:
 - a. Material: Extruded aluminum.
 - b. Size: As recommended by manufacturer; selected for suitability for installation conditions, span, and weight of shades.
 - c. Fabric Attachment: Utilize extruded channel in tube to accept vinyl spline welded to fabric edge. Shade band to be removable and replaceable without removing roller tube from brackets or inserting spline from the side of the roller tube.

- 4. Hembars: Designed to maintain bottom of shade straight and flat.
 - a. Style: Full wrap fabric covered bottom bar, flat profile with heat sealed closed ends.
 - b. Room-Darkening Shades: Provide a slot in bottom bar with wool-pile light seal.
- 5. Intelligent Encoded Electronic Drive System:
 - a. Low Voltage EDU (24 VDC):
 - 1) The drive system shall accept a 120 volt, single phase, 60 hz direct connection. The drive system shall convert the 120 volt connection to 24 volt DC, as required.
 - 2) Audible Noise: 38 dBA or less measured 3 feet from the motor unit, depending on motor torque.
 - 3) EDU to be capable of being configured to place the motor into Override Mode when local switch commands shade to new position. Upon entering Override Mode, EDU to monitor and log positioning commands from automation devices but not act upon them until exiting Override Mode.
 - 4) Preventative Maintenance: EDU to internally monitor important operating parameters to ensure motor and its shade assembly are functioning properly.
 - b. Modes of Operation:
 - 1) Uniform Mode: Allows for shades to move only to defined intermediate stop positions in order to maintain aesthetic uniformity.
 - 2) Manual Mode: Allows for shades to move by activating a switch and the shade stopping when the switch is released.
 - Maintenance Mode: Prevents shade from moving to newly commanded positions via dry contact or network control commands until EDU has been serviced and/or Maintenance Mode has been cleared/disabled.
 - c. Control Methods: Support both local isolated dry contact input and network control.
 - 1) Local isolated dry contact inputs support local switch control.
 - 2) Bidirectional network communication enables commanding the operation of large groups of shades over a common backbone.
 - 3) Provide a minimum of three customizable preset positions, in addition to fully open and fully closed, accessible over the local dry contact control inputs and over the network connection.
- 6. Accessories:
 - a. Fascia: Removable extruded aluminum fascia, size as required to conceal shade mounting, attachable to brackets without exposed fasteners; fabric wrapped finish to match shade.

2.03 SHADE FABRIC

- A. Fabric: Nonflammable, color-fast, impervious to heat and moisture, and able to retain its shape under normal operation.
 - 1. Basis of Design: Draper.
 - a. Light Filtering Fabric (SHADE-1): 1% openness factor; 1% E-Screen Sunshade; Color and metal finish to be selected by Architect; provide physical samples.
 - b. Room Darkening Fabric (SHADE-2): Flocke Blackout Product; Color and metal finish to be selected by Architect; provide physical samples.
 - c. Substitutions: See Section 01 6000 Product Requirements.

2.04 MOTOR CONTROLS

A. Unless specifically indicated to be excluded, provide all required equipment, conduit, boxes, wiring, connectors, hardware, supports, accessories, software, system programming, etc. as necessary for a

complete operating system that provides the control intent indicated.

- B. Provide all components and connections necessary to interface with other systems as indicated.
- C. Manual Controls:
 - 1. Control Functions:
 - a. Open: Automatically open controlled shade(s) to fully open position when button is pressed.
 - b. Close: Automatically close controlled shade(s) to fully closed position when button is pressed.
 - c. Presets control shade(s) to three determined shade lengths.
 - d. Multiple Shade Groups: Provide individual controls for each shade group as indicated.
 - 2. Wall Controls: Provided by shade manufacturer.
 - a. Finish: To be selected by Architect.
 - b. Button Engraving: Manufacturer's standard engraving, unless otherwise indicated.

2.05 ROLLER SHADE FABRICATION

- A. Field measure finished openings prior to ordering or fabrication.
- B. Dimensional Tolerances: Fabricate shades to fit openings within specified tolerances.
 - 1. Vertical Dimensions: Fill openings from head to sill with 1/2 inch (13 mm) space between bottom bar and window stool.
 - 2. Horizontal Dimensions Inside Mounting: Fill openings from jamb to jamb.
- C. At openings requiring continuous multiple shade units with separate rollers, locate roller joints at window mullion centers; butt rollers end-to-end.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Examine finished openings for deficiencies that may preclude satisfactory installation.
- B. Start of installation shall be considered acceptance of substrates.

3.02 PREPARATION

- A. Prepare surfaces using methods recommended by manufacturer for achieving best result for substrate under the project conditions.
- B. Coordinate with window installation and placement of concealed blocking to support shades.

3.03 INSTALLATION

- A. Install in accordance with manufacturer's instructions and approved shop drawings, using mounting devices as indicated.
- B. Adjust level, projection, and shade centering from mounting bracket. Verify there is no telescoping of shade fabric. Ensure smooth shade operation.

3.04 SYSTEM STARTUP

A. Motorized Shade System: Provide services of a manufacturer's authorized representative to perform system startup.

3.05 CLEANING

- A. Clean soiled shades and exposed components as recommended by manufacturer.
- B. Replace shades that cannot be cleaned to "like new" condition.

3.06 CLOSEOUT ACTIVITIES

A. See Section 01 7800 - Closeout Submittals, for closeout submittals.

- B. Demonstration: Demonstrate operation and maintenance of window shade system to Owner's personnel.
- C. Training: Train Owner's personnel on operation and maintenance of system.
 - 1. Use operation and maintenance manual as training reference, supplemented with additional training materials as required.
 - 2. Provide minimum of two hours training by manufacturer's authorized personnel at location designated by the Owner.

3.07 PROTECTION

- A. Protect installed products from subsequent construction operations.
- B. Touch-up, repair, or replace damaged products before Substantial Completion.
SECTION 26 05 00 - BASIC ELECTRICAL REQUIREMENTS

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Basic Electrical Requirements applicable to Division 26, Division 27 and Division 1 - General Requirements.

1.02 REFERENCES

- A. FM P7825 Approval Guide; Factory Mutual Research Corporation; current edition.
- B. NEMA MG 1 Motors and Generators; National Electrical Manufacturers Association; 2016.
- C. NFPA 70 National Electrical Code; National Fire Protection Association; 2020.

1.03 DEFINITIONS

- A. The meaning and intent of the word "provide" as used in these specifications is the same as the words "The Electrical Contractor (and/or proposer) shall provide."
- B. The word "provide" shall carry the same meaning as "furnish and install."
- C. The word "Contractor" shall mean the "Electrical Contractor."

1.04 PERFORMANCE REQUIREMENTS

- A. Conform to all applicable Building Codes, ordinances, laws and regulations.
- B. Electrical: Conform to NFPA 70 National Electrical Code.
- C. Furnish products listed and classified by Underwriters Laboratories Inc.[®], as suitable for the purpose specified and shown.
- D. Obtain permits, and request inspections from authority having jurisdiction.
- E. If the drawings and/or specifications conflict with any regulatory requirement, the regulatory requirement shall be followed. This does not relieve the Contractor from complying with items in the drawings and/or specifications in excess of the regulatory requirements.
- F. Test Standards:
 - 1. All materials and equipment shall be listed, labeled or certified by a nationally recognized testing laboratory to meet Underwriters Laboratories, Inc.[®], standards where test standards have been established. Equipment and materials which are not covered by UL[®] Standards will be accepted provided the equipment and material is listed, labeled, certified or otherwise determined to meet safety requirements of a nationally recognized testing laboratory acceptable to the authority having jurisdiction.
 - 2. Definitions:
 - a. Listed; equipment or device of a kind mentioned which:
 - 1) Is published by a nationally recognized laboratory which makes periodic inspection of production of such equipment.
 - 2) States that such equipment meets nationally recognized standards or has been tested and found safe for use in a specified manner.
 - b. Labeled; equipment or device is when:
 - 1) It embodies a valid label, symbol, or other identifying mark of a nationally recognized testing laboratory such as Underwriters Laboratories Inc.®
 - 2) The laboratory makes periodic inspections of the production of such equipment.

- 3) The labeling indicates compliance with nationally recognized standards or tests to determine safe use in a specified manner.
- c. Certified; equipment or product is which:
 - 1) Has been tested and found by a nationally recognized testing laboratory to meet nationally recognized standards or to be safe for use in a specified manner.
 - 2) Production of equipment or product is periodically inspected by a nationally recognized testing laboratory.
 - 3) Bears a label, tag, or other record of certification.
- d. Nationally recognized testing laboratory; laboratory which is approved by the authority having jurisdiction.

1.05 PROJECT/SITE CONDITIONS

- A. Install Work in locations shown on Drawings, unless prevented by Project conditions.
- B. Prepare drawings showing proposed rearrangement of Work to meet Project conditions, including changes to Work specified in other Sections. Obtain permission of Architect/Engineer before proceeding.

1.06 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Submit product data grouped to include complete submittals of related systems, products, and accessories.
- C. Shop Drawings: Submit Shop Drawings grouped to include complete submittals of related systems, products, and accessories.
- D. Warranty: Submit manufacturer warranty and ensure that forms have been completed in Owner's name and registered with manufacturer.
- E. Mark dimensions and values in units to match those specified.

1.07 DRAWINGS

- A. The drawings indicate the general arrangement and extent of electrical work. Do not scale off the electrical drawings. All data shall be field verified with actual field conditions. Review drawings of other trades and adjust work to meet the requirements of conditions shown. Contractor shall be responsible to field measure and confirm mounting heights and location of electrical equipment with respect to counters, radiation and other Architectural, Mechanical or Structural work. Coordinate site electrical equipment with the site utilities to ensure electrical equipment is not installed above underground site utilities.
- B. The drawings and specifications are complementary each to the other. What is called for by one shall be as binding as if called for by both.
- C. Omissions or discrepancies between different drawings or between drawings and specifications or between contract documents and regulations and/or codes shall be brought to the attention of the Architect/Engineer for a decision in writing. Interpretation before the proposal shall be by addendum only. If an interpretation is not given by addendum, propose the greater quantity or better quality.

1.08 PERMITS AND LICENSES

A. Obtain and pay for required licenses and permits. Pay for fees and charges for connection to outside services. Coordinate costs for electrical service including transformers, telephone service, cable TV service during the proposal phase of the project. Pay for use of property other than the site of the work

for storage of materials or other purposes.

B. Installation shall be performed by persons licensed and skilled in the trade, and shall be done under the supervision of a master electrician licensed by the State.

1.09 PROGRESS OF WORK

- A. Organize electrical work such that the progress of the work will conform to the progress of other trades, and complete the entire installation as soon as the conditions of the building will permit. Any cost resulting from defective or ill-timed work performed under this section shall be borne by this Contractor.
- B. Portions of work will be required to be accomplished during other than normal working hours.

1.10 CORRELATION OF WORK

- A. Organize work so that it will not interfere with the work of other trades. Consult the drawings and specifications for work of other trades to correlate information, and consult the architectural and structural drawings for details and dimensions. Verify the location of all outlets. If interference develops, bring it to the attention of the Architect/Engineer for a decision. No additional compensation will be allowed for the moving of misplaced outlets, wiring or equipment.
- B. Before roughing-in for electrical equipment furnished by others, verify the voltage and current characteristics and control connections of this equipment, and provide the proper feeders and connections as recommended by the manufacturer of the equipment.

1.11 CUTTING AND PATCHING

- A. Lay out all work in advance and where removal of door frames, portions of walls, ceilings or floors are required, and cutting, channeling, chasing, or drilling of building surfaces is necessary for the proper installation of electrical equipment, carefully perform this work in a manner which does not weaken floors and walls. Damaged surfaces shall be repaired at no cost to the Owner.
- B. Concrete shall be cut only with rotary type drilling tools. Electrical equipment shall not be cut with torches, and shall be joined only by bolting (i.e., do not weld wireways to panels).
- C. Patching, when required, shall be finished to match adjoining surfaces and is subject to approval by the Architect/Engineer.

1.12 EXAMINATION OF SITE

A. Before submitting a proposal, each proposer shall examine the site, check the means of installing electrical equipment within the building, making connections to services, and shall be familiar with the existing conditions and limitations. No extras will be allowed because of the Contractor's misunderstanding of the amount of work involved or lack of knowledge of any site conditions which may affect the work. Any apparent variance of the drawings or specifications from the existing conditions at the site shall be called to the attention of the Architect/Engineer before submitting a proposal.

1.13 OPERATION AND MAINTENANCE DATA

- A. Submit under provisions of Section 01 78 00.
- B. Format:
 - 1. Prepare data in the form of an instructional manual.

- 2. Organize in commercial quality, 8-1/2" x 11", three-ring binders with hard black or white, cleanable, plastic covers. When multiple binders are used, correlate data into related consistent groupings.
- 3. Identify each binder on cover with typed or printed title "OPERATION AND MAINTENANCE INSTRUCTIONS," list title of Project and identify subject matter of contents.
- 4. Arrange contents by section numbers and sequence of Table of Contents by this Project Manual.
- 5. Provide tabbed flyleaf for each separate product and system, with typed description of product and major component parts of equipment.
- 6. Text: Manufacturer's printed data or typewritten data on 20-pound paper.
- 7. Drawings: Provide with reinforced punched binder tab. Bind in with text. Fold larger drawings to size of text pages.
- C. Contents of Each Volume:
 - 1. Table of Contents: Provide title of Project; names, addresses and telephone numbers of Engineer and Contractor and listing of products and systems indexed to tabbed flyleaves.
 - 2. Updated Subcontractor, Supplier and Manufacturer List: Indicate any changes made after original submission at start of Project.
 - 3. Include description as to type and quantity of maintenance materials turned over to Owner in accordance with individual sections.
 - 4. Warranties and Bonds: Include all.
 - 5. Shop Drawings and Product Data: Include only those so required by individual sections.
 - 6. Operation and Maintenance Data for Equipment and Systems: Where required by individual sections, provide manufacturer's recommended operation procedures and maintenance requirements including guide for troubleshooting, disassembly, repair and assembly instructions and alignment, adjusting, balancing and checking instructions.
 - 7. Include a copy of ANSI/NFPA 70B Electrical Equipment Maintenance.
- D. Submittals:
 - 1. Submit one copy of completed volumes in final form 15 days prior to final inspection. Copy will be returned after final inspection, with Engineer's comments. Revise contents of documents as required prior to final submittal.
 - 2. Submit two copies of revised volumes of data in final form to Engineer within ten days after final inspection.

1.14 DELIVERY, STORAGE AND HANDLING

A. Deliver, store, protect and handle Products to site under provisions of Section 01 60 00.

1.15 PROJECT RECORD DOCUMENTS

- A. Submit under provisions of Section 01 78 00.
- B. Include all changes and deviations from contract documents. Clearly mark in red colored pencil. Include all addendum items and approved change orders.

1.16 MINIMUM REQUIREMENTS

- A. References to the National Electrical Code (NEC), Underwriters Laboratories, Inc. (UL), National Fire Protection Association (NFPA), National Electrical Installation Standards (NEIS), and any other applicable standards are minimum installation requirement standards.
- B. Drawings and other specification sections shall govern in those instances where requirements are greater than those specified in the above standards.

SECTION 26 05 01 - ELECTRICAL DEMOLITION

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Electrical demolition.

PART 2 PRODUCTS

2.01 MATERIALS AND EQUIPMENT

A. Materials and equipment for patching and extending work: As specified in individual sections.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify field measurements and circuiting arrangements are as shown on Drawings.
- B. Verify that abandoned wiring and equipment serve only abandoned facilities.
- C. Demolition drawings are based on casual field observation and existing record documents.
- D. Report discrepancies to Architect before disturbing existing installation.
- E. Beginning of demolition means installer accepts existing conditions.

3.02 PREPARATION

A. Existing Panelboards: Disable system only to make switchovers and connections. Minimize outage duration.

3.03 DEMOLITION AND EXTENSION OF EXISTING ELECTRICAL WORK

- A. Remove, relocate, and extend existing installations to accommodate new construction.
- B. Remove abandoned wiring to source of supply.
- C. Remove exposed abandoned conduit, including abandoned conduit above accessible ceiling finishes. Cut conduit flush with walls and floors, and patch surfaces.
- D. Disconnect abandoned outlets and remove devices. Remove abandoned outlets if conduit servicing them is abandoned and removed. Provide blank cover for abandoned outlets which are not removed.
- E. Disconnect and remove electrical devices and equipment serving utilization equipment that has been removed.
- F. Repair adjacent construction and finishes damaged during demolition and extension work.
- G. Maintain access to existing electrical installations which remain active. Modify installation or provide access panel as appropriate.
- H. Install junction boxes in walls, ceilings or floors if required to continue circuiting.
- I. Extend existing installations using materials and methods compatible with existing electrical installations, or as specified.
- J. Remove all abandoned systems cabling that has been abandoned above acoustical ceilings and within cable tray. Remove cable from end device back to patch panel, punchdown or termination location.

3.04 CLEANING AND REPAIR

- A. Clean and repair existing materials and equipment which remain or are to be reused.
- B. Panelboards: Clean exposed surfaces and check tightness of electrical connections. Replace damaged circuit breakers and provide closure plates for vacant positions. Provide typed circuit directory showing revised circuiting arrangement.

3.05 MATERIAL DISPOSAL

- A. Material and equipment deemed salvageable by the Owner shall remain the property of Owner.
 Contractor shall dismantle these items to manageable size and deliver to designated storage area on site. The Owner shall have first right of refusal on all material and equipment.
- B. All other materials and equipment shall become property of Contractor and must be removed from site and disposed of by approved method.

SECTION 26 05 19 - LOW VOLTAGE WIRING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Single conductor building wire.
- B. Metal-clad cable.
- C. Wiring connectors.
- D. Electrical tape.
- E. Wire pulling lubricant.
- F. Cable ties.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 01 Electrical Demolition
- B. Section 26 05 26 Grounding and Bonding: Additional requirements for grounding conductors and grounding connectors.
- C. Section 26 05 53 Electrical Identification: Identification products and requirements.

1.03 REFERENCE STANDARDS

- A. ASTM B3 Standard Specification for Soft or Annealed Copper Wire 2013 (Reapproved 2018).
- B. ASTM B8 Standard Specification for Concentric-Lay-Stranded Copper Conductors, Hard, Medium-Hard, or Soft 2011 (Reapproved 2017).
- C. ASTM B33 Standard Specification for Tin-Coated Soft or Annealed Copper Wire for Electrical Purposes 2010, with Editorial Revision (2020).
- D. ASTM B787/B787M Standard Specification for 19 Wire Combination Unilay-Stranded Copper Conductors for Subsequent Insulation 2004 (Reapproved 2020).
- E. ASTM D3005 Standard Specification for Low-Temperature Resistant Vinyl Chloride Plastic Pressure-Sensitive Electrical Insulating Tape 2017.
- F. IEEE 1210 IEEE Standard Tests for Determining Compatibility of Cable-Pulling Lubricants with Wire and Cable 2004 (Corrigendum 2014).
- G. IEEE 1210 IEEE Standard Tests for Determining Compatibility of Cable-Pulling Lubricants with Wire and Cable 2004 (Corrigendum 2014).
- H. NECA 1 Standard for Good Workmanship in Electrical Construction 2015.
- I. NECA 120 Standard for Installing Armored Cable (AC) and Type Metal-Clad (MC) Cable 2018.
- J. NFPA 70 National Electrical Code Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- K. UL 44 Thermoset-Insulated Wires and Cables Current Edition, Including All Revisions.
- L. UL 83 Thermoplastic-Insulated Wires and Cables Current Edition, Including All Revisions.
- M. UL 267 Outline of Investigation for Wire-Pulling Compounds Current Edition, Including All Revisions.
- N. UL 486A-486B Wire Connectors Current Edition, Including All Revisions.

- O. UL 486C Splicing Wire Connectors Current Edition, Including All Revisions.
- P. UL 486D Sealed Wire Connector Systems Current Edition, Including All Revisions.
- Q. UL 510 Polyvinyl Chloride, Polyethylene, and Rubber Insulating Tape Current Edition, Including All Revisions.
- R. UL 1569 Metal-Clad Cables Current Edition, Including All Revisions.
- S. ASTM B836 Standard Specification for Compact Round Stranded Aluminum Conductors using Single Input Wire Construction (2015).

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate sizes of raceways, boxes, and equipment enclosures installed under other sections with the actual conductors to be installed, including adjustments for conductor sizes increased for voltage drop.
 - 2. Coordinate with electrical equipment installed under other sections to provide terminations suitable for use with the conductors to be installed.
 - 3. Notify Architect of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.

1.05 QUALITY ASSURANCE

A. Comply with requirements of NFPA 70.

1.06 DELIVERY, STORAGE, AND HANDLING

A. Receive, inspect, handle, and store conductors and cables in accordance with manufacturer's instructions.

1.07 FIELD CONDITIONS

- A. Do not install or otherwise handle thermoplastic-insulated conductors at temperatures lower than 14 degrees F, unless otherwise permitted by manufacturer's instructions. When installation below this temperature is unavoidable, notify Architect and obtain direction before proceeding with work.
- B. Products: Furnish products listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated.

PART 2 PRODUCTS

2.01 CONDUCTOR AND CABLE APPLICATIONS

- A. Do not use conductors and cables for applications other than as permitted by NFPA 70 and product listing.
- B. Provide single conductor building wire installed in suitable raceway unless otherwise indicated, permitted, or required.
- C. Nonmetallic-sheathed cable is not permitted.
- D. Underground feeder and branch-circuit cable is not permitted.
- E. Service entrance cable is not permitted.
- F. Armored cable is not permitted.
- G. Metal-clad cable is permitted only as follows:
 - 1. Where not otherwise restricted, may be used:

- a. Where concealed above accessible ceilings for final connections from junction boxes to equipment.
 - 1) Maximum Length: 6 feet.
- H. Manufactured wiring systems are not permitted.

2.02 CONDUCTOR AND CABLE GENERAL REQUIREMENTS

- A. Provide products that comply with requirements of NFPA 70.
- B. Provide products listed, classified, and labeled as suitable for the purpose intended.
- C. Provide conductors and cables with lead content less than 300 parts per million.
- D. Provide new conductors and cables manufactured not more than one year prior to installation.
- E. Unless specifically indicated to be excluded, provide all required conduit, boxes, wiring, connectors, etc. as required for a complete operating system.
- F. Comply with NEMA WC 70.
- G. Thermoplastic-Insulated Conductors and Cables: Listed and labeled as complying with UL 83.
- H. Conductors for Grounding and Bonding: Also comply with Section 26 05 26.
- I. Conductors and Cables Installed Exposed in Spaces Used for Environmental Air (only where specifically permitted): Plenum rated, listed and labeled as suitable for use in return air plenums.
- J. Conductor Material:
 - 1. Provide copper conductors only. Aluminum conductors are not acceptable for this project. Conductor sizes indicated are based on copper.
 - 2. Copper Conductors: Soft drawn annealed, 98 percent conductivity, uncoated copper conductors complying with ASTM B3, ASTM B8, or ASTM B787/B787M unless otherwise indicated.
 - 3. Tinned Copper Conductors: Comply with ASTM B33.
- K. Minimum Conductor Size:
 - 1. Branch Circuits: 12 AWG.
 - a. Exceptions:
 - 1) 20 A, 120 V circuits longer than 75 feet: 10 AWG, for voltage drop.
 - 2) 20 A, 120 V circuits longer than 150 feet: 8 AWG, for voltage drop.
 - 3) 20 A, 277 V circuits longer than 150 feet: 10 AWG, for voltage drop.
 - 2. Control Circuits: 14 AWG.
- L. Where conductor size is not indicated, size to comply with NFPA 70 but not less than applicable minimum size requirements specified.
- M. Conductor Color Coding:
 - 1. Color code conductors as indicated unless otherwise required by the authority having jurisdiction. Maintain consistent color coding throughout project.
 - 2. Color Coding Method: Integrally colored insulation.
 - a. Conductors size 4 AWG and larger may have black insulation color coded using vinyl color coding electrical tape.
 - 3. Color Code:
 - a. 208Y/120 V, 3 Phase, 4 Wire System:
 - 1) Phase A: Black.
 - 2) Phase B: Red.
 - 3) Phase C: Blue.
 - 4) Neutral/Grounded: White.
 - b. Equipment Ground, All Systems: Green.

- c. For modifications or additions to existing wiring systems, comply with existing color code when existing code complies with NFPA 70 and is approved by the authority having jurisdiction.
- d. For control circuits, comply with manufacturer's recommended color code.

2.03 SINGLE CONDUCTOR BUILDING WIRE

- A. Manufacturers:
 - 1. Copper Building Wire:
 - a. Cerro Wire LLC: www.cerrowire.com/#sle.
 - b. Encore Wire Corporation: www.encorewire.com/#sle.
 - c. General Cable Technologies Corporation: www.generalcable.com/#sle.
 - d. Service Wire Co: www.servicewire.com/#sle.
 - e. Southwire Company: www.southwire.com/#sle.
 - f. Or Equal.
- B. Description: Single conductor insulated wire.
- C. Conductor Stranding:
 - 1. Feeders and Branch Circuits:
 - a. Size 10 AWG and Smaller: Solid.
 - b. Size 8 AWG and Larger: Stranded.
 - 2. Control Circuits: Stranded.
- D. Insulation Voltage Rating: 600 V.
- E. Insulation:
 - 1. Copper Building Wire: Type THHN/THWN-2 or XHHW-2.

2.04 METAL-CLAD CABLE

- A. Manufacturers:
 - 1. AFC Cable Systems Inc: www.afcweb.com/#sle.
 - 2. Encore Wire Corporation: www.encorewire.com/#sle.
 - 3. Service Wire Co: www.servicewire.com/#sle.
 - 4. Southwire Company: www.southwire.com/#sle.
- B. Description: NFPA 70, Type MC cable listed and labeled as complying with UL 1569, and listed for use in classified firestop systems to be used.
- C. Conductor Stranding:
 - 1. Size 10 AWG and Smaller: Solid.
 - 2. Size 8 AWG and Larger: Stranded.
- D. Insulation Voltage Rating: 600 V.
- E. Insulation: Type THHN/THWN-2 or XHHW-2.
- F. Provide dedicated neutral conductor for each phase conductor.
- G. Grounding: Full-size integral equipment grounding conductor.
- H. Armor: Aluminum or steel, interlocked tape.

2.05 WIRING CONNECTORS

- A. Description: Wiring connectors appropriate for the application, suitable for use with the conductors to be connected, and listed as complying with UL 486A-486B or UL 486C as applicable.
- B. Connectors for Grounding and Bonding: Comply with Section 26 05 26.
- C. Wiring Connectors for Splices and Taps:

- 1. Copper Conductors Size 8 AWG and Smaller: Use twist-on insulated spring connectors.
- D. Wiring Connectors for Terminations:
 - 1. Provide terminal lugs for connecting conductors to equipment furnished with terminations designed for terminal lugs.
 - 2. Provide compression adapters for connecting conductors to equipment furnished with mechanical lugs when only compression connectors are specified.
 - 3. Where over-sized conductors are larger than the equipment terminations can accommodate, provide connectors suitable for reducing to appropriate size, but not less than required for the rating of the overcurrent protective device.
 - 4. Stranded Conductors Size 10 AWG and Smaller: Use crimped terminals for connections to terminal screws.
 - 5. Conductors for Control Circuits: Use crimped terminals for all connections.
- E. Do not use insulation-piercing or insulation-displacement connectors designed for use with conductors without stripping insulation.
- F. Do not use push-in wire connectors as a substitute for twist-on insulated spring connectors.
- G. Twist-on Insulated Spring Connectors: Rated 600 V, 221 degrees F for standard applications and 302 degrees F for high temperature applications; pre-filled with sealant and listed as complying with UL 486D for damp and wet locations.
 - 1. Manufacturers:
 - a. 3M: www.3m.com/#sle.
 - b. Ideal Industries, Inc: www.idealindustries.com/#sle.
 - c. NSI Industries LLC: www.nsiindustries.com/#sle.
 - d. Or Equal.
- H. Crimped Terminals: Nylon-insulated, with insulation grip and terminal configuration suitable for connection to be made.
 - 1. Manufacturers:
 - a. Burndy LLC: www.burndy.com.
 - b. Ilsco: www.ilsco.com/#sle.
 - c. Thomas & Betts Corporation: www.tnb.com/#sle.
 - d. Or Equal.

2.06 ACCESSORIES

- A. Electrical Tape:
 - 1. Manufacturers:
 - a. 3M: www.3m.com/#sle.
 - b. Plymouth Rubber Europa: www.plymouthrubber.com/#sle.
 - c. Or Equal.
 - Vinyl Color Coding Electrical Tape: Integrally colored to match color code indicated; listed as complying with UL 510; minimum thickness of 7 mil; resistant to abrasion, corrosion, and sunlight; suitable for continuous temperature environment up to 221 degrees F.
 - 3. Vinyl Insulating Electrical Tape: Complying with ASTM D3005 and listed as complying with UL 510; minimum thickness of 7 mil; resistant to abrasion, corrosion, and sunlight; conformable for application down to 0 degrees F and suitable for continuous temperature environment up to 221 degrees F.
- B. Wire Pulling Lubricant:
 - 1. Manufacturers:
 - a. 3M: www.3m.com/#sle.
 - b. American Polywater Corporation: www.polywater.com/#sle.
 - c. Ideal Industries, Inc: www.idealindustries.com/#sle.

- d. Or Equal.
- 2. Listed and labeled as complying with UL 267.
- 3. Suitable for use with conductors/cables and associated insulation/jackets to be installed.
- 4. Suitable for use at installation temperature.
- C. Cable Ties: Material and tensile strength rating suitable for application.
 - 1. Manufacturers:
 - a. Burndy LLC: www.burndy.com.
 - b. Or Equal.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that interior of building has been protected from weather.
- B. Verify that work likely to damage wire and cable has been completed.
- C. Verify that raceways, boxes, and equipment enclosures are installed and are properly sized to accommodate conductors and cables in accordance with NFPA 70.
- D. Verify that field measurements are as indicated.
- E. Verify that conditions are satisfactory for installation prior to starting work.

3.02 PREPARATION

A. Clean raceways thoroughly to remove foreign materials before installing conductors and cables.

3.03 INSTALLATION

- A. Circuiting Requirements:
 - 1. Unless dimensioned, circuit routing indicated is diagrammatic.
 - 2. When circuit destination is indicated without specific routing, determine exact routing required.
 - 3. Arrange circuiting to minimize splices.
 - 4. Maintain separation of Class 1, Class 2, and Class 3 remote-control, signaling, and power-limited circuits in accordance with NFPA 70.
 - 5. Maintain separation of wiring for emergency systems in accordance with NFPA 70.
 - 6. Circuiting Adjustments: Unless otherwise indicated, when branch circuits are indicated as separate, combining them together in a single raceway is permitted, under the following conditions:
 - a. Provide no more than six current-carrying conductors in a single raceway. Dedicated neutral conductors are considered current-carrying conductors.
 - b. Increase size of conductors as required to account for ampacity derating.
 - c. Size raceways, boxes, etc. to accommodate conductors.
 - 7. Common Neutrals: Unless otherwise indicated, sharing of neutral/grounded conductors among up to three single phase branch circuits of different phases installed in the same raceway is not permitted. Provide dedicated neutral/grounded conductor for each individual branch circuit.
- B. Install products in accordance with manufacturer's instructions.
- C. Perform work in accordance with NECA 1 (general workmanship).
- D. Install metal-clad cable (Type MC) in accordance with NECA 120 and per the Manufacturer's Instructions.
- E. Installation in Raceway:
 - 1. Tape ends of conductors and cables to prevent infiltration of moisture and other contaminants.
 - 2. Pull all conductors and cables together into raceway at same time.

- 3. Do not damage conductors and cables or exceed manufacturer's recommended maximum pulling tension and sidewall pressure.
- 4. Use suitable wire pulling lubricant where necessary, except when lubricant is not recommended by the manufacturer.
- F. Secure and support conductors and cables in accordance with NFPA 70 using suitable supports and methods approved by the authority having jurisdiction. Provide independent support from building structure. Do not provide support from raceways, piping, ductwork, or other systems.
 - 1. Installation Above Suspended Ceilings: Do not provide support from ceiling support system. Do not provide support from ceiling grid or allow conductors and cables to lay on ceiling tiles.
- G. Terminate cables using suitable fittings.
 - 1. Metal-Clad Cable (Type MC):
 - a. Use listed fittings.
 - b. Cut cable armor only using specialized tools to prevent damaging conductors or insulation. Do not use hacksaw or wire cutters to cut armor.
 - c. Do not use direct-bearing set-screw type fittings for cables with aluminum armor.
- H. Install conductors with a minimum of 12 inches of slack at each outlet.
- I. Where conductors are installed in enclosures for future termination by others, provide a minimum of 5 feet of slack.
- J. Neatly train and bundle conductors inside boxes, wireways, panelboards and other equipment enclosures.
- K. Group or otherwise identify neutral/grounded conductors with associated ungrounded conductors inside enclosures in accordance with NFPA 70.
- L. Make wiring connections using specified wiring connectors.
 - 1. Make splices and taps only in accessible boxes. Do not pull splices into raceways or make splices in conduit bodies or wiring gutters.
 - 2. Remove appropriate amount of conductor insulation for making connections without cutting, nicking or damaging conductors.
 - 3. Do not remove conductor strands to facilitate insertion into connector.
 - 4. Clean contact surfaces on conductors and connectors to suitable remove corrosion, oxides, and other contaminates. Do not use wire brush on plated connector surfaces.
- M. Insulate splices and taps that are made with uninsulated connectors using methods suitable for the application, with insulation and mechanical strength at least equivalent to unspliced conductors.
 - 1. Dry Locations: Use insulating covers specifically designed for the connectors or heat shrink tubing.
 - 2. Damp Locations: Use insulating covers specifically designed for the connectors or heat shrink tubing.
 - a. For connections with insulating covers, apply outer covering of moisture sealing electrical tape.
- N. Insulate ends of spare conductors using vinyl insulating electrical tape.
- O. Field-Applied Color Coding: Where vinyl color coding electrical tape is used in lieu of integrally colored insulation as permitted in Part 2 under "Color Coding", apply half overlapping turns of tape at each termination and at each location conductors are accessible.
- P. Identify conductors and cables in accordance with Section 26 05 53.
- Q. Color Code Legend: Provide identification label identifying color code for ungrounded conductors at each piece of feeder or branch-circuit distribution equipment when premises has feeders or branch circuits served by more than one nominal voltage system.

R. Unless specifically indicated to be excluded, provide final connections to all equipment and devices, including those furnished by others, as required for a complete operating system.

3.04 FIELD QUALITY CONTROL

- A. Correct deficiencies and replace damaged or defective conductors and cables.
- B. Inspect wire for physical damage and proper connection.
- C. Measure tightness of bolted connections and compare torque measurements with manufacturer's recommended values.
- D. Verify continuity of each branch circuit conductor.

SECTION 26 05 26 - GROUNDING AND BONDING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Grounding and bonding requirements.
- B. Conductors for grounding and bonding.
- C. Connectors for grounding and bonding.
- D. Grounding and bonding components for electrical systems.

1.02 RELATED REQUIREMENTS

A. Section 26 0519 - Low-Voltage Electrical Power Conductors and Cables: Additional requirements for conductors for grounding and bonding, including conductor color coding.

1.03 REFERENCE STANDARDS

- A. NECA 1 Standard for Good Workmanship in Electrical Construction; National Electrical Contractors Association; 2010.
- B. NFPA 70 National Electrical Code; National Fire Protection Association; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- C. UL 467 Grounding and Bonding Equipment; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Verify exact locations of underground metal water service pipe entrances to building.
 - 2. Coordinate the work with other trades to provide steel reinforcement complying with specified requirements for concrete-encased electrode.
 - 3. Notify Architect of any conflicts with or deviations from the contract documents. Obtain direction before proceeding with work.
- B. Sequencing:
 - 1. Do not install ground rod electrodes until final backfill and compaction is complete.

1.05 QUALITY ASSURANCE

A. Conform to requirements of NFPA 70.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Receive, inspect, handle, and store products in accordance with manufacturer's instructions.
- B. Products: Listed and classified by Underwriters Laboratories Inc. as suitable for the purpose specified and indicated.
- C. Comply with UL 467.
- D. Comply with NECA's "Standard of Installation."

PART 2 PRODUCTS

2.01 GROUNDING AND BONDING REQUIREMENTS

A. Do not use products for applications other than as permitted by NFPA 70 and product listing.

Fargo Library Sunshades
Replacement

- B. Unless specifically indicated to be excluded, provide all required components, conductors, connectors, conduit, boxes, fittings, supports, accessories, etc. as necessary for a complete grounding and bonding system.
- C. Where conductor size is not indicated, size to comply with NFPA 70 but not less than applicable minimum size requirements specified.
- D. Bonding and Equipment Grounding:
 - 1. Provide bonding for equipment grounding conductors, equipment ground busses, metallic equipment enclosures, metallic raceways and boxes, device grounding terminals, and other normally non-current-carrying conductive materials enclosing electrical conductors/equipment or likely to become energized as indicated and in accordance with NFPA 70.
 - 2. Provide insulated equipment grounding conductor in each feeder and branch circuit raceway. Do not use raceways as sole equipment grounding conductor.
 - 3. Where circuit conductor sizes are increased for voltage drop, increase size of equipment grounding conductor proportionally in accordance with NFPA 70.
 - 4. Unless otherwise indicated, connect wiring device grounding terminal to branch circuit equipment grounding conductor and to outlet box with bonding jumper.
 - 5. Terminate branch circuit equipment grounding conductors on solidly bonded equipment ground bus only. Do not terminate on neutral (grounded) or isolated/insulated ground bus.
 - 6. Provide bonding jumper across expansion or expansion/deflection fittings provided to accommodate conduit movement.

2.02 GROUNDING AND BONDING COMPONENTS

- A. General Requirements:
 - 1. Provide products listed, classified, and labeled by Underwriter's Laboratories Inc. (UL) or Intertek (ETL) as suitable for the purpose indicated.
 - 2. Provide products listed and labeled as complying with UL 467 and IEEE 837 where applicable.
- B. Conductors for Grounding and Bonding, in addition to requirements of Section 26 0519:
 - 1. Use insulated copper conductors unless otherwise indicated.
- C. Connectors for Grounding and Bonding:
 - 1. Description: Connectors appropriate for the application and suitable for the conductors and items to be connected; listed and labeled as complying with UL 467 and IEEE 837.
 - 2. Unless otherwise indicated, use mechanical connectors for accessible connections.
 - 3. Manufacturers Mechanical and Compression Connectors:
 - a. Burndy LLC;: www.burndy.com/#sle.
 - b. Harger Lightning & Grounding: www.harger.com.
 - c. Thomas & Betts , a member of the ABB Group: www.tnb.com.
 - d. Or Equal.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that work likely to damage grounding and bonding system components has been completed.
- B. Verify that field measurements are as shown on the drawings.
- C. Verify that conditions are satisfactory for installation prior to starting work.
- D. Verify existing conditions prior to beginning work.

3.02 INSTALLATION

A. Install products in accordance with manufacturer's instructions.

- B. Install grounding and bonding system components in a neat and workmanlike manner in accordance with NECA 1.
- C. Make grounding and bonding connections using specified connectors.
 - 1. Remove appropriate amount of conductor insulation for making connections without cutting, nicking or damaging conductors. Do not remove conductor strands to facilitate insertion into connector.
 - 2. Remove nonconductive paint, enamel, or similar coating at threads, contact points, and contact surfaces.
 - 3. Mechanical Connectors: Secure connections using silicone bronze hardware, according to manufacturer's recommended torque settings.
- D. Comply with NEC
 - 1. Article 250 for types, sizes, and quantities of equipment grounding conductors, except where specific types, larger sizes, or more conductors than required by NEC are indicated.
- E. Equipment Grounding Conductor: Provide separate, insulated conductor within each feeder and branch circuit raceway. Terminate each end on suitable lug, bus, or bushing. Comply with NEC Article 250 for types, sizes, and quantities of equipment grounding conductors, except where specific types, larger sizes, or more conductors than required by NEC are indicated.
 - 1. Install equipment grounding conductor with circuit conductors for the items below in addition to those required by Code:
 - a. Feeders and branch circuits.
 - b. Receptacle circuits.
 - c. Single-phase motor or appliance branch circuits.
 - d. Flexible raceway runs.
 - e. Armored and metal-clad cable runs.
- F. Connections
 - 1. General: Make connections so possibility of galvanic action or electrolysis is minimized. Select connectors, connection hardware, conductors, and connection methods so metals in direct contact will be galvanically compatible.
 - 2. Equipment Grounding-Wire Terminations: For No. 8 AWG and larger, use pressure-type grounding lugs, SLUH type as manufactured by Ilsco. No. 10 AWG and smaller grounding conductors may be terminated with winged pressure-type connectors.
 - 3. Non-contact Metal Raceway Terminations: Where metallic raceways terminate at metal housings without mechanical and electrical connection to housing, terminate each conduit with a grounding bushing. Connect grounding bushings with a bare grounding conductor to grounding bus or terminal in housing. Bond electrically noncontinuous conduits at both entrances and exits with grounding bushings and bare grounding conductors, except as otherwise indicated.
 - 4. Tighten screws and bolts for grounding and bonding connectors and terminals according to manufacturer's published torque-tightening values. Where these requirements are not available, use those specified in UL 486A and UL 486B.
 - 5. Irreversible Compression-Type Connections: Use hydraulic compression tools, 14 ton minimum, to provide correct circumferential pressure for compression connectors. Use tools and dies recommended by manufacturer of connectors. Provide embossing die code or other standard method to make a visible indication that a connector has been adequately compressed on grounding conductor. Compression grounding connectors shall be factory filled with oxide inhibitors.
 - 6. Moisture Protection: Where insulated grounding conductors are connected to grounding rods or grounding buses, insulate entire area of connection and seal against moisture penetration of insulation and cable.

3.03 FIELD QUALITY CONTROL

A. Inspect grounding and bonding system conductors and connections for tightness and proper installation.

SECTION 26 05 29 - HANGERS AND SUPPORTS

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Support and attachment requirements and components for equipment, conduit, cable, boxes, and other electrical work.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 33.13 Conduit: Additional support and attachment requirements for conduits.
- B. Section 26 05 33.16 Boxes: Additional support and attachment requirements for boxes.

1.03 REFERENCE STANDARDS

- A. ASTM A123/A123M Standard Specification for Zinc (Hot-Dip Galvanized) Coatings on Iron and Steel Products 2017.
- ASTM A153/A153M Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware 2016a.
- C. ASTM B633 Standard Specification for Electrodeposited Coatings of Zinc on Iron and Steel 2023.
- D. MFMA-4 Metal Framing Standards Publication 2004.
- E. ICC-ES AC01 Acceptance Criteria for Expansion Anchors in Masonry Elements; 2009.
- F. ICC-ES AC193 Acceptance Criteria for Mechanical Anchors in Concrete Elements; 2010
- G. NECA 1 Standard for Good Workmanship in Electrical Construction 2015.
- H. NFPA 70 National Electrical Code Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- I. NFPA 101 Life Safety Code Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- J. UL 5B Strut-Type Channel Raceways and Fittings Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate sizes and arrangement of supports and bases with actual equipment and components to be installed.
 - 2. Coordinate work to provide additional framing and materials required for installation.
 - 3. Coordinate compatibility of support and attachment components with mounting surfaces at installed locations.
 - 4. Notify Architect of conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.

1.05 QUALITY ASSURANCE

- A. Maintain at project site one copy of each referenced document that prescribes execution requirements.
- B. Product Listing Organization Qualifications: Organization recognized by OSHA as Nationally Recognized Testing Laboratory (NRTL) and acceptable to authorities having jurisdiction.

1.06 DELIVERY, STORAGE, AND HANDLING

A. Receive, inspect, handle, and store products in accordance with manufacturer's instructions.

PART 2 PRODUCTS

2.01 SUPPORT AND ATTACHMENT COMPONENTS

- A. General Requirements:
 - 1. Comply with the following. Where requirements differ, comply with most stringent.
 - a. NFPA 70.
 - b. Requirements of authorities having jurisdiction.
 - 2. Provide required hangers, supports, anchors, fasteners, fittings, accessories, and hardware as necessary for complete installation of electrical work.
 - 3. Provide products listed, classified, and labeled as suitable for purpose intended, where applicable.
 - 4. Where support and attachment component types and sizes are not indicated, select in accordance with manufacturer's application criteria as required for the load to be supported with a minimum safety factor of 1.5. Include consideration for vibration, equipment operation, and shock loads where applicable.
 - 5. Do not use products for applications other than as permitted by NFPA 70 and product listing.
 - 6. Do not use wire, chain, perforated pipe strap, wood, or other supports not listed for the application for permanent supports unless specifically indicated or permitted.
 - 7. Steel Components: Use corrosion-resistant materials suitable for environment where installed.
 - a. Indoor Dry Locations: Use zinc-plated steel or approved equivalent unless otherwise indicated.
 - b. Outdoor and Damp or Wet Indoor Locations: Use galvanized steel, stainless steel, or approved equivalent unless otherwise indicated.
 - c. Zinc-Plated Steel: Electroplated in accordance with ASTM B633.
 - d. Galvanized Steel: Hot-dip galvanized after fabrication in accordance with ASTM A123/A123M or ASTM A153/A153M.
- B. Conduit and Cable Supports: Straps and clamps suitable for conduit or cable to be supported.
 - 1. Manufacturers:
 - a. ABB: www.electrification.us.abb.com/#sle.
 - b. Eaton Corporation: www.eaton.com/#sle.
 - c. Emerson Electric Co; O-Z/Gedney: www.emerson.com/#sle.
 - d. HoldRite, a brand of Reliance Worldwide Corporation: www.holdrite.com/#sle.
 - e. nVent; Caddy: www.nvent.com/#sle.
 - f. Or equal.
- C. Conduit Straps: One-hole or two-hole type; steel or malleable iron.
- D. Conduit Clamps: Bolted type unless otherwise indicated.
 - 1. Products:
 - a. Gripple, Inc; Universal Bracket: www.gripple.com/#sle.
 - b. Gripple, Inc; Fast Trak: www.gripple.com/#sle.
 - c. Gripple, Inc; Universal Clamp (Threaded): www.gripple.com/#sle.
 - d. Gripple, Inc; Low Profile Bracket Kits: www.gripple.com/#sle.
 - e. Or Equal.
- E. Outlet Box Supports: Hangers and brackets suitable for boxes to be supported.
 - 1. Manufacturers:
 - a. ABB: www.electrification.us.abb.com/#sle.
 - b. Eaton Corporation: www.eaton.com/#sle.
 - c. Emerson Electric Co; O-Z/Gedney: www.emerson.com/#sle.

- d. HoldRite, a brand of Reliance Worldwide Corporation: www.holdrite.com/#sle.
- e. nVent; Caddy: www.nvent.com/#sle.
- f. Or equal.
- F. Hanger Rods: Threaded, zinc-plated steel unless otherwise indicated.
 - 1. Minimum Size, Unless Otherwise Indicated or Required:
 - a. Equipment Supports: 1/2-inch diameter.
 - b. Single Conduit up to 1-inch (27 mm) Trade Size: 1/4-inch diameter.
 - c. Single Conduit Larger than 1-inch (27 mm) Trade Size: 3/8-inch diameter.
 - d. Trapeze Support for Multiple Conduits: 3/8-inch diameter.
 - e. Outlet Boxes: 1/4-inch diameter.
 - f. Luminaires: 1/4-inch diameter.
- G. Anchors and Fasteners:
 - 1. Manufacturers Mechanical Anchors:
 - a. Dewalt: anchors.dewalt.com/#sle.
 - b. Hilti, Inc: www.hilti.com/#sle.
 - c. ITW Red Head, a division of Illinois Tool Works, Inc: www.itwredhead.com/#sle.
 - d. Simpson Strong-Tie Company Inc: www.strongtie.com/#sle.
 - e. Or equal.
 - 2. Unless otherwise indicated and where not otherwise restricted, use anchor and fastener types indicated for specified applications.
 - 3. Concrete: Use preset concrete inserts, expansion anchors, or screw anchors.
 - 4. Solid or Grout-Filled Masonry: Use expansion anchors or screw anchors.
 - 5. Hollow Masonry: Use toggle bolts.
 - 6. Hollow Stud Walls: Use toggle bolts.
 - 7. Steel: Use beam clamps, machine bolts, or welded threaded studs.
 - 8. Sheet Metal: Use sheet metal screws.
 - 9. Wood: Use wood screws.
 - 10. Plastic and lead anchors are not permitted.
 - 11. Powder-actuated fasteners are not permitted.
 - 12. Hammer-driven anchors and fasteners are permitted only as follows:
 - a. Nails are permitted for attachment of nonmetallic boxes to wood frame construction.
 - b. Staples are permitted for attachment of nonmetallic-sheathed cable to wood frame construction.
 - 13. Preset Concrete Inserts: Continuous metal channel/strut and spot inserts specifically designed to be cast in concrete ceilings, walls, and floors.
 - a. Manufacturer: Same as manufacturer of metal channel/strut framing system.
 - b. Comply with MFMA-4.
 - c. Channel Material: Use galvanized steel.
 - d. Minimum Channel Thickness: Steel sheet, 12 gauge, 0.1046 inch minimum base metal thickness.
 - 14. Post-Installed Concrete and Masonry Anchors: Evaluated and recognized by ICC Evaluation Service, LLC (ICC-ES) for compliance with applicable building code.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that mounting surfaces are ready to receive support and attachment components.
- C. Verify that conditions are satisfactory for installation prior to starting work.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Install hangers and supports in accordance with NECA 1.
- C. Install anchors and fasteners in accordance with ICC Evaluation Services, LLC (ICC-ES) evaluation report conditions of use where applicable.
- D. Provide independent support from building structure. Do not provide support from piping, ductwork, or other systems.
- E. Unless specifically indicated or approved by Architect, do not provide support from suspended ceiling support system or ceiling grid.
- F. Unless specifically indicated or approved by Architect, do not provide support from roof deck.
- G. Do not penetrate or otherwise notch or cut structural members without approval of Structural Engineer.
- H. Field Welding, Where Approved by Architect: See Section 05 50 00.
- I. Equipment Support and Attachment:
 - 1. Use metal, fabricated supports or supports assembled from metal channel/strut to support equipment as required.
 - 2. Use metal channel/strut secured to studs to support equipment surface mounted on hollow stud walls when wall strength is not sufficient to resist pull-out.
 - 3. Use metal channel/strut to support surface-mounted equipment in wet or damp locations to provide space between equipment and mounting surface.
 - 4. Unless otherwise indicated, mount floor-mounted equipment on properly sized concrete pad 3 inches in height; see Section 03 30 00.
 - 5. Securely fasten floor-mounted equipment. Do not install equipment such that it relies on its own weight for support.
- J. Conduit Support and Attachment: See Section 26 05 33.13 for additional requirements.
- K. Box Support and Attachment: See Section 26 05 33.16 for additional requirements.
- L. Preset Concrete Inserts: Use manufacturer provided closure strips to inhibit concrete seepage during concrete pour.
- M. Secure fasteners in accordance with manufacturer's recommended torque settings.
- N. Remove temporary supports.
- O. Identify independent electrical component support wires above accessible ceilings, where permitted, with color distinguishable from ceiling support wires in accordance with NFPA 70.

3.03 FIELD QUALITY CONTROL

- A. Inspect support and attachment components for damage and defects.
- B. Repair cuts and abrasions in galvanized finishes using zinc-rich paint recommended by manufacturer. Replace components that exhibit signs of corrosion.
- C. Correct deficiencies and replace damaged or defective support and attachment components.

D. Install hangers and supports as required to adequately and securely support electrical system components, in a neat and workmanlike manner, as specified in NECA 1. Size metal framing system as required for the application and structural requirements.

SECTION 26 05 33.13 - CONDUIT

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Flexible metal conduit (FMC).
- B. Galvanized steel electrical metallic tubing (EMT).
- C. Conduit, fittings and conduit bodies.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 19 Low Voltage Wiring.
- B. Section 26 05 26 Grounding and Bonding.
 1. Includes additional requirements for fittings for grounding and bonding.
- C. Section 26 05 29 Hangers and Supports.
- D. Section 26 05 33.16 Boxes.
- E. Section 26 05 53 Electrical Identification: Identification products and requirements.

1.03 REFERENCE STANDARDS

- A. ANSI C80.1 American National Standard for Electrical Rigid Steel Conduit (ERSC) 2020.
- B. ANSI C80.3 American National Standard for Electrical Metallic Tubing -- Steel (EMT-S) 2020.
- C. ASTM D1598 Standard Test Methods for Time-to-Failure of Plastic Pipe Under Constant Internal Pressure 2021.
- D. ASTM D1599 Standard Test Method for Resistance to Short-Time Hydraulic Pressure of Plastic Pipe, Tubing, and Fittings 2018.
- E. NECA 1 Standard for Good Workmanship in Electrical Construction 2015.
- F. NECA 101 Standard for Installing Steel Conduits (Rigid, IMC, EMT) 2020.
- G. NECA 111 Standard for Installing Nonmetallic Raceways (RNC, ENT, LFNC) 2017.
- H. NEMA FB 1 Fittings, Cast Metal Boxes, and Conduit Bodies for Conduit, Electrical Metallic Tubing, and Cable 2014.
- I. NEMA TC 2 Electrical Polyvinyl Chloride (PVC) Conduit 2020.
- J. NEMA TC 3 Polyvinyl Chloride (PVC) Fittings for Use with Rigid PVC Conduit and Tubing 2021.
- K. NFPA 70 National Electrical Code Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- L. UL 1 Flexible Metal Conduit Current Edition, Including All Revisions.
- M. UL 360 Liquid-Tight Flexible Metal Conduit Current Edition, Including All Revisions.
- N. UL 514A Metallic Outlet Boxes Current Edition, Including All Revisions.
- O. UL 514B Conduit, Tubing, and Cable Fittings Current Edition, Including All Revisions.
- P. UL 651 Schedule 40, 80, Type EB and A Rigid PVC Conduit and Fittings Current Edition, Including All Revisions.
- Q. UL 797 Electrical Metallic Tubing-Steel Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate minimum sizes of conduits with actual type and quantity of conductors to be installed, including adjustments for conductor sizes increased for voltage drop.
 - 2. Coordinate arrangement of conduits with structural members, ductwork, piping, equipment, and other potential conflicts.
 - 3. Verify exact conduit termination locations required for boxes, enclosures, and equipment.
 - 4. Coordinate work to provide roof penetrations that preserve integrity of roofing system and do not void roof warranty.
 - 5. Notify Architect of conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.

B. Sequencing:

1. Do not begin installation of conductors and cables until installation of conduit between termination points is complete.

1.05 QUALITY ASSURANCE

A. Products: Listed and classified by Underwriters Laboratories Inc. as suitable for purpose specified and shown.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Receive, inspect, handle, and store conduit and fittings in accordance with manufacturer's instructions.
- B. Protect conduit from corrosion and entrance of debris by storing above grade. Provide appropriate covering.

1.07 DESIGN REQUIREMENTS

A. Conduit Size: ANSI/NFPA 70 or as indicated on Drawings, whichever is larger.

PART 2 PRODUCTS

2.01 CONDUIT APPLICATIONS

- A. Do not use conduit and associated fittings for applications other than as permitted by NFPA 70, manufacturer's instructions, and product listing.
- B. Concealed Within Hollow Stud Walls: Use electrical metallic tubing (EMT).
- C. Concealed Above Accessible Ceilings: Use electrical metallic tubing (EMT).
- D. Exposed, Interior, use electrical metallic tubing (EMT).
- E. Flexible Connections to Vibrating Equipment:
 - 1. Dry Locations: Use flexible metal conduit (FMC).
 - 2. Maximum Length: 6 feet unless otherwise indicated.
 - Vibrating equipment includes, but is not limited to:
 a. Motors.
- F. Fished in Existing Walls, Where Necessary: Use flexible metal conduit (FMC).

2.02 CONDUIT - GENERAL REQUIREMENTS

- A. Comply with NFPA 70.
- B. Existing Work: Where existing conduits are indicated to be reused, they may be reused only where they comply with specified requirements, are free from corrosion, and integrity is verified by pulling mandrel

through them.

- C. Communications Systems Conduits: Also comply with Section 27 10 05.
- D. Fittings for Grounding and Bonding: See Section 26 05 26 for additional requirements.
- E. Provide conduit, fittings, supports, and accessories required for complete raceway system.
- F. Provide products listed, classified, and labeled as suitable for purpose intended.
- G. Minimum Conduit Size, Unless Otherwise Indicated:
 - 1. Branch Circuits: 3/4-inch trade size.
 - 2. Branch Circuit Homeruns: 3/4-inch trade size.
 - 3. Control Circuits: 1/2-inch trade size.
- H. Where conduit size is not indicated, size to comply with NFPA 70 but not less than applicable minimum size requirements specified.

2.03 FLEXIBLE METAL CONDUIT (FMC)

- A. Manufacturers:
 - 1. AFC Cable Systems, Inc: www.afcweb.com.
 - 2. Electri-Flex Company: www.electriflex.com.
 - 3. International Metal Hose: www.metalhose.com.
 - 4. Or Equal.
- B. Description: NFPA 70, Type FMC standard-wall steel flexible metal conduit listed and labeled as complying with UL 1, and listed for use in classified firestop systems.
- C. Fittings:
 - 1. Manufacturers:
 - a. ABB; T&B: www.electrification.us.abb.com/#sle.
 - b. Bridgeport Fittings, LLC: www.bptfittings.com/#sle.
 - c. Emerson Electric Co; O-Z/Gedney: www.emerson.com/#sle.
 - d. Or Equal.
 - Description: Fittings complying with NEMA FB 1 and listed and labeled as complying with UL 514B.
 - 3. Material: Use steel or malleable iron.
 - a. Do not use die cast zinc fittings.
- D. Description: Interlocked steel construction.
- E. Fittings: NEMA FB 1.

2.04 LIQUIDTIGHT FLEXIBLE METAL CONDUIT (LFMC)

- A. Manufacturers:
 - 1. AFC Cable Systems, Inc: www.afcweb.com.
 - 2. Electri-Flex Company: www.electriflex.com.
 - 3. International Metal Hose: www.metalhose.com.
 - 4. Or Equal.
- B. Description: NFPA 70, Type LFMC polyvinyl chloride (PVC) jacketed steel flexible metal conduit listed and labeled as complying with UL 360.
- C. Fittings:
 - 1. Manufacturers:
 - a. ABB; T&B: www.electrification.us.abb.com/#sle.
 - b. Bridgeport Fittings, LLC: www.bptfittings.com/#sle.
 - c. Emerson Electric Co; O-Z/Gedney: www.emerson.com/#sle.

- d. Or Equal.
- Description: Fittings complying with NEMA FB 1 and listed and labeled as complying with UL 514B.
- Material: Use steel or malleable iron.
 a. Do not use die cast zinc fittings.
- D. Description: Interlocked steel construction with PVC jacket.
- E. Fittings: NEMA FB 1. Rain tight compression ring steel fitting. Connectors with insulated throat.

2.05 GALVANIZED STEEL ELECTRICAL METALLIC TUBING (EMT)

- A. Manufacturers:
 - 1. Allied Tube & Conduit: www.alliedeg.com.
 - 2. Nucor Tubular Products: www.nucortubular/#sle.
 - 3. Western Tube, a division of Zekelman Industries: www.westerntube.com/#sle.
 - 4. Wheatland Tube Company: www.wheatland.com.
 - 5. Or Equal.
- B. Description: NFPA 70, Type EMT galvanized steel electrical metallic tubing complying with ANSI C80.3 and listed and labeled as complying with UL 797.
- C. Fittings:
 - 1. Manufacturers:
 - a. ABB; T&B: www.electrification.us.abb.com/#sle.
 - b. Allied Tube & Conduit, a division of Atkore International: www.alliedeg.us/#sle.
 - c. Bridgeport Fittings, LLC: www.bptfittings.com/#sle.
 - d. Emerson Electric Co; O-Z/Gedney: www.emerson.com/#sle.
 - 2. Description: Fittings complying with NEMA FB 1 and listed and labeled as complying with UL 514B.
 - 3. Material: Use steel or malleable iron.
 - a. Do not use die cast zinc fittings.
 - 4. Connectors and Couplings: Use compression/gland or set-screw type. Insulated Throat.a. Do not use indenter type connectors and couplings.
 - 5. Damp or Wet Locations, Where Permitted: Use fittings listed for use in wet locations.
 - 6. Embedded Within Concrete, Where Permitted: Use fittings listed as concrete-tight. Fittings that require taping to be concrete-tight are acceptable.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that mounting surfaces are ready to receive conduits.
- C. Verify that conditions are satisfactory for installation prior to starting work.
- D. Verify routing and termination locations of conduit prior to rough-in.
- E. Conduit routing is shown on drawings in approximate locations unless dimensioned. Route as required to complete wiring system.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Install conduit in accordance with NECA 1.
- C. Conduit Routing:

- 1. Unless dimensioned, conduit routing indicated is diagrammatic.
- 2. When conduit destination is indicated without specific routing, determine exact routing required.
- 3. Conceal conduits unless specifically indicated to be exposed.
- 4. Conduits in the following areas may be exposed, unless otherwise indicated:
 - a. Electrical rooms.
 - b. Mechanical equipment rooms.
 - c. Within joists in areas with no ceiling.
- 5. Unless otherwise approved, do not route exposed conduits:
 - a. Across building exterior surfaces.
 - b. In any finished areas.
- 6. Arrange conduit to maintain adequate headroom, clearances, and access.
- 7. Arrange conduit to provide no more than equivalent of four 90-degree bends between pull points.
- 8. Arrange conduit to provide no more than 150 feet between pull points.
- 9. Maintain minimum clearance of 6 inches between conduits and piping for other systems.
- D. Conduit Support:
 - 1. Secure and support conduits in accordance with NFPA 70 using suitable supports and methods approved by authorities having jurisdiction; see Section 26 05 29.
 - 2. Provide independent support from building structure. Do not provide support from piping, ductwork, or other systems.
 - 3. Installation Above Suspended Ceilings: Do not provide support from ceiling support system. Do not provide support from ceiling grid or allow conduits to lay on ceiling tiles.
 - 4. Use conduit strap to support single surface-mounted conduit.
 - a. Use clamp back spacer with conduit strap for damp and wet locations to provide space between conduit and mounting surface.
 - 5. Use metal channel/strut with accessory conduit clamps to support multiple parallel surfacemounted conduits.
 - 6. Use conduit clamp to support single conduit from beam clamp or threaded rod.
 - 7. Use trapeze hangers assembled from threaded rods and metal channel/strut with accessory conduit clamps to support multiple parallel suspended conduits.
 - 8. Use of spring steel conduit clips for support of conduits is not permitted.
 - a. Support of electrical metallic tubing (EMT) up to 1-inch (27 mm) trade size concealed above accessible ceilings and within hollow stud walls.
 - 9. Use of wire for support of conduits is not permitted.
 - 10. Where conduit support intervals specified in NFPA 70 and NECA standards differ, comply with most stringent requirements.
- E. Connections and Terminations:
 - 1. Provide insulating bushings, insulated throats, or listed metal fittings with smooth, rounded edges at conduit terminations to protect conductors.
 - 2. Secure joints and connections to provide mechanical strength and electrical continuity.
- F. Penetrations:
 - 1. Do not penetrate or otherwise notch or cut structural members, including footings and grade beams, without approval of Structural Engineer.
 - 2. Make penetrations perpendicular to surfaces unless otherwise indicated.
 - 3. Provide sleeves for penetrations as indicated or as required to facilitate installation. Set sleeves flush with exposed surfaces unless otherwise indicated or required.
- G. Provide grounding and bonding; see Section 26 05 26.

3.03 FIELD QUALITY CONTROL

A. Correct deficiencies and replace damaged or defective conduits.

3.04 CLEANING

A. Clean interior of conduits to remove moisture and foreign matter.

3.05 PROTECTION

- A. Immediately after installation of conduit, use suitable manufactured plugs to provide protection from entry of moisture and foreign material and do not remove until ready for installation of conductors.
- B. All conduit in finished areas shall be installed concealed in walls, floors or ceilings unless noted otherwise on the drawings. Unfinished areas are considered mechanical rooms, electrical rooms and utility spaces only.
- C. Route exposed conduit parallel and perpendicular to walls.
- D. Route conduit installed above accessible ceilings parallel and perpendicular to walls.
- E. Route conduit continuous from outlet to outlet, outlet to cabinets, outlet to pull or junction boxes. Secure conduit to all boxes with locknuts and bushings in such manner that each system is mechanically and electrically continuous throughout.
- F. Install all conduit within the building except where specifically noted or shown otherwise on the drawings.
- G. Conduit systems must be installed complete before conductors are pulled in.
- H. Repair any damage done to insulation or interior vapor barrier.
- I. Fill conduits which can admit air to or release air from air plenums through the connecting conduit system with sealing compound.
- J. Seal around all conduits passing through partitions such as walls, floor slabs and other elements. For non-rated partitions, sealant to match surrounding surface. For rated partitions, provide fireproofing sealant which preserves the fire resistant rating of the partition. Use materials and methods as directed by the manufacturer of the fireproofing and approved by the Architect/Engineer. See Architectural drawings and existing building drawings for location of new and existing fire-rated partitions.

SECTION 26 05 33.16 - BOXES

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Outlet and device boxes up to 100 cubic inches, including those used as junction and pull boxes.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 26 Grounding and Bonding.
- B. Section 26 05 29 Hangers and Supports.
- C. Section 26 05 33.13 Conduit:
 - 1. Conduit bodies and other fittings.
 - 2. Additional requirements for locating boxes to limit conduit length and/or number of bends between pulling points.
- D. Section 26 05 53 Electrical Identification: Identification products and requirements.

1.03 REFERENCE STANDARDS

- A. NECA 1 Standard for Good Workmanship in Electrical Construction 2015.
- B. NECA 130 Standard for Installing and Maintaining Wiring Devices 2016.
- C. NEMA OS 1 Sheet-Steel Outlet Boxes, Device Boxes, Covers, and Box Supports 2013 (Reaffirmed 2020).
- D. NFPA 70 National Electrical Code Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- E. UL 514A Metallic Outlet Boxes Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate the work with other trades to avoid placement of ductwork, piping, equipment, or other potential obstructions within the dedicated equipment spaces and working clearances for electrical equipment required by NFPA 70.
 - 2. Coordinate arrangement of electrical equipment with the dimensions and clearance requirements of the actual equipment to be installed.
 - 3. Coordinate minimum sizes of boxes with the actual installed arrangement of conductors, clamps, support fittings, and devices, calculated according to NFPA 70.
 - 4. Coordinate minimum sizes of pull boxes with the actual installed arrangement of connected conduits, calculated according to NFPA 70.
 - 5. Coordinate the placement of boxes with millwork, furniture, devices, equipment, etc. installed under other sections or by others.
 - 6. Coordinate the work with other trades to preserve insulation integrity.
 - 7. Coordinate the work with other trades to provide walls suitable for installation of flush-mounted boxes where indicated.
 - 8. Notify Architect of any conflicts with or deviations from Contract Documents. Obtain direction before proceeding with work.

1.05 QUALITY ASSURANCE

A. Comply with requirements of NFPA 70.

1.06 DELIVERY, STORAGE, AND HANDLING

A. Receive, inspect, handle, and store products in accordance with manufacturer's instructions.

PART 2 PRODUCTS

2.01 BOXES

- A. General Requirements:
 - 1. Do not use boxes and associated accessories for applications other than as permitted by NFPA 70 and product listing.
 - 2. Provide all boxes, fittings, supports, and accessories required for a complete raceway system and to accommodate devices and equipment to be installed.
 - 3. Provide products listed, classified, and labeled as suitable for the purpose intended.
 - 4. Where box size is not indicated, size to comply with NFPA 70 but not less than applicable minimum size requirements specified.
 - 5. Provide grounding terminals within boxes where equipment grounding conductors terminate.
- B. Outlet and Device Boxes Up to 100 cubic inches, Including Those Used as Junction and Pull Boxes:
 - 1. Use sheet-steel boxes for dry locations unless otherwise indicated or required.
 - 2. Use raised covers suitable for the type of wall construction and device configuration where required.
 - 3. Sheet-Steel Boxes: Comply with NEMA OS 1, and list and label as complying with UL 514A.
 - 4. Minimum Box Size, Unless Otherwise Indicated:
 - a. Wiring Devices: 4 inch square by 1-1/2 inch deep (100 by 38 mm) trade size.
 - b. Communications Systems Outlets in sheetrock walls or in ceiling applications: 4 inch square by 2-1/8 inch (100 by 54 mm) trade size. See section 27 1005 for further requirements.
 - 5. Ceiling Outlets: 4 inch octagonal or square by 1-1/2 inch deep (100 by 38 mm) trade size.
 - 6. Manufacturers:
 - a. Cooper Crouse-Hinds, a division of Eaton Corporation: www.cooperindustries.com/#sle.
 - b. Hubbell Incorporated; Bell Products: www.hubbell-rtb.com.
 - c. Hubbell Incorporated; RACO Products: www.hubbell-rtb.com.
 - d. O-Z/Gedney, a brand of Emerson Electric Co: www.emerson.com.
 - e. Thomas & Betts Corporations Member of the ABB Group: www.tnb.com.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Verify that field measurements are as indicated.
- B. Verify that mounting surfaces are ready to receive boxes.
- C. Verify that conditions are satisfactory for installation prior to starting work.
- D. Verify locations of floor boxes and outlets in offices and work areas prior to rough-in.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Install boxes in accordance with NECA 1 (general workmanship) and, where applicable, NECA 130, including mounting heights specified in those standards where mounting heights are not indicated.
- C. Arrange equipment to provide minimum clearances in accordance with manufacturer's instructions and NFPA 70.
- D. Provide separate boxes for emergency power and normal power systems.

- E. Unless otherwise indicated, provide separate boxes for line voltage and low voltage systems.
- F. Flush-mount boxes in finished areas unless specifically indicated to be surface-mounted.
- G. Unless otherwise indicated, boxes may be surface-mounted where exposed conduits are indicated or permitted.
- H. Box Locations:
 - 1. Unless dimensioned, box locations indicated are approximate.
 - 2. Locate boxes as required for devices installed under other sections or by others.
 - 3. Locate junction and pull boxes as indicated, as required to facilitate installation of conductors, and to limit conduit length and/or number of bends between pulling points in accordance with Section 26 05 33.13.
 - 4. Locate junction and pull boxes in the following areas, unless otherwise indicated or approved by the Architect:
 - a. Concealed above accessible suspended ceilings.
 - b. Within joists in areas with no ceiling.
 - c. Electrical rooms.
 - d. Mechanical equipment rooms.
- I. Box Supports:
 - 1. Secure and support boxes in accordance with NFPA 70 and Section 26 05 29 using suitable supports and methods approved by the authority having jurisdiction.
 - 2. Provide independent support from building structure except for cast metal boxes (other than boxes used for fixture support) supported by threaded conduit connections in accordance with NFPA 70. Do not provide support from piping, ductwork, or other systems.
 - 3. Installation Above Suspended Ceilings: Do not provide support from ceiling grid or ceiling support system.
- J. Install boxes plumb and level.
- K. Close unused box openings.
- L. Install blank wall plates on junction boxes and on outlet boxes with no devices or equipment installed or designated for future use.
- M. Provide grounding and bonding in accordance with Section 26 05 26.
- N. All boxes shall be installed flush in finished spaces unless noted otherwise. Unfinished spaces include mechanical, electrical and utility rooms only.
- O. Install boxes securely, in a neat and workmanlike manner, as specified in NECA 1.
- P. Install in locations as shown on Drawings, and as required for splices, taps, wire pulling, equipment connections, and as required by NFPA 70.
- Q. Maintain headroom and present neat mechanical appearance.
- R. Install pull boxes and junction boxes above accessible ceilings and in unfinished areas only.
- S. Inaccessible Ceiling Areas: Install outlet and junction boxes no more than 6 inches from ceiling access panel or from removable recessed luminaire.
- T. Coordinate mounting heights and locations of outlets mounted above counters, benches, and backsplashes and mechanical radiation.
- U. Use surface mounted 4-inch square box with matching raised cover on exposed conduit runs.
- V. Use 4-inch square, 1-1/2 inch deep box with round tile ring in ceiling.
- W. Use gang box with plaster ring for single device outlets.

- X. Surface mounted outlets are permitted only in mechanical and electrical rooms and above removable ceilings.
- Y. Locate outlets to clear piping, duct work and other obstructions.
- Z. All outlet boxes noted as WP shall be flush mounted with a sheet metal box. See section 26 27 26 for covers and devices.
- AA. Pull boxes and junction boxes are not indicated on Drawings except for special requirements. Install as required to facilitate pulling wire. Size as required by National Electric Code. Install above removable ceilings, electrical rooms, utility rooms or storage areas in accessible locations. Installation in finished spaces not permitted without approval of the Architect/Engineer.
- BB. Do not mount junction boxes or pull boxes to duct work, ceiling system or other piping. Mount from structural system only. Mount independent of conduit system. Junction boxes supported only from conduit system will not be permitted.
- CC. Label all junction box covers with panelboard name and circuit numbers for circuits in junction box.Label all junction box covers with the type of communication system contained within; example: "Nurse Call," "Security," etc. See section 26 0553 Electrical Identification.

3.03 ADJUSTING

- A. Adjust flush-mounting outlets to make front flush with finished wall material.
- B. Install knockout closures in unused box openings.

3.04 CLEANING

A. Clean interior of boxes to remove dirt, debris, plaster and other foreign material.

3.05 PROTECTION

A. Immediately after installation, protect boxes from entry of moisture and foreign material until ready for installation of conductors.

SECTION 26 05 53 - ELECTRICAL IDENTIFICATION

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Electrical identification requirements.
- B. Device and Junction Box Labels
- C. Wire and cable markers.

1.02 RELATED REQUIREMENTS

- A. Section 26 05 19 Low Voltage Wiring: Color coding for power conductors and cables 600 V and less; vinyl color coding electrical tape.
- B. Section 27 10 05 Telecommunications Cabling: Identification for communications cabling and devices.

1.03 REFERENCE STANDARDS

- A. ANSI Z535.2 American National Standard for Environmental and Facility Safety Signs 2011 (Reaffirmed 2017).
- B. ANSI Z535.4 American National Standard for Product Safety Signs and Labels 2011 (Reaffirmed 2017).
- C. NFPA 70 National Electrical Code Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- D. NFPA 70E Standard for Electrical Safety in the Workplace 2021.
- E. UL 969 Marking and Labeling Systems Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Verify final designations for equipment, systems, and components to be identified prior to fabrication of identification products.
- B. Sequencing:
 - 1. Do not conceal items to be identified, in locations such as above suspended ceilings, until identification products have been installed.
 - 2. Do not install identification products until final surface finishes and painting are complete.

1.05 QUALITY ASSURANCE

A. Comply with requirements of NFPA 70.

1.06 FIELD CONDITIONS

- A. Do not install adhesive products when ambient temperature is lower than recommended by manufacturer.
- B. Products: Listed and classified by Underwriters Laboratories Inc. as suitable for purpose specified and shown.
PART 2 PRODUCTS

2.01 IDENTIFICATION REQUIREMENTS

- A. Existing Work: Unless specifically excluded, identify existing elements to remain that are not already identified in accordance with specified requirements.
- B. Identification for Equipment:
 - 1. Use identification nameplate to identify each piece of electrical distribution and control equipment and associated sections, compartments, and components.
 - a. Panelboards:
 - Use typewritten circuit directory to identify load(s) served for panelboards with a door. Identify spares and spaces using pencil.
 - 2. Use identification nameplate to identify disconnect location for equipment with remote disconnecting means.
- C. Identification for Conductors and Cables:
 - 1. Color Coding for Power Conductors 600 V and Less: Comply with Section 26 05 19.
 - 2. Identification for Communications Conductors and Cables: Comply with Section 27 10 05.
 - 3. Use identification nameplate or identification label to identify color code for ungrounded and grounded power conductors inside door or enclosure at each piece of feeder or branch-circuit distribution equipment when premises has feeders or branch circuits served by more than one nominal voltage system.
- D. Identification for Boxes:
 - Use identification labels or handwritten text using indelible marker to identify circuits enclosed.
 a. For exposed boxes in public areas, provide identification on inside face of cover.
- E. Identification for Devices:
 - 1. Identification for Communications Devices: Comply with Section 27 10 05.
 - 2. Communications Systems: Use identification label to indicate system contained within, 'Nurse Call', 'Television', etc.
 - 3. Use identification label or engraved wallplate to identify load controlled for wall-mounted control devices controlling loads that are not visible from the control location and for multiple wall-mounted control devices installed at one location.

2.02 MANUFACTURERS

- A. Brady Corporation: www.bradycorp.com.
- B. Seton Identification Products: www.seton.com/aec.
- C. HellermannTyton: www.hellermanntyton.com.
- D. Or Equal.

2.03 IDENTIFICATION NAMEPLATES AND LABELS

- A. Identification Labels:
 - 1. Use for devices, control switches and other small controllers.
 - 2. Manufacturers:
 - a. Brady Corporation: www.bradyid.com.
 - b. Brother International Corporation: www.brother-usa.com/#sle.
 - c. Panduit Corp: www.panduit.com/#sle.
 - d. Or Equal.
 - 3. Materials: Use self-adhesive laminated plastic labels; UV, chemical, water, heat, and abrasion resistant.

- a. Use only for indoor locations.
- 4. Text: Use factory pre-printed or machine-printed text. Do not use handwritten text unless otherwise indicated.
- B. Format for Control Device Identification Labels:
 - 1. Minimum Size: 3/8 inch by 1.5 inches.
 - 2. Legend: Load controlled or other designation indicated.
 - 3. Text: All capitalized unless otherwise indicated.
 - 4. Minimum Text Height: 3/16 inch.
 - 5. Color: Black text on clear background.

PART 3 EXECUTION

3.01 PREPARATION

- A. Clean surfaces to receive adhesive products according to manufacturer's instructions.
- B. Degrease and clean surfaces to receive nameplates and labels.

3.02 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Install identification products to be plainly visible for examination, adjustment, servicing, and maintenance. Unless otherwise indicated, locate products as follows:
 - 1. Boxes: Outside face of cover.
 - 2. Conductors and Cables: Legible from the point of access.
 - 3. Devices: Outside face of cover.
- C. Install identification products centered, level, and parallel with lines of item being identified.
- D. Install self-adhesive labels and markers to achieve maximum adhesion, with no bubbles or wrinkles and edges properly sealed.
- E. Mark all handwritten text, where permitted, to be neat and legible.

3.03 FIELD QUALITY CONTROL

- A. Replace self-adhesive labels and markers that exhibit bubbles, wrinkles, curling or other signs of improper adhesion.
- B. Provide self-adhesive labels on all receptacles by identifying the panel name and circuit number, example: H1-24.
- C. Provide self-adhesive labels on all junction box covers to identify the circuits contained within for all power circuits or the system contained within for all communications systems. Example: 'Panel L1, Ckt 11' or 'Paging System'.

END OF SECTION

SECTION 27 10 05 - TELECOMMUNICATIONS CABLING

PART 1 GENERAL

1.01 SECTION INCLUDES

- A. Copper cable and terminations.
- B. Communications identification.
- C. Cabling and pathways inside building(s).

1.02 RELATED REQUIREMENTS

- A. Section 26 05 26 Grounding and Bonding.
 - 1. Includes bonding jumpers for bonding of communications systems and electrical system grounding.
- B. Section 26 05 33.13 Conduit.
- C. Section 26 05 33.16 Boxes.
- D. Section 26 05 53 Electrical Identification: Identification products.

1.03 REFERENCE STANDARDS

- A. NFPA 70 National Electrical Code Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- TIA-455-21 FOTP-21 Mating Durability of Fiber Optic Interconnecting Devices 1988a (Reaffirmed 2012).
- C. TIA-492AAAD Detail Specification for 850-nm Laser- Optimized, 50-μm Core Diameter/125-μm Cladding Diameter Class la Graded-Index Multimode Optical Fibers Suitable for Manufacturing OM4 Cabled Optical Fiber 2009.
- D. TIA-492AAAC-B Detail Specification for 850-nm Laser-Optimized, 50-um Core Diameter/125-um Cladding Diameter Class Ia Graded-Index Multimode Optical Fibers 2009b.
- E. TIA-492AAAB-A Detail Specification for 50-um Core Diameter/125-um Cladding Diameter Class Ia Graded-Index Multimode Optical Fibers 2009a.
- F. TIA-492AAAA-B Detail Specification for 62.5-um Core Diameter/125-um Cladding Diameter Class Ia Graded-Index Multimode Optical Fibers 2009b.
- G. TIA-492CAAB Detail Specification for Class IVa Dispersion-Unshifted Single-Mode Optical Fibers with Low Water Peak 2000 (Reaffirmed 2005).
- H. TIA-492CAAA Detail Specification for Class IVa Dispersion-Unshifted Single-Mode Optical Fibers 1998 (Reaffirmed 2002).
- I. EIA/ECA-310 Cabinets, Racks, Panels, and Associated Equipment; Electronic Industries Alliance/Electrical Components Association; Revision E, 2005.
- J. ICEA S-83-596 Indoor Optical Fiber Cables; Insulated Cable Engineers Association; 2011 (ANSI/ICEA S-83-596).
- K. NECA/BICSI 568 Standard for Installing Building Telecommunications Cabling; National Electrical Contractors Association; 2006. (ANSI/NECA/BICSI 568)

- L. NFPA 70 National Electrical Code; Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- M. TIA-526-14 OFSTP-14 Optical Power Loss Measurements of Installed Multimode Fiber Cable Plant; Telecommunications Industry Association; Rev B, 2010.
- N. TIA-568 (SET) Commercial Building Telecommunications Cabling Standard Set; 2015
- O. TIA-568-C.2 Commercial Building Telecommunications Cabling Standard Part 2: Balanced Twisted Pair Cabling Components; Telecommunications Industry Association; Rev C, 2009.
- P. TIA-568-C.3 Optical Fiber Cabling Components Standard; Telecommunications Industry Association; 2008 (with Addenda; 2011).
- Q. TIA/EIA-568-B.3 Commercial Building Telecommunications Cabling Standard Part 3: Optical Fiber Cabling Components Standard, and Addendum 1 - Additional Transmission Performance Specifications for 50/125 um Optical Fiber Cables; Rev B, 2000; Addendum 1.
- R. TIA-569-C Telecommunications Pathways and Spaces; Telecommunications Industry Association; Rev C, 2012 (with Addenda; 2013).
- S. TIA-598-C Optical Fiber Cable Color Coding; Telecommunications Industry Association; Rev C, 2005.
- T. TIA-606-B Administration Standard for the Telecommunications Infrastructure; Telecommunications Industry Association; Rev B, 2012.
- U. TIA-607-B Generic Telecommunications Bonding and Grounding (Earthing) for Customer Premises; Telecommunications Industry Association; Rev B, 2012 (with Addenda; 2013).
- V. ANSI/J-STD-607 Commercial Building Grounding (Earthing) and Bonding Requirements for Telecommunications; Rev A, 2002.
- W. UL 497 Standard for Protectors for Paired-Conductor Communications Circuits; Current Edition, Including All Revisions.
- X. UL 1863 Communications-Circuit Accessories; Current Edition, Including All Revisions.

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination:
 - 1. Coordinate arrangement of communications equipment with the dimensions and clearance requirements of the actual equipment to be installed.
 - 2. Notify Architect of any conflicts with or deviations from the contract documents. Obtain direction before proceeding with work.

1.05 SUBMITTALS

- A. See Section 01 30 00 Administrative Requirements, for submittal procedures.
- B. Product Data: Provide manufacturer's standard catalog pages and data sheets for each product.
 - 1. Storage and handling requirements and recommendations.
 - 2. Installation methods.
- C. Manufacturer Qualifications.
- D. Field Test Reports.
- E. Operation and Maintenance Data: List of all components with part numbers, sources of supply, and operation and maintenance instructions; include copy of project record documents.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: At least 3 years experience manufacturing products of the type specified.
- B. Installer Qualifications: A company having at least 3 years experience in the installation and testing of the type of system specified, and:
 - 1. Supervisors and installers factory certified by manufacturers of products to be installed.
 - 2. Employing experienced technicians for all work; show at least 3 years experience in the installation of the type of system specified, with evidence from at least 2 projects that have been in use for at least 18 months; submit project name, address, and written certification by user.
- C. Products: Listed, classified, and labeled as suitable for the purpose intended.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.
- B. Keep stored products clean and dry.

1.08 WARRANTY

- A. See Section 01 78 00 Closeout Submittals, for additional warranty requirements.
- B. Correct defective Work within a 1 year period after Date of Substantial Completion.
- C. Manufacturer shall warranty and provide maintenance service for 15 years minimum on the network system and a lifetime for products used in the system.

PART 2 PRODUCTS

2.01 SYSTEM DESIGN

- A. Provide a complete permanent system of cabling and pathways for voice and data communications, including cables, conduits and wireways, pull wires, support structures, enclosures and cabinets, and outlets.
 - 1. Comply with TIA-568 (cabling) and TIA-569 (pathways), latest editions (commercial standards).
 - 2. Provide fixed cables and pathways that comply with NFPA 70 and TIA-607 and are UL listed or third party independent testing laboratory certified.
 - 3. Provide connection devices that are rated for operation under conditions of 32 to 140 degrees F at relative humidity of 0 to 95 percent, noncondensing.
 - 4. In this project, the term plenum is defined as return air spaces above ceilings, inside ducts, under raised floors, and other air-handling spaces.
- B. System Description:
 - 1. Horizontal Cabling: Copper.

2.02 PATHWAYS

- A. Conduit: As specified in Section 26 05 33.13; provide pull cords in all conduit.
- B. Outlets
 - 1. As specified in Section 26 05 33.16- Boxes.

2.03 COPPER CABLE AND TERMINATIONS

A. Copper Horizontal Cable: TIA/EIA-568 Category 6 solid conductor unshielded twisted pair (UTP), 24 AWG, 100 ohm; 250 Mhz, 4 individually twisted pairs; covered with blue jacket and complying with all relevant parts of and addenda to latest edition of TIA/EIA-568 and UL 444.

- 1. Manufacturer: General Genspeed GS6, Commscope 6504+ or Berk-Tek LANmark-6 Series or equal by Approved Manufacturer.
 - a. Panduit NUL6 Series.
 - b. General Genspeed GS6 Series.
 - c. Berk Tek LANmark-6 Series.
 - d. Hitachi ECO Series
 - e. Approved Equal.
- 2. Plenum rated cable, NFPA 70 type CMP.
- B. Jacks and Connectors: Category 6, 8 position, 8 wire, Modular RJ-45, non-keyed, terminated with 110style insulation displacement connectors (IDC); high impact thermoplastic housing; suitable for and complying with same standard as specified horizontal cable; UL 1863 listed.
 - 1. Performance: 500 mating cycles.
 - 2. Voice and Data Jacks: 4-pair, pre-wired to T568B configuration.
 - 3. Connector modules shall be Panduit Netkey NK688 Series or Signamax MT Series.
 - 4. Jack Colors:
 - a. All Applications: Provide off white colored jack.

2.04 GROUNDING AND BONDING COMPONENTS

- A. Comply with TIA-607.
- B. Comply with Section 26 05 26.

2.05 IDENTIFICATION PRODUCTS

- A. Comply with TIA-606.
- B. Comply with Section 26 05 53.

2.06 SOURCE QUALITY CONTROL

A. Factory test cables according to TIA-568.

2.07 CABLE SUPPORT HANGERS

- A. Manufacturers:
 - 1. Panduit J-Pro Series J-hook.
 - 2. CADDY CAT HP Series J-hook.
 - 3. CADDY CAT 425 Series adjustable strap hanger.
 - 4. Approved Equal.
 - Panduit JP2 Series j-hook shall be used for up to 46 Category 6 4-pair communications cables, 30 Category 6A cables.
 - b. Panduit JP4 Series j-hook shall be used for up to 180 Category 6 cables or 115 Category 6A cables.
 - c. Caddy CAT 425 Series adjustable cable support for up to 325 Category 6 cables, or 210 Category 6A cables.
 - d. Manufacturer guidelines shall be used for supporting/mounting the cable supports. Provide wall mount, ceiling mount, threaded rod clip, beam clamp, etc. mounting option as appropriate for the installation
 - e. Cable shall be supported at no greater than four-foot intervals for Category 6 cable. Provide a cable tie at each J-hook to retain and manage the cable bundle.
 - f. J-hooks or adjustable cable supports. to be UL listed as suitable for air handling plenum spaces.

PART 3 EXECUTION

3.01 INSTALLATION - GENERAL

- A. Comply with latest editions and addenda of TIA-568 (cabling), TIA-569 (pathways), TIA-607 (grounding and bonding), NECA/BICSI 568, NFPA 70, and SYSTEM DESIGN as specified in PART 2.
- B. See Section 26 0534 Conduit for Telecommunications raceway installation requirements.
- C. See Section 26 0526 Grounding and Bonding for Electrical Systems for Telecommunications systems grounding and bonding requirements.
- D. Comply with Communication Service Provider requirements.
- E. Grounding and Bonding: Perform in accordance with TIA-607 and NFPA 70.

3.02 INSTALLATION OF PATHWAYS

- A. Install pathways with the following minimum clearances:
 - 1. 48 inches from motors, generators, frequency converters, transformers, x-ray equipment, and uninterruptible power systems.
 - 2. 12 inches from power conduits and cables and panelboards.
 - 3. 5 inches from fluorescent and high frequency lighting fixtures.
 - 4. 6 inches from flues, hot water pipes, and steam pipes.
- B. Conduit, in Addition to Requirements of Section 26 05 33.13:
 - 1. Arrange conduit to provide no more than the equivalent of two 90 degree bend(s) between pull points.
 - 2. Conduit Bends: Inside radius not less than 10 times conduit internal diameter.
 - 3. Arrange conduit to provide no more than 100 feet between pull points.
 - 4. Do not use conduit bodies.
- C. Conduit:
 - 1. All penetrations through fire barrier walls or floors shall consist of a conduit sleeve and shall be sealed with an industry approved fire barrier caulk or compound reamed and bushed.All vertical/horizontal sleeves shall be sized according to station count passing through each. Sized for maximum 60 percent fill.
 - 2. Install conduit from outlet to a location adjacent to the cable tray above the nearest accessible ceiling. Terminate conduit using an insulated bushing.

3.03 INSTALLATION OF EQUIPMENT AND CABLING

- A. Cabling:
 - 1. Do not bend cable at radius less than manufacturer's recommended bend radius; for unshielded twisted pair use bend radius of not less than 4 times cable diameter.
 - 2. Do not over-cinch or crush cables.
 - 3. Do not exceed manufacturer's recommended cable pull tension.
 - 4. When installing in conduit, use only lubricants approved by cable manufacturer and do not chafe or damage outer jacket.
 - 5. Install cable support hooks a maximum of 4'-0" on center above ceiling.
 - 6. Where telecommunication cables are run exposed above accessible ceilings, support the cables to keep them from resting on ceiling tiles. Use properly sized Cable Caddies or J-Hooks on walls above the ceilings to neatly route cables between outlet and termination locations. Minimum distance between supports is 4 feet or in accordance with EAI/TIA standards, whichever is less.
- B. Service Loops (Slack or Excess Length): Provide the following minimum extra length of cable, looped neatly:

- 1. At Outlets Copper: 12 inches.
- C. Copper Cabling:
 - 1. Category 6 and Above: Maintain cable geometry; do not untwist more than 1/2 inch from point of termination.
 - 2. For 4-pair cables in conduit, do not exceed 25 pounds pull tension.
 - 3. Bridged taps/splices are not allowed as part of the horizontal wiring system.
 - 4. Avoide routing cab les near EMI sources.
 - 5. All cabling shall consist of 4 pairs and 1 cable per jack.
 - 6. Install modular outlets at all locations shown on the Drawings. Terminate wiring at workstation jacks and rack.
 - 7. Install cable from all workstation outlets to rack.
 - 8. Each workstation jack shall be provided with its own UTP cable continuous (without splice) from jack to rack.
 - 9. Telecommunications wiring shall be used for both voice and data wiring.
 - 10. Where indicated, workstation jacks may be ganged under a common wall plate.
- D. Identification:
 - 1. Use wire and cable markers to identify cables at each end.
- E. Field-Installed Labels: Comply with TIA/EIA-606 using encoded identifiers.
 - 1. Cables: Install color coded labels on both ends.
 - 2. Outlets: Label each jack on its face plate as to its type and function, with a unique numerical identifier.
 - 3. All horizontal cabling shall be labeled with permanent tag indication from which jack the cable originated.
 - 4. Machine labels shall be installed on each workstation jack faceplate.
 - 5. All labels shall be a machine label in conformance with ANSI/EIA/TIA 606.
 - 6. Numbering of workstation jacks shall be consistent.
 - 7. Labeling to be verified with Engineer and Owner.
 - 8. Final room numbers to be used for labeling, room numbers on plans are not to be used.

3.04 FIELD QUALITY CONTROL

- A. Comply with inspection and testing requirements of specified installation standards.
- B. Visual Inspection:
 - 1. Inspect cable jackets for certification markings.
 - 2. Inspect cable terminations for color coded labels of proper type.
 - 3. Inspect outlet plates and patch panels for complete labels.
- C. Testing Copper Cabling and Associated Equipment:
 - 1. Test operation of shorting bars in connection blocks.
 - 2. Category 6 Links: Perform tests for wire map, length, insertion loss, NEXT, PSNEXT, ELFNEXT, PSELFEXT, return loss, delay skew and propagation delay.
 - a. Utilize a Level III/Level IV rated tester compatible with the following test standards:
 - 1) TIA-1152 Level IIIe and ISO/IEC 61935-1 Level IV accuracy.
 - 2) TIA-58-C.2, TIA1152 Category 5, 5e, 6, 6A, and ISO/IEC 11801.
 - b. The cabling tester shall be approved for use with the selected connectivity solution for both Channel and Permanent Link tests, and for the associated warranty provided by the connectivity Manufacturers.
 - c. The company/individual testing the cable shall be manufacturer certified for products provided.
 - d. Contractor shall perform and document all conductor tests per TIA-568-B and ANSI/TIA-606. Return one copy of testing report to the Engineer and one copy to the Owner. All copper station runs must be tested after final installation and termination. All cable runs shall be

documented with a hard copy printout of the test results. This printout shall be bound and delivered to the Owner prior to final payment

D. Final Testing: After all work is complete, including installation of telecommunications outlets, and telephone dial tone service is active, test each voice jack for dial tone.

END OF SECTION