

Some questions came up. Here are the questions and answer:

1. Is a bid bond required – Yes.
2. Can we email you the bid – No.
3. Is there any addendums to the bid - No
4. RT #1 – where is the vault being placed. There are existing Vaults/Pull Boxes along that route. The new conduit goes from an existing Pull Box into the building.
5. RT #2 – the print states that the fiber route needs to be completed on each end – what does this mean. – physically, there is fiber there, but it needs to be finished.
What size fiber are we splicing- Plan on splicing 12 strands on each end.
On the print it states existing 2 conduits to be removed – are we removing them – There are no conduits to remove. I was re-using a diagram that was provided during construction and forgot to remove the peripheral information. The diagram is meant to show the layout, not those details.
6. Rt #4 – the print is very vague and the bid sheet states adding 2” pipe – where is this going , on the overhead tray from the doghouse to the wave guide port location?– do you have a different map – There are no pipes to add. The cable can route through the overhead cable tray between the Communications Shed and the Base of the water Tower.
Do you have an approximate length of fiber. – The shed in the diagram is 12’X24’. It appears the distance between the shed and the base of the Water Tower is slightly longer than the width of the Communications Shed. So, I would guess it is about 15’ between the Shed and the base. I am unsure how much to account for inside the shed or the base.
7. Rt #5 – the bid description asks for 2” pipe, vault and pull box - what map are we supposed to look at. The last map in the attachment shows a water tower, Route #5 description says 7th ave north and the attachment list on page 6 of the bid docs under route 05 says 12th ave. – I see that the engineer mislabeled the diagram. It is labeled “FIBER 32 Ave S Water Tower”. That is Page 12 in the PDF that was posted online.

On Question #7 RT-5 you stated that we refer to map Fiber 32nd Ave S water tower, what map are we to use for RT #3?

- 64th Ave WT is Page 14.
- 32nd Ave WT is Page 15.
- 45th St W.T is Page 16.

1. Do we only need to fill out page 5 for the bid? - YES
2. How many copies of the bid form? - ONE
3. Any other documentation required when submitting the bid? – BOND INFORMATION

The specs do not call out for a bid bond anywhere. You have not required a bid bond in the past. I just saw that Q&A requires a Bid bond. I can not get one on this short notice.

Due to a mistake in the RFV development, we did not include a Bid Bond requirement. You will not be required to have a Bid Bond included in your submittals.